



CERTIFICATE OF ANALYSIS

Customer : Whitman
7 Pleasant Hill Road
Cranbury, NJ 08512

Project ID : Atlantic Campus
PAS Project ID : P17-0850

Matrix : Drinking Water
Report Date : 3/2/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0850-01	SL-STAFF LOUNGE-AC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 10:30	2/24/17 13:49
P17-0850-02	KITCHEN-AC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 10:32	2/24/17 13:53
P17-0850-03	CR-101-AC	Lead	1.31 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 10:34	2/24/17 13:57
P17-0850-04	CR-104-AC	Lead	8.94	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 10:35	2/24/17 14:02
P17-0850-05	TRAILER DF-ROOM EXT. 3113-AC	Lead	3.00	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 10:40	2/24/17 14:06
P17-0850-06	CR-106-AC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 10:42	2/24/17 14:10
P17-0850-07	CR-107-AC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 10:43	2/24/17 14:14
P17-0850-08	ICE MACHINE IN KITCHEN-AC	Lead	4.42	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 10:55	2/24/17 14:18
P17-0850-09	FIELD BLANK-AC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 10:57	2/24/17 14:22

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director