

Corporate Headquarters  
 7 Pleasant Hill Road  
 Cranbury, NJ 08512

Tel: 732.390.5858 • Fax: 732.390.9496  
[www.whitmanco.com](http://www.whitmanco.com)

March 9, 2017

Mr. Ronald Wybraniec  
 New Jersey Department of Children and Families  
 50 East State Street  
 Trenton, NJ 08608

RE: Lead in Water Sampling  
 New Jersey Department of Children and Families (NJDCF) Atlantic Campus  
 2562 Tilton Road  
 Egg Harbor Township, New Jersey  
**Whitman Project #16-11-49T**

Dear Mr. Wybraniec:

The potable drinking water sampling, which consisted of six (6) cold faucet samples, one (1) fountain sample, one (1) ice machine sample, and a laboratory blank sample were conducted by Lisa Scarpelli of Whitman on February 20, 2017. First draw samples were collected from all sampling locations, in accordance with the USEPA and NJDEP protocols. All water samples and associated laboratory blanks were transported to Precision Analytical Services, Inc. located in Toms River, New Jersey for analysis. All sample analysis was performed utilizing the USEPA test method “Lead and Copper in Water by Furnace AAS (EPA 200.9)”.

The samples collected from the Atlantic Campus were found to be either not detected (ND) or below the action level of 15.0 ppb established by the USEPA and the NJDEP. Sampling results are summarized below and are provided as an attachment to this letter.

School	Sample Location	Result (ug/L)
Atlantic Campus	Staff Lounge cold faucet	ND
	Kitchen cold faucet	ND
	Classroom 101 cold faucet	1.31
	Classroom 104 cold faucet	8.94
	Trailer Room (Ext. 3113) cold faucet	3.00
	Classroom 106 cold faucet	ND
	Classroom 107 cold faucet	ND
	Kitchen ice machine – filtered sample	4.42
	N/A (Laboratory Blank)	ND

Ronald Wybraniec  
New Jersey Division of Children and Families  
March 10, 2017  
Page 2

Should you have any questions or require additional information, please feel free to contact our office at 732-390-5858.

Very truly yours,



Mark E. Hasting  
Director

MEH/  
Attachment