



CERTIFICATE OF ANALYSIS

Customer : Whitman
7 Pleasant Hill Road
Cranbury, NJ 08512

Project ID : Burlington Campus
PAS Project ID : P17-0853

Matrix : Drinking Water
Report Date : 3/2/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0853-01	KITCHEN-HAND SINK	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 11:29	2/27/17 14:12
P17-0853-02	STAFF RM #105-HAND SINK	Lead	2.84	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 11:32	2/27/17 14:21
P17-0853-03	RM #107-HAND SINK	Lead	1.04 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 11:34	2/27/17 14:25
P17-0853-04	RM #108-HAND SINK	Lead	1.94 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 11:36	2/27/17 14:30
P17-0853-05	RM #112-HAND SINK	Lead	3.43	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 11:38	2/27/17 14:34
P17-0853-06	FIELD BLANK BURLINGTON	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 11:40	2/27/17 14:58

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- B = Compound found in blank and samples
- E = Concentration exceeds calibration range
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director