

May 2, 2006

Contacts – Sunila Agrawal and Hironmoy Sikdar

Workgroup Recommendations and Other Potential Control Measures
Stationary Combustion Sources Workgroup

SCS009 – Municipal Waste Combustors

Control Measure Summary	Emissions (tons/year) in NJ State	
<p>2002 existing measure: Federal performance standards and emissions guidelines for large MWCs (40 CFR 60 Subparts Cb and Eb). To meet the emissions limits in Subparts Cb and Eb, no new control technology was needed. EPA approved state programs as facility-wide averaging for NOx compliance.</p> <p><i>Emission Reductions prior to 2002:</i> 1,489 tons/yr reduction in NOx emissions due to installation of SNCR in 10 MWC units. 10,200 tons/yr reduction in SO2 emissions due to installation of Scrubbers in all MWC units. 23,700 tons/yr reduction in particulate emissions due to installation of Baghouse/ESPs in all MWC units.</p> <p><i>Control Cost:</i> \$7.2 per Mg municipal solid waste combusted for SNCR installation.</p> <p><i>Timing of Implementation:</i> Compliance required December 19, 2000.</p> <p><i>Implementation Area:</i> New Jersey Statewide.</p>	Actual NOx in 2002	1,803
	Actual SO2 in 2002	198
	Actual VOC in 2002	18
	Actual Particulate in 2002	125
<p>Candidate Measures when the Proposed Revised NSPS is Adopted:</p> <p>NOx: EPA’s December 2005 proposed revision of Subpart Cb does not propose any change in NOx emission limits for the existing units and therefore, with the implementation of the proposed rule there will be no NOx reduction in New Jersey.</p> <p>SO2: EPA’s December 2005 proposed revision of Subpart Cb proposes to change SO2 emission limits for the existing units from 29 parts per million dry volume to 23 parts per million dry volume or SO2 control efficiency from 75% to 80% after 4/29/09. Therefore, with the implementation of the proposed rule there will be an SO2 reduction of 422 tons/yr (PTE) in New Jersey.</p> <p>PM: EPA’s December 2005 proposed revision of Subpart Cb proposes to change PM emission limits for the existing units from 27 mg/dscm to 24 mg/dscm after 4/29/09. Therefore, with the implementation of the proposed rule there will be a PM reduction of 26 tons/yr (PTE) in New Jersey.</p>	NOx 2002 PTE	3,541
	PTE reduction after 4/29/06	0
	SO2 2002 PTE	2,040
	PTE reduction after 4/29/06	422
	PM 2002 PTE	237
	PTE reduction after 4/29/06	26

Disclaimer – The recommendations contained within this white paper do not constitute official state decisions nor reflect any pending regulatory or nonregulatory actions. The NJDEP welcomes public feedback on this (or any other) white paper.

May 2, 2006

Contacts – Sunila Agrawal and Hironmoy Sikdar

Workgroup Recommendations and Other Potential Control Measures
Stationary Combustion Sources Workgroup

SCS009 – Municipal Waste Combustors

Policy Recommendation of State:

All of the New Jersey MWC units except Camden CRRF are equipped with SNCR. Camden CRRF does not have SNCR but the facility already accepted a facility-wide emission cap for NO_x equivalent to SNCR at other plants. Therefore, there is very little chance for any further reduction in NO_x emissions from New Jersey MWC units.

All of the New Jersey MWC units have scrubbers for SO₂ control and ESP or baghouses for PM control. Most of them are already achieving the proposed emission limits. The units with ESP control may install baghouses for mercury control, which will help in further reductions of PM. Some units may need minor adjustments of the controls, if they are not achieving the proposed limits.

May 2, 2006

Contacts – Sunila Agrawal and Hironmoy Sikdar

Workgroup Recommendations and Other Potential Control Measures
Stationary Combustion Sources Workgroup

SCS009 – Municipal Waste Combustors

BACKGROUND INFORMATION

New Jersey has five (5) facilities with thirteen (13) municipal waste combustors (MWC) units. Owners and operators of the New Jersey's MWC units were required to comply with the facility specific NOx emission limits according to New Jersey's NOx Regulations adopted in January 1994.

In December 1995, United States Environmental Protection Agency (EPA) adopted new source performance standards (NSPS) (40 CFR 60 subpart Eb) and emission guidelines (subpart Cb) for MWC units with a combustion capacity greater than 250 tons per day. Both the NSPS and emission guidelines require compliance with emission limitations for nine pollutants including NOx that reflect the performance of maximum achievable control technology (MACT). The emission guidelines required compliance by December 2000 for all existing MWC units, while the NSPS apply to new MWC units. As mandated by the Clean Air Act, on November 12, 1998, EPA adopted a Federal Plan to implement and enforce the December 19, 1995, MWC guidelines for existing municipal waste combustors (40 CFR 60 subpart Cb).

On November 9, 1999, New Jersey requested the delegation of authority from EPA. On March 17, 2000, the EPA approved New Jersey's request for delegation of the Federal Plan. On January 24, 2001, New Jersey DEP agreed to the terms and conditions of the Memorandum of Agreement (MOA) to implement and enforce the federal plan for municipal waste combustor (MWC) facilities in New Jersey. Currently, all New Jersey MWC units are in compliance with the federal plan standards.

Owners and operators of eleven (11) of the thirteen (13) MWC units in New Jersey with a combustion capacity greater than 250 tons per day were required to comply with the EPA emissions limits no later than December 19, 2000. Three facilities (Essex, Union and Gloucester) with 8 MWC units that are subject to 40 CFR 60 Subpart Cb have installed selective non-catalytic reduction (SNCR) as NOx control device. One facility (Warren) with two MWC units (combustion capacity less than 250 tons per day), though not subject to Subpart Cb, also installed SNCR. One facility (Camden) with 3 MWC units did not install SNCR, however it is in compliance with the Subpart Cb requirements. The following potential NOx emissions reductions have been achieved in New Jersey after installation of SNCRs at the ten (10) MWC units:

- 1,489 tons per year;
- 624 tons per ozone season; and
- 4.08 tons per day during the ozone season.¹

¹ Assumes 100% rule effectiveness, which is reasonable given that the MWCs are operated with continuous emissions monitoring.

Disclaimer – The recommendations contained within this white paper do not constitute official state decisions nor reflect any pending regulatory or nonregulatory actions. The NJDEP welcomes public feedback on this (or any other) white paper.

May 2, 2006

Contacts – Sunila Agrawal and Hironmoy Sikdar

Workgroup Recommendations and Other Potential Control Measures
Stationary Combustion Sources Workgroup

SCS009 – Municipal Waste Combustors

On December 19, 2005, EPA proposed revisions to the emissions guidelines to reflect the levels of performance achieved due to the installation of control equipment (70 FR 75348). Selective non-catalytic reduction (SNCR) is considered MACT for NO_x under both the 1995 guidelines and the 2005 proposal. Once EPA's December 19, 2005, proposal to update the 1995 emissions standards is adopted, New Jersey will review the final version of the guidelines, and may request another delegation to implement and enforce these standards.

All New Jersey MWC units are equipped with Scrubbers for SO₂ control. Most of these units are already in compliance with the proposed emission limits. However, some units may need minor adjustments to achieve the proposed emission limits. A potential SO₂ emissions reduction of 10,200 tons/yr has been achieved in New Jersey after installation of Scrubbers in all MWC units prior to 2002.

Six (6) of the eleven (11) MWC units in New Jersey (Essex and Camden) that are subject to 40 CFR 60 Subpart Cb have installed Electrostatic Precipitator (ESP) for PM control and rest of the units have installed Baghouse. A potential PM emissions reduction of 23,700 tons/yr has been achieved in New Jersey after installation of ESP/Baghouse in all MWC units prior to 2002. All units are achieving the proposed emission limits. In order to achieve the mercury emission limits, the units with ESPs may install polishing baghouse, which will help further reduction of PM emissions.

Add-on NO_x Control

The number of NO_x-reduction technologies for MWC units are limited as these units use a heterogeneous, wet fuel; are less thermally efficient than fossil fuel-fired boilers of comparable heat input; and require larger amounts of excess air and less densely-packed heat recovery systems. Low-NO_x burners, fuel switching and load curtailment are not possible control options.

The only generally applicable and feasible add-on control technology for reducing NO_x emissions from MWC units is SNCR. SNCR is a chemical process for removing NO_x from flue gas. In the SNCR process, a reagent, typically liquid urea or anhydrous gaseous ammonia, is injected within a boiler or in ducts in a region where the temperature is between 900 and 1,100 degrees Celsius. The reaction converts NO_x to nitrogen gas and water vapor. SNCR performance depends on factors specific to each type of combustion equipment, including flue gas temperature, residence time for the reagent and flue gas, amount of reagent injected, reagent distribution, uncontrolled NO_x level and carbon monoxide and oxygen concentrations.

Some disadvantages arise from the use of SNCR including: the high operating temperatures required; ineffectiveness at high temperatures with low concentrations of NO_x; the need to accommodate enough residence time to complete the chemical reaction at high temperatures; and

Disclaimer – The recommendations contained within this white paper do not constitute official state decisions nor reflect any pending regulatory or nonregulatory actions. The NJDEP welcomes public feedback on this (or any other) white paper.

May 2, 2006

Contacts – Sunila Agrawal and Hironmoy Sikdar

Workgroup Recommendations and Other Potential Control Measures
Stationary Combustion Sources Workgroup

SCS009 – Municipal Waste Combustors

undesirable excess ammonia and urea emissions (ammonia slip) that arise from an incomplete chemical reaction (Thermal Energy International, 2000).

Cost

The capital cost of installing SNCR on a MWC unit is approximately \$1,500 per million British Thermal Units per hour (MMBtu/hr) (see, e.g., Institute of Clean Air Companies, 2000). Most of the cost of using SNCR is in operating expenses (Institute of Clean Air Companies, 2000), which EPA estimates as falling between \$680 and \$1,200 per MMBtu/hr (1993 dollars). Thus, SNCR is well suited for seasonal control in that it may provide significant reductions in NO_x emissions but incurs little cost when the system is not in use. EPA has assigned an ozone season cost effectiveness to SNCR operated on MWC units of \$2,140 per ton of NO_x reduced (1990 dollars)(EPA, 1999, Table 16).

Emissions reductions

In New Jersey, MWC facility owners report potential emissions reductions of 24 to 42% from the operation of SNCR; a typical reduction of 35 to 40% is usually assumed from the installation and operation of SNCR/ammonia injection to MWC units of similar size and type. Other combustors of varying technologies and capacities but with similar baseline NO_x emissions have reported reductions ranging from 35 to 75% from the operation of urea-based SNCR (Appendix 1, Institute of Clean Air Companies, 2000). EPA assigns a typical 45% emission reduction to the effectiveness of SNCR at MWC units (EPA, 1999, Table 16).

In New Jersey, MWC facility owners report actual SO₂ emissions reductions of 83% to 98% from the operation of Scrubbers, which already exceeds the proposed EPA limits. Also, the actual PM emission reductions of greater than 99% have been reported by the owners from the operations of the ESP/Baghouse.

REFERENCES

Institute of Clean Air Companies. May 2000. *Selective Non-Catalytic Reduction (SNCR) for Controlling NO_x Emissions*. <http://www.fueltechnv.com/pdf/TPP-534.pdf>.

U.S. Environmental Protection Agency. November 1999. Nitrogen Oxides (NO_x), *Why and How They are Controlled*. Clean Air Technology Center: EPA 456/F-99-006R.

U.S. Environmental Protection Agency. December 19, 2005. *Standards of Performance for New Stationary Sources and Emission Guidelines for Existing Sources: Large Municipal Waste Combustors; Proposed Rule*. 70 FR 75348.

Ozone Transportation Commission. *Summary of OTC NO_x Control Measures at the MWC Units* http://www.otcair.org/projects_details.asp?FID=92&fview=stationary.

Disclaimer – The recommendations contained within this white paper do not constitute official state decisions nor reflect any pending regulatory or nonregulatory actions. The NJDEP welcomes public feedback on this (or any other) white paper.