

**STATE OF NEW JERSEY
BOARD OF PUBLIC UTILITIES**

**I/M/O THE PETITION OF PUBLIC) BPU Docket Nos. EO13020155 and
SERVICE ELECTRIC & GAS) GO13020156
COMPANY FOR APPROVAL OF)
THE ENERGY STRONG PROGRAM)**

**APPENDIX TO
CHARLES P. SALAMONE'S DIRECT TESTIMONY
ON BEHALF OF THE
DIVISION OF RATE COUNSEL**

**STEFANIE A. BRAND, ESQ.
DIRECTOR, DIVISION OF RATE COUNSEL**

**DIVISION OF RATE COUNSEL
140 East Front Street-4th Floor
P. O. Box 003
Trenton, New Jersey 08625
Phone: 609-984-1460
Email: njratepayer@rpa.state.nj.us**

Dated: October 28, 2013

PUBLIC VERSION

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
QUANTIFY INCREASED RESILIENCY

QUESTION:

Regarding page 2, line 36 of Mr. Cardenas' direct testimony, please explain how the Company intends to quantify increased resiliency of the electric delivery system.

ANSWER:

The attached charts document the assumptions used for customers impacted from each electric investment along with assumptions for the associated reductions in outages and improved restoration times. The assumptions are based on a major Sandy-like storm event with over 90% of customers affected, including storm surge and river flooding.

Based on these assumptions and a storm of the magnitude of Superstorm Sandy, which had 162,495,633 of customer hours interrupted, PSE&G estimates that on average all customers would have seen a 39% reduction in outage time if the proposed investments were in place.

A different set of assumptions on storm impact may lead to different results. However, in all storm events, the investments proposed would lead to decreased outages and improved restoration times than what would otherwise occur.

| Program | Description | Actions | Assumptions in quantifying customers impacted by either elimination of outage or decrease in outage duration | Assumption in quantifying outages that are eliminated Outage duration is 3 days unless noted | Assumptions in quantifying outages that are reduced in duration |
|--|---|--|--|---|---|
| 1. Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA flood guidelines | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | Number of customers supplied either directly or indirectly by the Stations to be protected assuming each station will be impacted once | 33% reduction in 5-day customer outages | With station supply in, customer still out reduced from 5 Days to 4 days |
| 2. Outside Plant Higher Design and Construction Standards | This program will involve improvements to design standards to strengthen construction | Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) | 5% of Customers supplied by 4kV | 20% Reduction of Outages | Due to reduced damage, restoration work will be less, assuming a 10% reduction in outage time of 3 days (7.2 Hours) for Customers out of service |
| | | Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) | 5% of Customers supplied by 26/4kV substations | 50% Reduction due to raised conductors. | Due to reduced damage, restoration work will be less, assuming a 10% reduction in outage time of 3 days (7.2 Hours) for Customers out of service |
| | | Add spacer cable to eliminate open wire to targeted areas | Assume 10 circuits. Average customers/13kV section = 735 Customers/section x 10 circuits | 40% Reduction due to increased ability to withstand weather events | No Benefit |
| 3. Strengthening Pole Infrastructure | This program will involve accelerated pole replacements, additional construction hardening, including reduced pole span lengths, and increased pole diameters This program will evaluate the use of new non-wood material to replace wood poles in the future. | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards | # of poles impacted/total poles in system * customers | 2% Reduction in the number of Outages Due to Poles replaced. Value low due to low coincidence of possible damage with replaced poles. | No Benefit |
| | | Non-wood poles | # of poles impacted/total poles in system * customers | 2% Reduction due to Poles replaced. Value low due to low coincidence of possible damage with replaced poles. | No Benefit |
| 4. Rebuild/Relocate Backyard poles | This program will consider the relocation and rebuilding of backyard pole lines to front lot and/or UG configuration | Rebuild backyard poles (including tree trimming) | Customers supplied by backyard circuits | 50% Reduction | Due to better access and newer facilities restoration work will be decreased by 7.2 hours(10% of 3 days) for Customers out of service |
| 5. Undergrounding | This program will consider the conversion of OH to UG in selected areas and the replacement of PM equipment with a submersible equivalent in targeted areas | A. Convert certain OH areas to UG | Estimate # circuits that could be done to get customer count. Assume 1 mile per circuit, 20 Circuits with average of 735 customers/section | Assume 60% reduction due to damage being avoided on primary lines now Underground. | No Benefit |
| | | B. Replace PM xfmr's with submersible xfmr's in target areas | Avg Customers per padmounted transformers in flood area | Assume 90% reduction in PSE&G equipment outages due to storm surge. Outage duration of 3 days avoided. | No Benefit |
| | | C. Replace ATS switches/transformers with submersible switches | Customer benefit aligned with PM Transformer program as ATS typically supply PM in these areas | Combined with 5B | No Benefit |
| 6. Relocate ESOC/GSOC/DERC/SR | This program will relocate our critical Electrical & Gas dispatch operating centers to a higher level within the existing building, making it less susceptible flooding, etc. | Relocate critical operating centers | Total number of Customers | N/A | Low probability event. Assume 1% probability in a major event with Average 6 hour increase in overall restoration. |
| Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | System Visibility 1a. Expand implementation of 26kV, 13kV, and 4kV Microprocessor Relays and SCADA field equipment (RTUs) to enable remote operation and position indication of each feeder circuit breaker, provide remote monitoring capabilities including circuit and transformer loading, circuit breaker position, load imbalance, will assist in fault location and more. | # Customers in Stations | No Benefit | Assume 4 hour improvement in overall restoration time due to indication of circuit outages, immediate load data for decision making and the ability to remotely set-up circuits for work. |
| | | 1c. System to visualize, control, collect and analyze all monitored points from each Distribution station. This includes SCADA monitors and servers, dispatch consoles, communications switches and servers, historical serves with appropriate back-up and redundancy. (DMS) | Benefits Aligned with 1A | Combined with 1A | Combined with 1A |
| | | Communication Network 2a. High Speed Fiber Optic Network (Backbone)- Transmission - Complete build out equating to approximately 30% of the total system (in-progress). Distribution - Build fiber optic network from [91] of the (125) Distribution substations (Class A, B, C, CN, CS, etc) to facilitate the information transfer from the station to the new DMS system. | Benefits Aligned with 1A | Combined with 1A | Combined with 1A |
| | | 2b. Pilot Satellite Communication Program | Total number of Customers | No Benefit | Low probability event. Assume 5% probability in a major event with Average 12 hour increase in overall restoration. |
| | | Storm Damage Assessment (need all items in System Visibility) 3a. Advanced Distribution Management System (ADMS) functionality to improve visibility of circuit operations in storm conditions and support restoration of customers. Integration of SCADA, DMS, OMS and GIS. | Benefits Aligned with 1A | Combined with 1A | Combined with 1A |
| | | 3b. Enhance Storm Management Systems to improve plant damage assessment process, optimize restoration work plans, integrate mutual aid crews, and develop capability to provide predictive ETRs under complex storm conditions. | Total number of Customers | No Benefit | Through confirmed damage location visibility, improved look-up process and elimination of duplicate records restoration process will be improved. Assume 4 hour improvement in average restoration in overall storm work. |
| | | 3c. Expand communication channels to improve ability to communicate storm-related information to customers. (Outage Map, Mobile App, Preference Management, SMS, Mobile Web) | Total number of Customers | No Benefit | No Benefit |
| Contingency Reconfiguration Strategies | This program refers to the ability of utilities to recover quickly from damage to any of its components | Establish contingency reconfiguration strategies by creating multiple sections, utilizing smart switches, smart fuses, and adding redundancy within our loop scheme | Using CIP 2 Major Results of \$12M per circuit equal 167 13kV circuits. Avg customer count of 1500 = 250,500 | Due to reconfiguration of circuits, loop improvement and fusing, 10% reduction in outages. | With greater system redundancy restoration time on average will improve by 10% (7.2 Hours) |
| Emergency Backup Generator and Quick Connect Stockpile Program | PSE&G to purchase and stockpile emergency backup generators to utilize during storm restoration. Technologies exist whereby a connection can be made to a residential customer electric meter which allows the quick connection of a portable generator. | PSE&G to deploy emergency generators to customers based on priorities driven by local municipal officials. In addition, PSE&G will maintain the supply of quick connects to be deployed as directed. | Number of Generators | No Benefit | Assuming a two day implementation of these measures, outage time reduced by 2 days |
| Municipal Pilot Program | To improve resiliency of the electric system, particularly by engaging valuable municipal resources in the event of prolonged outages | Develop a municipal storm plan which addresses vegetation maintenance, mobile field applications and a combined heat and power (CHP) pilot for targeted critical municipal facilities meeting the high efficiency specifications for application of this technology. | TBD | TBD | TBD |

| Program | Description | Actions | Number of Customers | Avoided Outages (Hrs) | Number of Customer Outages Eliminated | Outage Duration Decrease | Total Customer Hours Outage Reduction (Sum Of Outages Avoided and Duration Decreases) | |
|--|--|--|---------------------|-----------------------|---|------------------------------------|---|-----------|
| 1. Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA flood guidelines | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | 748,500 | 29,640,600 | 247,005 | 11,856,240 | 41,496,840 | |
| 2. Outside Plant Higher Design and Construction Standards | This program will involve improvements to design standards to strengthen construction | Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) | 30,449 | 438,471 | 6,090 | 175,388 | 613,859 | |
| | | Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) | 29,873 | 1,075,437 | 14,937 | 107,544 | 1,182,981 | |
| | | Add spacer cable to eliminate open wire to targeted areas | 7,350 | 211,680 | 2,940 | 0 | 211,680 | |
| 3. Strengthening Pole Infrastructure | This program will involve accelerated pole replacements, additional construction hardening, including reduced pole span lengths, and increased pole diameters | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards | 50,634 | 72,913 | 1,013 | 0 | 72,913 | |
| | This program will evaluate the use of new non-wood material to replace wood poles in the future. | Non-wood poles | 1,407 | 2,025 | 28 | 0 | 2,025 | |
| 4. Rebuild/Relocate Backyard poles | This program will consider the relocation and rebuilding of backyard pole lines to front lot and/or UG configuration | Rebuild backyard poles (including tree trimming) | 36,973 | 1,331,028 | 18,487 | 133,103 | 1,464,131 | |
| 5. Undergrounding | This program will consider the conversion of OH to UG in selected areas and the replacement of PM equipment with a submersible equivalent in targeted areas | A. Convert certain OH areas to UG | 14,700 | 635,040 | 8,820 | 0 | 635,040 | |
| | | B. Replace PM xfmsr with submersible xfmsr in target areas | 1,894 | 122,731 | 1,705 | 0 | 122,731 | |
| | | C. Replace ATS switches/transformers with submersible switches | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | |
| 6. Relocate ESOC/GSOC/DERC/SR | This program will relocate our critical Electrical & Gas dispatch operating centers to a higher level within the existing building, making it less susceptible flooding, etc. | Relocate critical operating centers | 2,250,511 | 0 | 0 | 135,031 | Risk Item not included in hours saved | |
| Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communication to customers. | System Visibility 1a. Expand implementation of 26kV, 13kV, and 4kV Microprocessor Relays and SCADA field equipment (RTUs) to enable remote operation and position indication of each feeder circuit breaker, provide remote monitoring capabilities including circuit and transformer loading, circuit breaker position, load imbalance, will assist in fault location and more. | 1,134,374 | 0 | 0 | 4,537,496 | 4,537,496 | |
| | | 1c. System to visualize, control, collect and analyze all monitored points from each Distribution station. This includes SCADA monitors and servers, dispatch consoles, communications switches and servers, historical servers with appropriate back-up and redundancy. (DMS) | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | |
| | | Communication Network 2a. High Speed Fiber Optic Network (Backbone) - Transmission - Complete build out equating to approximately 30% of the total system (in-progress). Distribution - Build fiber optic network from (91) of the (125) Distribution substations (Class A, B, C, CN, CS, etc) to facilitate the information transfer from the station to the new DMS system. | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | |
| | | 2b. Pilot Satellite Communication Program | 2,250,511 | 0 | 0 | 1,350,307 | Risk Item not included in hours saved | |
| | | Storm Damage Assessment (need all items in System Visibility) 3a. Advanced Distribution Management System (ADMS) functionality to improve visibility of circuit operations in storm conditions and support restoration of customers. Integration of SCADA, DMS, OMS and GIS. | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | |
| | | 3b. Enhance Storm Management Systems to improve plant damage assessment process, optimize restoration work plans, integrate mutual aid crews, and develop capability to provide predictive ETRs under complex storm conditions. | 2,250,511 | 0 | 0 | 9,002,044 | 9,002,044 | |
| | | 3c. Expand communication channels to improve ability to communicate storm-related information to customers. (Outage Map, Mobile App, Preference Management, SMS, Mobile Web) | 2,250,511 | 0 | 0 | 0 | 0 | |
| Contingency Reconfiguration Strategies | This program refers to the ability of utilities to recover quickly from damage to any of its components | Establish contingency reconfiguration strategies by creating multiple sections, utilizing smart switches, smart fuses, and adding redundancy within our loop scheme | 245,824 | 1,769,933 | 24,582 | 1,592,940 | 3,362,872 | |
| Emergency Backup Generator and Quick Connect Stockpile Program | PSE&G to purchase and stockpile emergency backup generators to utilize during storm restoration. Technologies exist whereby a connection can be made to a residential customer electric meter which allows the quick connection of a portable generator. | PSE&G to deploy emergency generators to customers based on priorities driven by local municipal officials. In addition, PSE&G will maintain the supply of quick connects to be deployed as directed. | 200 | 0 | 0 | 9,600 | 9,600 | |
| Municipal Pilot Program | To improve resiliency of the electric system, particularly by engaging valuable municipal resources in the event of prolonged outages | Develop a municipal storm plan which addresses vegetation maintenance, mobile field applications and a combined heat and power (CHP) pilot for targeted critical municipal facilities meeting the high efficiency specifications for application of this technology. | TBD | TBD | TBD | TBD | TBD | |
| | | | | | | Total Outage Hour Reduction | 62,714,213 | |
| | | | | | | Total Customers | 2,250,511 | |
| | | | | | Number of Customer Outages Avoided | 325,606 | Average Outage Reduction Per Customer | 28 |

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
DAMAGE IN TERMS OF DOLLARS, OUTAGES AND EQUIPMENT

QUESTION:

Regarding page 2, lines 44 through 46 of Mr. Cardenas' direct testimony, please quantify the damage in terms of (a) dollar amounts, (b) outage statistics, and (c) damage to PSEG electric infrastructure system equipment for each of the three referenced events.

ANSWER:

Following is a summary of electric costs incurred, outage statistics and infrastructure equipment damage. The summary below is for electric damage only; gas amount and statistics are not included.

A. Dollar Amounts

| Electric Distribution Infrastructure (\$Millions) | |
|--|-------------------|
| | Total Cost |
| Irene | \$ 50.6 |
| October 2011 Snow Storm | \$ 45.8 |
| Superstorm Sandy | \$ 282.4 |

B. Outage Statistics

| Storm | Customers Affected |
|-----------------------------|---------------------------|
| Hurricane Irene | 872,492 |
| October 29, 2011 Snow Storm | 636,898 |
| Super Storm Sandy | 2,014,516 |

C. Damage To PSE&G Electric Infrastructure System Equipment

| Storm | Outside Plant Damage |
|-----------------------------|--|
| Hurricane Irene | 69/26-kV Locations - 78 13/4-kV Locations - 1,384 Transformers - 383 Secondaries - 519 Services - 2,223 Poles - 599 Tree Locations - 2,314 |
| October 29, 2011 Snow Storm | 69/26-kV Locations - 66 13/4-kV Locations - 1,340 Transformers - 274 Secondaries - 541 Services - 16,174 Poles - 298 Tree Locations - 12,041 |
| Superstorm Sandy | 69/26-kV Locations - 355 13/4-kV Locations - 2,504 Transformers - 1,022 Secondaries - N/A Services - 8,330 Poles - 2,500 Tree Locations - 48,000 |

Inside Plant Damage:

A list of PSE&G electric station equipment damaged during Hurricane Irene is as follows:

| | |
|--|--|
| Rahway Cranford Marshall Street Garfield Place River Edge Somerville Hillsdale New Milford | 4 kV and 13kV breakers, voltage regulator controls and relay equipment damaged; AC and DC control systems, auxiliary power system damaged. |
|--|--|

There was no damage to substation equipment during the October 2011 Snow Storm.

RESPONSE TO RATE COUNSEL
 REQUEST: RCR-E-7
 WITNESS(S): CARDENAS
 PAGE 3 OF 4
 ENERGY STRONG PROGRAM

A list of PSE&G electric station equipment damaged during Superstorm Sandy follows:

| | |
|--|---|
| Bayway Substation | 26 and 4 kV breakers and control cabinets and voltage regulator controls damaged. |
| Linden Switch | 138kV breakers and control cabinets, battery chargers and relay equipment damaged. |
| Sewaren Switch | 230, 138 & 26 kV breakers and control cabinet, AC and DC control systems, auxiliary power system damaged. |
| Cliff Road Substation | 26/13kV Unit Substation's breaker damaged. |
| Essex Switch and Substation | 230 kV Transformers' auxiliary equipment, breaker and disconnect motor operators; battery chargers, DC control system and relay equipment, 26 kV breakers and both 26/13kV unit substation and 132 kV Reactor Shunt breakers damaged. |
| Port Street Substation | 26/13kV Unit Substations breaker and relay controls, all 4 kV breakers, voltage regulator controls and relay equipment damaged. |
| Marion Switch | 132-3 Phase 2 Transformer failed, six 26 kV reactors failed, six 26 kV reactors failed, 138/26kV breakers, station battery, DC and AC control systems were damaged. |
| Hudson Switch | 230 kV breakers and disconnect motor operators damaged. |
| Jersey City Switch | Transformer control cabinets, battery chargers, relay equipment and 13 kV breakers damaged. |
| South Waterfront Switch and Substation | 230 kV disconnect motor operators, 26 kV breakers and control cabinets, 13 kV breakers damaged. |
| Bayonne Switch and Substation | 138 and 13 kV disconnect motor operators, relay equipment and 13 kV breakers damaged. |
| St. Paul's Avenue Substation | 26/13 kV Unit Substation, station battery and relay equipment damaged. |
| Howell Street Substation | 4 kV breakers and voltage regulator controls damaged. |
| River Road Substation | 26/13 kV auxiliary switches damaged. |

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-7
WITNESS(S): CARDENAS
PAGE 4 OF 4
ENERGY STRONG PROGRAM

| | |
|----------------------------|--|
| Marshall Street Substation | 4 kV breakers, voltage regulator controls and relay equipment damaged |
| Madison Street Substation | 26 kV breaker compartments, 4 kV breakers, voltage regulator controls and relay equipment damaged. |
| Hoboken Substation | Disconnect motor operator and 13 kV breakers damaged. |
| Third Street Substation | 4 kV breakers, voltage regulator controls and relay equipment damaged. |
| Hackensack Substation | 4 kV reactors failed; 4 kV breakers, voltage regulator controls and relay equipment damaged. |
| Little Ferry Substation | Relay equipment damaged. |

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-6
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
IMPROVEMENTS IN REDUCED OUTAGE FREQUENCY AND DURATION

QUESTION:

Regarding page 2, lines 38 through 41 of Mr. Cardenas' direct testimony, has the Company quantified the anticipated improvements in reduced outage frequency and duration associated with the proposed Energy Strong program? If so, please quantify and provide supporting documentation. If not, please explain why not.

ANSWER:

Please see the response to RCR-E-2, which was developed to estimate the impact of avoided outages and reduced durations. Based on these assumptions and a storm of the magnitude of Superstorm Sandy, which had 162,495,633 of customer hours interrupted, PSE&G estimates that on average all customers would see an approximate 39% reduction in outage time due to the investments proposed.

The 39% reduction is calculated as the total reduced customer outage time from the response to RCR-E-2, page 3, divided by the total customer outage time for Superstorm Sandy listed above ($62,714,213 / 162,495,633 = 38.59\%$).

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
COMPANY'S STATION FLOOD MITIGATION STANDARDS

QUESTION:

For the Company's proposed Station Flood Mitigation program, please provide the Company's current standards and/or mitigation plans to address station flood mitigation.

ANSWER:

Please see the attached PSE&G directive entitled "Preventing/Controlling Tidal Surge and Other Flood-Related Damages in Electric Substations" that was issued on March 13, 2013, after FEMA-adjusted flood data was published on January 24, 2013, as a result of Superstorm Sandy. This directive is intended to address re-design of stations which had work planned prior to Superstorm Sandy. Since FEMA published new flood data, re-design projects have been required to include the recently established flood levels. In all other stations where re-designs were not already planned, PSE&G will follow this directive as work is performed based on equipment failure or based upon assessment of equipment that indicates equipment failure is likely.

Following this directive will only provide incremental improvements in stations over time based upon such equipment failures or assessments. With Energy Strong, PSE&G will complete comprehensive mitigation at the impacted stations in the Program within the term of the Program.

To:

Ananda Kanapathy
Jack Bridges
Shashikant Patel
Robert J Piano, Sr.
Eduardo Pereira
John O'Connell
Paul Toscarelli
Andrew Gleichmann
Matt Rieger
Tim Ambacher
Thomas Brauchle
Mike Kayes
Robert Felton
John Ribardo
Tim McGuire
Gino Leonardis
David Coleman

William Labos
Richard Wernsing
Antonio Mannarino
Robert Pollock
Stan Solowski
Ray Alvarez
Michael Fox
John Hearon
Boris Shvartsberg
Kevin Davideit
Boris Troya
Esam Khadr
Glenn Catenacci
Qamar Arsalan
Kenneth Tanis
Noel Rivera

From: Kevin Davideit

Date: March 13, 2013

Subject: **DIRECTIVE** – **Preventing / Controlling Tidal Surge & Other Flood Related Damage in Substations & Switching Stations**

Historically, the New Jersey Department of Environmental Protection (NJDEP) has taken a strong role in the development of a rigorous floodplain management program at the state level, both pre-dating and supporting those same efforts at the federal level with the Federal Emergency Management Agency (FEMA).

NJDEP is the state agency responsible for coordinating Federal, State and local aspects of flood plain management activities as required under the provisions of the National Flood Insurance Program (NFIP).

The embedded document below provides a high level overview of the aftermath of recent devastating storm events affecting PSE&G substations and switching stations:

- Twenty-one (21) stations impacted by the tidal surge from Superstorm Sandy that fall within the new FEMA Advisory Base Flood Elevations (ABFE).
- Thirteen (13) stations impacted by Hurricane Irene and Other Water Intrusion Events causing flood conditions associated with heavy rains and elevated water levels in rivers, streams, etc. These stations have been cross-referenced with the

- NJDEP Flood Hazard Area Limit (FHAL) mapping to define the design elevations in on-going studies (Initial study prepared by Black & Veatch, 3/2/12).
- Sixty-one (61) other stations subsequently identified as being located within the new FEMA ABFE, the FEMA 100-year base flood elevation (BFE) or are on the fringe of either of these FEMA designated areas. Each station will need to be cross-referenced with the NJDEP FHAL mapping to define flood impacts (if applicable) and the design elevations in future studies. Unlike the ABFE or BFE, FHAL information is not readily available in GIS. Each site will need to be cross-referenced to off-line mapping files. The Surveys and Mapping Group can provide these files. (David.coleman@pseg.com, 973-430-8109).

See page 7 below for site details.

In the aftermath of Superstorm Sandy, a number of PSE&G substations and switching stations were directly impacted by the tidal surge of rivers in northern and central New Jersey.

FEMA has adjusted flood data along this corridor, increasing levels by 2ft to 8ft above previously recorded base flood elevations (BFE).

In January, initial Advisory Base Flood Elevation (ABFE) data was released primarily applying to the following 10 coastal counties and superseding portions of previous FEMA mapping: Atlantic, Bergen, Burlington, Cape May, Essex, Hudson, Middlesex, Monmouth, Ocean and Union.

The remaining counties in which PSE&G services electric customers (Passaic, Somerset, Mercer, Camden and Gloucester) may not be updated if they were not directly affected by the Sandy tidal surges (coastal).

For stations outside of the coastal areas, refer to previously enacted flood hazard area (pre-Sandy) data from:

1. FEMA – Existing fluvial (river/inland waterway) 100-year flood plain base flood elevation (BFE) maps, or
2. NJDEP - Developed maps based on their New Jersey FHAL which may exceed FEMA pre-Sandy 100-year Base Flood Elevations (BFE) by 2 to 3 feet. FHAL, where applicable, will govern for permitting new construction in the state.

Emergency Regulations approved by Governor Christie and NJDEP on 1/24/13 adopted FEMA's updated ABFE maps as the uniform rebuilding standard for the municipalities affected by the tidal surge. The regulations stated that this preliminary ABFE data reflects the most accurate information about 100 year floods available right now. As the mitigation process moves forward, the ABFEs could be adjusted and may be lower as the mapping is finalized and the formal federal maps are adopted over the next 18 to 24 months.

Furthermore, it should be noted that the causes for flooding of stations not directly affected by the tidal surges discussed above are the result of significant rainfall events coupled with any one or a combination of the following scenarios:

1. Overflow of delineated inland (fluvial) waterways.

2. Rapid accumulation and runoff of surface waters from any source. (partially attributable to overdevelopment above the location of older stations causing an increase in impervious surfaces and subsequent decrease in infiltration rates within existing drainage basins/watersheds)
3. Backup or curtailment of surface flow resulting from clogged inlets directly connected to municipal storm sewer systems.

Scenarios 2 and/or 3 may exacerbate a flood condition but can't be readily quantified without direct visual observation/measurement during and after the storm event. To say that the increase in flood level caused by these conditions, if over and above Scenario 1, could possibly mean the difference between a station remaining in service or tripping out may be difficult to ascertain.

In order to prevent future tidal surge and other flood related damage and to consider all possible design alternatives up to and including perimeter flood walls, treat each station site as unique in its own right, greatly influenced by the location and physical characteristics of the parcel of land that it is constructed upon. The following procedure should be implemented going forward:

Phase I

1. Identify and categorize the affected stations as:
 - Sites that were originally constructed in or near established flood hazard zones (excluding those stations that pre-date the formation of NJDEP in 1972 and the development of comprehensive flood studies for the substation areas).
 - Sites that were impacted for the first time by the tidal surges of Sandy and now fall within the new FEMA Advisory Base Flood Elevations (ABFE).
2. At minimum, assume that all critical equipment/structures shall be elevated to 1ft. above the highest design flood elevation as determined by:
 - FEMA Advisory Base Flood Elevation (ABFE + 1)
 - FEMA Base Flood Elevation (BFE + 1)
 - NJDEP Flood Hazard Limit (FHAL + 1)

This would include, but not be limited to, transformer control boxes and secondary containment walls, control enclosures of dead and live tank circuit breakers, CT/PT connection boxes, motor operator control boxes of circuit switchers, AC distribution panels, control house and switchgear floors, neutral grounding resistors, 26kV current limiting reactors, pad mount station light and power transformers, etc.

3. Coordinate the following engineering drawings to produce composite profiles that specifically illustrate the critical equipment/structures and existing 'top of concrete' elevations for all foundations (piers, slabs, walls, etc.) that currently support them. Include key site features (driveways, drainage appurtenances, perimeter fencing, property lines, retaining walls, transformer secondary containment and/or other SPCC diversionary structures, etc.) as appropriate to accurately represent a complete profile:
 - Bus Plans and Sections
 - Property Layout / Site Plan, Sections and Details
 - Foundation Plans, Sections and Details
4. Additionally, request updated boundary and topographic surveys from the Surveys & Mapping Group (Internal Services) for each station. Coordinate development of topographic profiles of the property that correspond to the engineering profiles produced in item 3. Add the associated ABFE, BFE, or FHAL line to each profile. These composite scaled images should provide an accurate representation of existing conditions at each station.

5. **Vertical Datums**

The National Geodetic Vertical Datum of 1929 (NGVD 29), established by the United States Coast and Geodetic Survey (USC&GS), was the official U.S. datum for vertical surveying until the North American Vertical Datum of 1988 (NAVD 88) was released in 1991. Currently, NAVD 88 is the official vertical datum for the United States, against which federal agencies like FEMA measure elevations. It is important to note that PSE&G substations and switching stations whose boundary and topographic surveys were produced prior to PSE&G's transition to NAVD 88 were based on either:

- PS Datum (tied to a local benchmark with an arbitrarily set elevation of 100.00) or
- NGVD 29

Of those stations, only the ones that have experienced major expansions/upgrades in the last 20 years or so (requiring municipal site plan approval) have been re-surveyed in accordance with NAVD 88. This can become an issue especially when the engineering drawings associated with the original installations (item 3) reference the PS Datum or NGVD 29 elevations. These elevations must be converted to NAVD 88 in order to be consistent with FEMA ABFEs. **In other words, all 'active' civil and electrical drawings currently stored in PSE&G's Document Management System (DMS) that contain elevation references must be reviewed and updated to reflect the most recent vertical datum data.** The Surveys and Mapping Group will prepare a vertical datum chart for each station surveyed that will provide conversions between station vertical datum/NGVD29/NAVD88, the associated FEMA 100yr flood elevation, and if applicable, the NJ State studied 100yr flood elevation and Flood Hazard Area Limit elevation.

6. Assume that some major reconstruction of foundations will be required. When the appropriate design alternatives are finalized for each location, obtain new/recently updated geotechnical engineering investigations as necessary to expedite completion of the licensing and permitting process.

Phase II

1. Schedule individual site visits to confirm drawing accuracy and identify other onsite/offsite structures, equipment, topographic and other natural/man-made features requiring consideration when developing flood mitigation design alternatives for discussion.
2. In all cases, the alternative selection process must provide due consideration for continued barrier-free accessibility to these sites for operations and maintenance activities as well as for the safety and security of our employees and customers.

Hardening – Electric Station Flood Mitigation

PSE&G has recently proposed several “hardening and resiliency” initiatives as part of the Energy Strong Program. The Energy Strong Program focuses on those items that will allow the electric system to effectively sustain or quickly respond to future severe, damaging weather related events. In response to concerns associated with flooding this paper provides definitions and tables that describe the stations impacted by Hurricane Irene, Superstorm Sandy and other water intrusion events. Additionally, this paper utilizes the “new” coastal FEMA Advisory Base Flood Elevations (ABFE) and the existing fluvial (river) FEMA 100-year flood plain Base Flood Elevations (BFE) to classify those stations and/or equipment that are at risk to future flooding events or tidal surge events. In general, the stations defined in these tables require further engineering evaluation including, but not limited to updated geo-technical, topographic surveys, storm surge analysis, and hydraulic studies. These engineering efforts will help determine the level of risk and aid in defining the scope for flood protection schemes (relocate/raise-rebuild/flood walls).

- In January 2013 FEMA released the “new” coastal Advisory Base Flood Elevations. These new advisory elevations were approved and accepted by the NJDEP and provide new flood elevations for 10 counties in New Jersey. The new advisory elevations primarily apply to coastal counties only, and supersede portions of previous FEMA mapping.
- The existing fluvial (river) FEMA 100-year flood plain Base Flood Elevation (BFE) maps are based on hydrologic and hydraulic models, topographic and bathymetric surveys (depth of water bodies), and detailed engineering studies. These elevations have been available and historically utilized. For purposes of this paper, the BFE will be applied to all PSE&G facilities not within the new ABFE.

The (21) stations listed in the “Stations Impacted by Sandy” table define the stations that were affected by the tidal surge from Superstorm Sandy and are within the new ABFE.

| Stations (21) Impacted by Sandy | | | |
|--|-------------------|---------------------|-----------------|
| Station Name | Location | Station Name | Location |
| Sewaren 230/138/26kV | Woodbridge | * Bayway Sw. /Sub. | Elizabeth |
| Essex 230/138/26kV | Newark | Madison | Hoboken |
| Hudson 230kV | Jersey City | Hackensack | Hackensack |
| Linden 230/138/26kV | Linden | Jersey City 13kV | Jersey City |
| Bayonne 138/26/13 | Bayonne | St Paul's | Jersey City |
| * Marion 138/26kV | Jersey City | Little Ferry | Little Ferry |
| Hoboken | Hoboken | Howell | Jersey City |
| * Marshall St | Hoboken | Cliff Rd | Woodbridge |
| River Rd | North Bergen | Third St | South Kearny |
| South Waterfront | Jersey City | Port St | Newark |
| ** Newark Airport Breaker Station | Newark /Elizabeth | | |

* Stations impacted by both Hurricane Irene and Superstorm Sandy

** As a result of temporary measures taken prior to Superstorm Sandy, this breaker station was not impacted by storm surge, and is therefore not included in the total number of station outages resulting from the storm.

The (13) stations listed in the “Stations Impacted by Irene and Other Water Intrusion Events” are the stations that were affected by the flooding events from storms with heavy rains and usually associated with elevated water levels from rivers, streams, etc. The majority of these stations do not fall within the new ABFE but, are part of the FEMA BFE. These stations have been cross-referenced with the NJDEP Flood Hazard Limit mapping to define the design elevations in on-going studies.

| Stations (13) Impacted by Irene and Other Water Intrusion Events | | | |
|---|-----------------|---------------------|-----------------|
| Station Name | Location | Station Name | Location |
| * Marion 138/26kV | Jersey City | * Bayway Sw. /Sub. | Elizabeth |
| New Milford | New Milford | * Marshall St | Hoboken |
| Hillsdale | Hillsdale | Ewing | Ewing |
| Somerville Substation | Somerville | Belmont | Garfield |
| Jackson Road | Wayne | Garfield Place | Wallington |
| Rahway Substation | Rahway | River Edge | River Edge |
| Cranford | Cranford | | |

* Stations impacted by both Hurricane Irene and Superstorm Sandy

The stations (61) listed below were identified using FEMA mapping. Each station will be cross-referenced with the NJDEP Flood Hazard Limit mapping to define flood impacts (if applicable) and the design elevations in future studies.

| Stations (61) identified using FEMA mapping | | | |
|--|-------------------|-------------------------------|-----------------|
| Station Name | Location | Station Name | Location |
| 49TH Street Pothead Rack | North Bergen | Lakeside Avenue Substation | Orange |
| Academy Street Substation | Jersey City | Lawnside Substation | Lawnside |
| Albany Street Breaker Station | New Brunswick | Leonia Substation | Leonia |
| Arcola Substation | Paramus | Locust Street Substation | Camden |
| Beaver Brook Substation | Beaver Brook | Market Street Substation | Camden |
| Bennett's Lane Substation | Franklin Twp. | McLean Boulevard Substation | Paterson |
| Bergen Point Substation | Bayonne | Morgan Street Substation | Jersey City |
| Bergen Switching Station | Ridgefield Park | Mountain Avenue Substation | Bridgewater |
| Bridgewater Switching Station | Bridgewater | New Freedom Switching Station | Winslow Twp |
| Camden Switching Station | Pennsauken | Newport Substation | Jersey City |
| Carlstadt Substation | Carlstadt | North Avenue Substation | Elizabeth |
| Clay Street Substation | Newark | North Bergen Substation | North Bergen |
| Constable Hook Substation | Bayonne | Orange Valley Substation | Orange |
| Cuthbert Blvd. Substation | Cherry Hill | Paramus Park Mall Substation | Paramus |
| Dayton Unit Substation | Dayton | Passaic Substation | Passaic |
| Deans Switching Station | South Brunswick | Paterson Substation | Paterson |
| Devils Brook Substation | South Brunswick | Penhorn Substation | Jersey City |
| Edison Switching Station | Edison | Plank Road Substation | Newark |
| Elizabeth Substation | Elizabeth | Ridgefield Substation | Ridgefield Park |
| First Street Substation | Elizabeth | Roseland Switching Switch | Roseland |
| Foundry Street Substation | Newark | Runnemedede Substation | Runnemedede |
| Frank Rodgers Unit Substation | Harrison | State Street Substation | Trenton |
| Franklin Substation | Franklin Twp | Toney's Brook Substation | Bloomfield |
| Gloucester Switching Station | Gloucester | Tremley Substation | Linden |
| Hasbrouck Heights Substation | Hasbrouck Heights | Turnpike Substation | Kearny |
| Hinchman's Avenue Substation | Wayne | Warinanco Substation | Linden |
| Homestead Substation | North Bergen | Waverly Substation | Newark |
| Ironbound Substation | Newark | Westfield Substation | Westfield |

| Stations (61) identified using FEMA mapping | | | |
|--|-----------------|----------------------|-----------|
| Kearny Switch Switching Station | South Kearny | Woodbury Substation | Woodbury |
| Kilmer Substation | Piscataway | Woodlynne Substation | Woodlynne |
| Kingsland Substation | North Arlington | | |

Note:

1. The ABFE were released January 2013 and apply only to the following counties: Atlantic, Bergen, Burlington, Cape May, Essex, Hudson, Middlesex, Monmouth, Ocean and Union.
2. Counties that were not updated in the new ABFE and where PSE&G electric customers are served include: Passaic, Somerset, Mercer, Camden and Gloucester.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-3
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
SUPPORTING STUDIES TO ASSESS RESILIENCY

QUESTION:

With regard to the response to RCR-E-2, please provide supporting studies, if any, relied upon by the Company to assess the resiliency of its electric delivery system.

ANSWER:

The assumptions supporting the impact of the Company's Energy Strong resiliency investments are based on operational knowledge in daily operations and in extreme weather events from experienced PSE&G personnel. Those assumptions were used by the Brattle Group to quantify the benefit to customers. For the Brattle Group Study, see the responses to S-PSEG-ES-2 & S-PSEG-ES-25.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-51
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PAD-MOUNTED SWITCHES

QUESTION:

Regarding page 20, lines 444 of Mr. Cardenas' Direct Testimony, please identify the number of customers served by the 75 identified pad-mounted switches.

ANSWER:

The 58 units that were flooded during Sandy feed approximately 27,000 customers, a combination of both office buildings and residential. The remaining 17 locations in flood prone areas serve approximately 7,900 customers.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-52
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PAD-MOUNTED SWITCHES AND EXISTING TECHNOLOGIES

QUESTION:

Regarding page 20, lines 444 of Mr. Cardenas' Direct Testimony, please provide the estimated cost of replacing the 75 pad-mounted switches with existing technologies.

ANSWER:

The cost of replacing an Automatic Transfer Switch (ATS), post-Superstorm Sandy, was an average of \$85,000. The total estimated cost to replace the 75 pad-mounted switches with existing technologies is \$6.375M.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-57
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
CUSTOMERS SERVED BY PAD-MOUNTED TRANSFORMERS

QUESTION:

Regarding page 22, lines 465 and 466 of Mr. Cardenas' Direct Testimony, please identify the number of customers served by the 200 identified pad-mounted transformers.

ANSWER:

An exact number of customers cannot be determined, until the specific transformers are identified. These large three phase transformers typically supply one to six customers; therefore the number of customers supplied by the submersible replacement transformers will be between 200 and 1200. It is important to note that one customer could be a building with 200 household units expanding the potential impact of a pad mount transformer failing.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-58
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
REPLACEMENT COST OF PAD-MOUNTED TRANSFORMERS

QUESTION:

Regarding page 22, lines 465 and 466 of Mr. Cardenas' Direct Testimony, please provide the estimated cost of replacing the 200 pad-mounted transformers with existing technologies.

ANSWER:

Depending on the complexity of the job and the size of the transformer, the cost to replace a pad mounted transformer is approximately \$10,000. The total estimated cost of replacing the 200 pad-mounted transformers with existing technologies is \$2,000,000.

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PROPOSED CONTINGENCY RECONFIGURATION STRATEGY

QUESTION:

Regarding page 31, lines 679 and 680 of Mr. Cardenas' Direct Testimony, through its proposed contingency reconfiguration strategy is the Company proposing to reconfigure its entire distribution system? If so, please explain. If not, please quantify the number of feeders and circuits targeted for loop reconfiguration.

ANSWER:

The contingency reconfiguration strategy does not propose to reconfigure the entire distribution system. The intent of this strategy is to optimally reconfigure those circuits that could benefit most from this program. The circuit selection criteria consists of the number of customers impacted, historical storm outage data, high profile customers such police, hospitals, sewage and water treatment facilities that have global impact on the community. After completion of the engineering design, the Company will determine the number of targeted circuits.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-28
WITNESS(S): CARDENAS
PAGE 1 OF 6
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
CIRCUIT OUTAGE DATA AND PLANT DAMAGE REPORTS

QUESTION:

Regarding page 14, line 299 of Mr. Cardenas' Direct Testimony, please provide the "circuit outage data and plant damage reports" referenced in the testimony.

ANSWER:

The Company objects to this request due to the volume of all the circuit damage and outage reports and the onerous nature of providing all that information. Notwithstanding or in any way limiting the foregoing, the Company is hereby providing a sample of the data the Company would analyze to select the equipment to be upgraded. Each record is referred to as a plant damage report. Plant damage reports over the past several years will be analyzed, which equates to tens of thousands of records.

Additional data can be provided upon request.

Criteria:
 Includes Momentary and Extended Outages
 Includes "PORPRI", "PORPCA", "PORSEC"
 AND/OR Total Loss of Power
 Excludes Major Outages
 Excludes Service/Meter (Isolated to Customer)

Enterprise Detail Report On Demand with Alerts for: > 3 Hours and Watch List

Last Refresh: 06-04-2013 11:08:11

From: 05/12/2013 To: 05/12/2013

RCR-E-28
 PAGE 2 OF 6

05/12/2013

Central Division

| Incident | Event | Time | - Source Station - (POR DIV) | - Station Circuit - Device | Momentary Customers | Extended Customers | | | | Cust. Not Restored | Total Extended Cust. | Dur. | Type of Construction | Equipment Damaged | Cause of Trouble | |
|---|------------|-------|------------------------------|----------------------------|---------------------|----------------------|--------------------|----------|---|--------------------|----------------------|------|---------------------------------------|-------------------|------------------------------------|--|
| | | | | | <=5 Minutes | >5 Minutes to 1 Hour | >1 Hour to 3 Hours | >3 Hours | | | | | | | | |
| 2004258049 | 2004552780 | 13:59 | Bennetts Lane (03) | BEN8023 SSUB | 0 | 916 | 0 | 0 | 0 | 0 | 916 | 0:14 | 13-kv Insulation(spacer) | Oh transformer | OH - TRANSFORMER | |
| 50 kva Transformer On P-63o57 Redmond St. Near Omaha Rd..trouble Has it So It Is In and Working Presently,however It Is All Burnt And Damaged,and Should Be Replaced Asap. Cbs Tdgpw | | | | | | | | | | | | | | | | |
| 2004258112 | 2004552763 | 14:01 | Brunswick Sub (03) | BRU8013 FUSE | 0 | 0 | 0 | 70 | 0 | 0 | 70 | 7:17 | Bud Construction | Bud primary cable | UG - BUD - CABLE | |
| Bud 98 Multi problems... Pd 175 Transformer Was Filled With Mud And Could Not Operate... Cable Failure Between 628 And 111... And To Top It Off The Cutout Had To Be Change Before Energizing... All Cust Restored... Cbs Tdgpw | | | | | | | | | | | | | | | | |
| 2004258149 | 2004552827 | 17:06 | Kilmer (03) | KIL8023 SSUB Watch List | 0 | 0 | 1,712 | 0 | 0 | 0 | 1,712 | 1:18 | Owa 3 Ph Covered | Oh conductor | OH - CONDUCTOR - OPEN WIRE ARMLESS | |
| | 2004552830 | 17:06 | Kilmer (03) | KIL8023 REC_FRL Watch List | 79 | 0 | 0 | 0 | 0 | 0 | 0 | 0:01 | Owa 3 Ph Covered | Oh conductor | OH - CONDUCTOR - OPEN WIRE ARMLESS | |
| Phase Down. Made Safe And Restored. Line Dept To Make Repairs. Cbs Tdgpw | | | | | | | | | | | | | | | | |
| Central Division Totals: | | | | | 79 | 916 | 1,712 | 70 | 0 | 0 | 2,698 | | Preliminary Daily CAIDI: 65.59 | | | |

Criteria:
 Includes Momentary and Extended Outages
 Includes "PORPRI", "PORPCA", "PORSEC"
 AND/OR Total Loss of Power
 Excludes Major Outages
 Excludes Service/Meter (Isolated to Customer)

Enterprise Detail Report On Demand with Alerts for: > 3 Hours and Watch List

Last Refresh: 06-04-2013 11:08:11

From: 05/12/2013 To: 05/12/2013

RCR-E-28
 PAGE 3 OF 6

05/12/2013

Metro Division

| Incident | Event | Time | - Source Station - (POR DIV) | - Station Circuit - Device | Momentary Customers | Extended Customers | | | | Cust. Not Restored | Total Extended Cust. | Dur. | Type of Construction | Equipment Damaged | Cause of Trouble |
|--|--|-------|------------------------------|----------------------------|---------------------|----------------------|--------------------|----------|---|--------------------|----------------------|---------------------------------------|----------------------|-------------------|------------------|
| | | | | | <=5 Minutes | >5 Minutes to 1 Hour | >1 Hour to 3 Hours | >3 Hours | | | | | | | |
| 2004258216 | 2004552884 PORPRI PSED-05122 013-0185 | 18:51 | Paterson (07) | PAT4012 SSUB | 0 | 685 | 0 | 0 | 0 | 685 | 0:45 | 4-kv Spacer Cable | Oh transformer | OH - TAP | |
| Primary Tap To A 50kva Lighting Pot Of A Open Delta @ 83 Lafayette St, Pat Pulled Out Of Bushing And Grounded Pot On Pole 65165, Repaired Temp | | | | | | | | | | | | | | | |
| Metro Division Totals: | | | | | 0 | 685 | 0 | 0 | 0 | 685 | | Preliminary Daily CAIDI: 45.00 | | | |

Criteria:
 Includes Momentary and Extended Outages
 Includes "PORPRI", "PORNCA", "PORSEC"
 AND/OR Total Loss of Power
 Excludes Major Outages
 Excludes Service/Meter (Isolated to Customer)

Enterprise Detail Report On Demand with Alerts for: > 3 Hours and Watch List

Last Refresh: 06-04-2013 11:08:11

RCR-E-28
 PAGE 4 OF 6

From: 05/12/2013 To: 05/12/2013

05/12/2013

Palisades Division

| Incident | Event | Time | - Source Station - (POR DIV) | - Station Circuit - Device | Momentary Customers | Extended Customers | | | | Total Extended Cust. | Dur. | Type of Construction | Equipment Damaged | Cause of Trouble |
|--|--|-------|------------------------------|--------------------------------|---------------------|----------------------|--------------------|----------|--------------------|----------------------|------|---------------------------------------|-------------------|-----------------------------|
| | | | | | <=5 Minutes | >5 Minutes to 1 Hour | >1 Hour to 3 Hours | >3 Hours | Cust. Not Restored | | | | | |
| 2004257976 | 2004552618 PORPRI PSED-05122 013-0026 | 06:30 | Saddle Brook (05) | SAD8043 REC_FRL | 1,068 | 0 | 0 | 0 | 0 | 0 | 0:01 | 13-kv Shielded Spacer Cable | None | UNKNOWN - NO TROUBLE FOUND |
| F-r, No Reports Of Trouble To Be Patrolled Cbs Tdj9t | | | | | | | | | | | | | | |
| 2004258000 | 2004552653 PORPRI PSED-05122 013-0034 | 07:10 | East Rutherford Sub (05) | EAT8021 FUUSE | 0 | 0 | 274 | 0 | 0 | 274 | 1:01 | 2 Ph Covered(crossarm) | None | OH - TREE - NON PREVENTABLE |
| F-o, Limb Cut Clear Refused Ok Cbs Tdj9d | | | | | | | | | | | | | | |
| 2004258122 | 2004552787 PORPRI PSED-05122 013-0134 | 14:21 | River Edge (05) | RIG8003 FUUSE Watch List | 0 | 0 | 44 | 0 | 0 | 44 | 2:09 | 2 Ph Covered(crossarm) | Oh conductor | OH - TREE - NON PREVENTABLE |
| F-o, Tree Condition Brought Phase Down Cbs Tdj9t | | | | | | | | | | | | | | |
| 2004258171 | 2004552850 PORPRI PSED-05122 013-0163 | 17:04 | Waldwick (05) | WAD8015 FUUSE Watch List | 0 | 0 | 11 | 0 | 0 | 11 | 1:07 | Bud Construction | Bud riser cable | UG - BUD - RISER |
| F-o, Riser Cable Bad Ref To Ug P62303, Primary Break Closed Everyone Back In Power , 18:12 Cbs Tdj9t | | | | | | | | | | | | | | |
| Palisades Division Totals: | | | | | 1,068 | 0 | 329 | 0 | 0 | 329 | | Preliminary Daily CAIDI: 70.29 | | |

Criteria:
 Includes Momentary and Extended Outages
 Includes "PORPRI", "PORNCA", "PORSEC"
 AND/OR Total Loss of Power
 Excludes Major Outages
 Excludes Service/Meter (Isolated to Customer)

Enterprise Detail Report On Demand with Alerts for: > 3 Hours and Watch List

Last Refresh: 06-04-2013 11:08:11

From: 05/12/2013 To: 05/12/2013

RCR-E-28
 PAGE 5 OF 6

05/12/2013

Southern Division

| Incident | Event | Time | - Source Station - (POR DIV) | - Station Circuit - Device | Momentary Customers | | Extended Customers | | | | Dur. | Type of Construction | Equipment Damaged | Cause of Trouble |
|---|--|-------|------------------------------|----------------------------|---------------------|----------------------|--------------------|----------|--------------------|----------------------|------|-----------------------------|-------------------|-------------------------|
| | | | | | <=5 Minutes | >5 Minutes to 1 Hour | >1 Hour to 3 Hours | >3 Hours | Cust. Not Restored | Total Extended Cust. | | | | |
| 2004257973 | 2004552593 PORPRI PSED-05122 013-0024 | 06:07 | Marlton (08) | MAR8003 REC_FRL | 536 | 0 | 0 | 0 | 0 | 0 | 0:01 | 13-kv Insulation(spacer) | Oh conductor | OH - ANIMAL - HAD GUARD |
| Oh Called Out To Repair Main Line Spacer. Custs Bis. Feeding Both Ways.. cbs Cmves | | | | | | | | | | | | | | |
| 2004257979 | 2004552625 PORPRI PSED-05122 013-0028 | 06:30 | Lawnside (08) | LAW8015 SSUB | 0 | 0 | 536 | 0 | 0 | 536 | 1:14 | 1 Ph Covered(standoff) | Oh transformer | OH - ANIMAL - HAD GUARD |
| | 2004552622 PORPRI PSED-05122 013-0172 | 06:31 | Lawnside (08) | LAW8015 REC_FRL | 240 | 0 | 0 | 0 | 0 | 0 | 0:01 | 1 Ph Covered(ridge Pin) | Oh transformer | OH - ANIMAL - NO GUARD |
| P#60739 Transformer Lid Blew Off. Animal Contact. Trans. Jumpers Installed In Front Of House #43....law 8015 Fr Would Not Close And Had To Wait Til Op Went To Station To Get Cust Back, Law 8015-25 X-fer Bkr Closed Due To Tran Outage, Cbs Cmves | | | | | | | | | | | | | | |
| 2004257981 | 2004552627 PORPRI PSED-05122 013-0037 | 07:10 | Beaver Brook (08) | BEA8006 FUZE | 0 | 0 | 14 | 0 | 0 | 14 | 1:13 | 1 Ph Bare(ridge Pin) | None | OH - ANIMAL - HAD GUARD |
| P#60740 Animal Contact At Transformer, Refused Lateral At 100a. Trans Ok cbs Cmves | | | | | | | | | | | | | | |
| 2004257986 | 2004552632 PORPRI PSED-05122 013-0029 | 06:49 | Bustleton (08) | BUS8011 FUZE | 0 | 0 | 7 | 0 | 0 | 7 | 2:21 | 13-kv Shielded Spacer Cable | Arrester | OH - ANIMAL - HAD GUARD |
| All Custs. Bis 0910hrs. Rfo. Cbs Cmves | | | | | | | | | | | | | | |

Criteria:
 Includes Momentary and Extended Outages
 Includes "PORPRI", "PORPCA", "PORSEC"
 AND/OR Total Loss of Power
 Excludes Major Outages
 Excludes Service/Meter (Isolated to Customer)

Enterprise Detail Report On Demand with Alerts for: > 3 Hours and Watch List

Last Refresh: 06-04-2013 11:08:11

From: 05/12/2013 To: 05/12/2013

RCR-E-28
 PAGE 6 OF 6

05/12/2013

Southern Division

| Incident | Event | Time | - Source Station - (POR DIV) | - Station Circuit - Device | Momentary Customers | | Extended Customers | | | | Dur. | Type of Construction | Equipment Damaged | Cause of Trouble | |
|--|--|-------|------------------------------|----------------------------|---------------------|----------------------|--------------------|----------|--------------------|----------------------|------|----------------------|---------------------------------------|------------------|-----------------------------|
| | | | | | <=5 Minutes | >5 Minutes to 1 Hour | >1 Hour to 3 Hours | >3 Hours | Cust. Not Restored | Total Extended Cust. | | | | | |
| 2004258042 | 2004552689 PORPRI PSED-05122 013-0089 | 11:17 | Maple Shade (08) | MAD8038 FUSE | 0 | 0 | 21 | 0 | 0 | 0 | 21 | 1:23 | 3 Ph Bare(armless) | None | UNKNOWN - NO TROUBLE FOUND |
| Patrolled Clear, Refused Ok. All Custs. Cbs Cmves | | | | | | | | | | | | | | | |
| 2004258183 | 2004552878 PORPRI PSED-05122 013-0170 | 17:48 | Fernwood Unit 8051 (08) | FEN8051 FUSE | 0 | 27 | 0 | 0 | 0 | 0 | 27 | 0:41 | 1 Ph Covered(ridge Pin) | None | OH - CUTOUT - SWITCH |
| Cutout Blew At Pole 66758 Patrolled Circuit Line Was Clear..refused At Same Pole 65amp..fuse Holding Customers Back In Power..complete cbs Cmves | | | | | | | | | | | | | | | |
| 2004258219 | 2004552883 PORPRI PSED-05122 013-0184 | 18:56 | Penns Neck (08) | PEK8035 FUSE | 0 | 19 | 0 | 0 | 0 | 0 | 19 | 0:38 | 1 Ph Covered(ridge Pin) | None | OH - TREE - NON PREVENTABLE |
| Tree Limb Down On 1/0 Primary And Neutral. Cut Clear And Refuse 100 Amps At Pole 62109 To Restore Power. Cbs Cmves | | | | | | | | | | | | | | | |
| Southern Division Totals: | | | | | 776 | 46 | 578 | 0 | 0 | 0 | 624 | | Preliminary Daily CAIDI: 72.51 | | |

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
BACKYARD CONSTRUCTION AREAS

QUESTION:

Regarding page 18, lines 389 and 392 of Mr. Cardenas' Direct Testimony, please identify the number of linear feet of lines and the number of back yard poles in the Company's service territory.

ANSWER:

PSE&G has identified the associated towns and approximate number of customers supplied by backyard construction areas. PSE&G does not track backyard construction and other construction types separately and distinctly in its data and mapping systems. Based on this customer count, an estimate was made of the linear feet of conductor and the number of poles for backyard areas.

| <u>DESCRIPTION</u> | <u>QUANTITY</u> |
|--------------------------|-----------------------|
| Municipalities | 53 |
| Customers | 36,970 |
| Linear feet of conductor | 2,218,380 (420 miles) |
| Number of poles | 22,184 |

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-67
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
CIRCUITS CURRENTLY WITH SCADA

QUESTION:

Regarding the response to RCR-E-66, how many of those circuits and feeders with supervisory control and data acquisition (“SCADA”) field equipment were damaged in each of the following three major storm events: Hurricane Irene, Derecho, and Superstorm Sandy.

ANSWER:

Approximately 405 circuits with SCADA field equipment were damaged during Superstorm Sandy and 225 were damaged during Hurricane Irene.

The Derecho event did not affect PSE&G’s service territory.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-99
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
STUDIES SUPPORTING UNDERGROUNDING PROGRAM

QUESTION:

With regard to the response to RCR-E-2, please provide any and all studies conducted, commissioned, and/or relied upon by the company regarding converting circuits from Overhead to Underground as part of the Undergrounding program

ANSWER:

In the development of the targeted underground program, PSE&G reviewed the following documents: Edison Electric Institute (EEI) report entitled “Out of Sight, Out of Mind – 2012, An Updated Study on the Undergrounding Of Overhead Power Lines,” published in January 2013, and the Edison Electric Institute (EEI) report entitled “Before And After The Storm, A compilation of recent studies programs and policies related to storm hardening and resiliency,” published in January 2013.

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
UNDERGROUNDING PROGRAM CRITERIA

QUESTION:

With regard to the response to RCR-E-2, what criteria were used to determine which circuits would be converted from Overhead to Underground as part of the Undergrounding program?

ANSWER:

The selection criteria for the target undergrounding program is based on

- area accessibility (for trucks and heavy equipment)
- conditions of the terrain (including vegetation density and tree root mitigation)
- soil conditions (rock vs. dirt and compactness of ground material)
- outage history (based on major storm events)
- circuit criticality (number of critical customers such as emergency services, water treatment plants, etc.)
- station supply circuits (circuits which feed substations)

The identification of the exact circuits to be selected for this program is still a work in progress.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-113
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
VEGETATION MANAGEMENT

QUESTION:

Has the Company evaluated enhanced vegetation management as an alternative to its proposed Energy Strong program? If so, please provide any analyses. If not, please explain why not.

ANSWER:

Please see the responses to S-PSEG-ES-61 and RCR-E-82.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-126
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
FREQUENCY OF MAJOR STORM EVENTS

QUESTION:

Is it the Company's opinion that major events like Hurricane Irene and Sandy will be more frequent in the future? Please explain the Company's position and identify the sources of information relied upon by the Company to support its conclusion.

ANSWER:

Based on recent experiences of extreme weather such as the storms referenced in this question, the Company proposed Energy Strong to harden the PSE&G distribution systems and system and make the systems more resilient to better withstand and respond to extreme weather conditions in the future. The Company has not developed a forecast of future extreme events.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-114
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
RESPONSE TO MAJOR STORM EVENTS

QUESTION:

Is it the Company's opinion that its (a.) present and (b.) proposed response for major storm events is reasonable and prudent? If so, please explain. If not, please explain why not.

ANSWER:

Yes. The Company's current plans to respond to major storm events build upon the plans used and implemented during Superstorm Sandy, which were reasonable and prudent by any reasonable measure. Since the future plans build upon and improve on that response, PSE&G's proposed plans are also reasonable and prudent.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-131
WITNESS(S): CARDENAS
PAGE 1 OF 3
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
COST/BENEFIT ANALYSIS FOR OTHER STORMS

QUESTION:

With reference to the response to S-PSEG-ES-2, please restate the cost benefit analysis of the proposed Energy Strong program for (a.) Hurricane Irene and (b.) October Storm scenarios. Please provide all supporting inputs and calculations in electronic format with formulae intact.

ANSWER:

- a. Please refer to Excel document named RCR-E-131-1 - Hurricane Irene.xls Tab Q131.
- b. Please refer to Excel document named RCR-E-131-2 - October SnowStorm.xls Tab Q131.

Cost Benefits Analysis – Hurricane Irene

| Program | Actions | Total Estimated Costs (\$ Million) | Number of Customers affected | Avoided Outages (Hrs) | Outage Duration Decrease (Hrs) | Total Customer Outage Reduction (Hrs) | Value (to customers) of Lost Load (\$ Million) | Cost/Benefit Ratio | Rank Based on Cost/Benefit Ratio |
|---|--|------------------------------------|------------------------------|-----------------------|--------------------------------|---------------------------------------|--|--------------------|----------------------------------|
| 1. Station Flood Mitigation | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | \$ 1,678 | 169,020 | 2,342,617 | 937,047 | 3,279,664 | \$ 1,244.82 | 1.35 | 1 |
| 2. Outside Plant Higher Design and Construction Standards | Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) | \$ 65 | 12,012 | 46,132 | 18,453 | 64,584 | \$ 24.51 | 1.68 | 2 |
| | Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) | \$ 60 | 11,784 | 113,147 | 11,315 | 124,462 | \$ 47.24 | | |
| | Add spacer cable to eliminate open wire to targeted areas | \$ 10 | 2,899 | 22,271 | 0 | 22,271 | \$ 8.45 | | |
| 3. Strengthening Pole Infrastructure | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards | \$ 102 | 19,631 | 7,540 | 0 | 7,540 | \$ 2.86 | 35.70 | 4 |
| | Non-wood poles | \$ 3 | 545 | 209 | 0 | 209 | \$ 0.08 | | |
| 4. Rebuild/Relocate Backyard poles | Rebuild backyard poles (including tree trimming) | \$ 100 | 14,585 | 140,038 | 14,004 | 154,042 | \$ 0.12 | 827.85 | 5 |
| 5. Undergrounding | A. Convert certain OH areas to UG | \$ 60 | 5,799 | 66,813 | 0 | 66,813 | \$ 25.36 | 2.51 | 3 |
| | B. Replace PM xfmrs with submersible xfmrs in target areas | \$ 8 | 747 | 12,913 | 0 | 12,913 | \$ 4.90 | | |
| | C. Replace ATS switches/transformers with submersible switches | \$ 8 | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | \$ - | | |
| 6. Relocate ESOC/GSOC/DERC/SR | Relocate critical operating centers | \$ 15 | 872,492 | 0 | 0 | 0 | \$ - | No Benefit | 0 |

Cost Benefits Analysis – 2011 October Snowstorm

| Program | Actions | Total Estimated Costs (\$ Million) | Number of Customers affected | Avoided Outages (Hrs) | Outage Duration Decrease (Hrs) | Total Customer Outage Reduction (Hrs) | Value (to customers) of Lost Load (\$ Million) | Cost/Benefit Ratio | Rank Based on Cost/Benefit Ratio |
|---|--|------------------------------------|------------------------------|-----------------------|--------------------------------|---------------------------------------|--|--------------------|----------------------------------|
| 1. Station Flood Mitigation | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | \$ 1,678 | 0 | 0 | 0 | 0 | \$ - | No Benefit | 0 |
| 2. Outside Plant Higher Design and Construction Standards | Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) | \$ 65 | 8,768 | 38,622 | 15,449 | 54,071 | \$ 20.52 | 2.01 | 1 |
| | Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) | \$ 60 | 8,602 | 94,729 | 9,473 | 104,202 | \$ 39.55 | | |
| | Add spacer cable to eliminate open wire to targeted areas | \$ 10 | 2,116 | 18,646 | 0 | 18,646 | \$ 7.08 | | |
| 3. Strengthening Pole Infrastructure | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards | \$ 102 | 14,330 | 6,312 | 0 | 6,312 | \$ 2.40 | 42.64 | 3 |
| | Non-wood poles | \$ 3 | 398 | 175 | 0 | 175 | \$ 0.07 | | |
| 4. Rebuild/Relocate Backyard poles | Rebuild backyard poles (including tree trimming) | \$ 100 | 10,647 | 117,242 | 11,724 | 128,966 | \$ 0.10 | 988.81 | 4 |
| 5. Undergrounding | A. Convert certain OH areas to UG | \$ 60 | 4,233 | 55,937 | 0 | 55,937 | \$ 21.23 | 3.00 | 2 |
| | B. Replace PM xfms with submersible xfms in target areas | \$ 8 | 545 | 10,811 | 0 | 10,811 | \$ 4.10 | | |
| | C. Replace ATS switches/transformers with submersible switches | \$ 8 | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | \$ - | | |
| 6. Relocate ESOC/GSOC/DERC/SR | Relocate critical operating centers | \$ 15 | 636,898 | 0 | 0 | 0 | \$ - | No Benefit | 0 |

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-140
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
UPDATED COST-BENEFIT ANALYSIS

QUESTION:

With reference to the response to AARP-9, will PSE&G provide an updated cost-benefit analysis if the proposed Energy Strong Program is approved?

ANSWER:

Please see the Response to RCR-G-POL-83.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-10
WITNESS(S): CARDENAS
PAGE 1 OF 3
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PA CONSULTING REPORTS

QUESTION:

Regarding page 5, line 112 of Mr. Cardenas' direct testimony, please provide the PA Consulting reports referenced in footnote 1.

ANSWER:

Please note that in footnote 1 there is no reference to "PA Consulting" reports. The PA Consulting Group does issue a letter each year where outstanding reliability performance is recognized. In PSE&G's case, the letters state that PSE&G's process for collecting, analyzing, verifying and reporting reliability statistics has been certified by PA Consulting for its accuracy and completeness and that the reported reliability statistics fairly represent the actual reliability of the system.

Below is a listing of the performance years and awards for which PSE&G was recognized:

2001 - Mid-Atlantic Award
2002 - Mid-Atlantic Award
2003 - Mid-Atlantic Award
2004 - Mid-Atlantic Award, National Award
2005 - Mid-Atlantic Award, National Award
2006 - Mid-Atlantic Award
2007 - Mid-Atlantic Award, National Award
2008 - Mid-Atlantic Award, National Award
2009 - Mid-Atlantic Award
2010 - Mid-Atlantic Award, Outage Response to a Major Event (March 2010 Nor'easter)
2011 - Mid-Atlantic Award, National Award, Outage Response to a Major Event (Hurricane Irene and the October Snowstorm)

Attached are copies of the letters to PSE&G from the PA Consulting Group recognizing PSE&G's outstanding reliability performance for the years 2011 and 2010.



45th Floor
The Chrysler Building
405 Lexington Avenue
New York, NY 10174
www.paconsulting.com

Tel: +1 212 973 5900
Fax: +1 212 973 5959

October 23rd, 2012

Mr. John Latka
Vice President, Electric Operations
Public Service Electric and Gas Company
80 Park Plaza
Newark, NJ 07101

Dear John:

PA Consulting Group has completed its Reliability Certification Review of Public Service Electric and Gas (PSE&G) Company's distribution reliability results for the year ending December 31, 2011. We are pleased to report that within industry norms and standards PSE&G's process for collecting, analyzing, verifying and reporting reliability statistics has been certified by PA Consulting Group for its accuracy and completeness and we believe that the reported reliability statistics fairly represent the actual reliability of the system.

Our examination was made in accordance with generally accepted utility industry practices and formulas, and accordingly included a review of the outage records and all relevant procedures. These efforts included: (1) conducting interviews with the personnel involved in the data collection, calculation and reporting of electric distribution outage statistics, (2) reviewing and documenting the processes involved, (3) examining the policies, procedures, forms and records used to gather and report results, and (4) sampling and analysis of outage data.

PA Consulting Group congratulates PSE&G for their outstanding reliability performance for the year 2011.

Best regards,

A handwritten signature in black ink that reads 'Jeffrey H. Lewis'.

Jeffrey H. Lewis
Program Director - ReliabilityOne™
Practice Head and Member of PA's Management Group



ReliabilityOne™

AWARDED BY PA Consulting Group

45th Floor
The Chrysler Building
405 Lexington Avenue
New York, NY 10174

Tel: +1 212 973 5900
Fax: +1 212 973 5959
www.paconsulting.com

November 15, 2011

Mr. John Latka
Vice President, Electric Operations
Public Service Electric and Gas Company
80 Park Plaza
Newark, NJ 07101

Dear John:

PA Consulting Group has completed its Reliability Certification Review of Public Service Electric and Gas (PSE&G) Company's distribution reliability results for the year ending December 31, 2010. We are pleased to report that within industry norms and standards PSE&G's process for collecting, analyzing, verifying and reporting reliability statistics has been certified by PA Consulting Group for its accuracy and completeness and we believe that the reported reliability statistics fairly represent the actual reliability of the system.

Our examination was made in accordance with generally accepted utility industry practices and formulas, and accordingly included a review of the outage records and all relevant procedures. These efforts included: (1) conducting interviews with the personnel involved in the data collection, calculation and reporting of electric distribution outage statistics, (2) reviewing and documenting the processes involved, (3) examining the policies, procedures, forms and records used to gather and report results, and (4) sampling and analysis of outage data.

PA Consulting Group congratulates PSE&G for their outstanding reliability performance for the year 2010.

Best regards,

A handwritten signature in blue ink that reads "Jeffrey H. Lewis".

Jeffrey H. Lewis
Program Director - ReliabilityOne™
Practice Head and Member of PA's Management Group

Encl: ReliabilityOne™ Replica

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ROR-8
WITNESS(S):
PAGE 1 OF 21
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
BOARD OF DIRECTORS PRESENTATIONS

QUESTION:

Please provide copies of any presentations to the PSE&G and PEG Boards of Directors concerning the Energy Strong Program.

ANSWER:

Attached please find the following presentations to the PSEG Board of Directors on the Energy Strong Program:

1. PSE&G - Transmission and Distribution (Energy Strong Infrastructure Program) Infrastructure Investments, dated February 19, 2012
2. PSE&G - Current Developments and Initiatives dated April 16, 2013

*PSE&G – Transmission and Distribution
(Energy Strong Infrastructure Program)
Infrastructure Investments*

February 19, 2013

Ralph LaRossa

President and Chief Operating Officer, PSE&G



Transmission and Distribution Infrastructure Investments

- As a result of unprecedented weather events over the last two years, PSE&G is proposing investments to work towards improving our ability to withstand and recover from severe storms
- PSE&G is proposing to file a petition with the NJBPU seeking approval for an Energy Strong Infrastructure Program (ESIP) which will harden electric and gas distribution infrastructure making it less susceptible to extreme wind and water damage
- In addition, the filing would propose investments to increase the resiliency of the electric distribution system to recover more quickly from damage to any of its components or any of the external systems on which it depends
- The filing complements the NJBPU's recently issued order requiring all Electric Distribution Companies to take specific actions to improve preparedness and response to major storms
- ESIP's methodology and cost recovery are modeled after the 2009 Capital Infrastructure Program (CIP I) providing contemporaneous returns and requesting our allowed ROE of 10.3% and cost of capital approved in our 2010 rate case

Transmission and Distribution Infrastructure Investments (cont'd)


- In addition to the filing, there are Transmission projects associated with station flood mitigation that are proposed and would be handled separately through the FERC Formula Rate process and are not part of the NJBPU filing
- Transmission projects are assumed to receive the allowed ROE of 11.68% with no incentives

Distribution (ESIP) and Transmission Investment Levels

| | \$ Millions | 2013 | 2014 | 2015 | 2016 | 2017 | 2018-2023 | Total |
|----------------------------------|--------------|-----------|------------|------------|------------|------------|--------------|--------------|
| Electric Distribution Investment | | 40 | 183 | 291 | 421 | 415 | 1,412 | 2,762 |
| Gas Distribution Investment | | 30 | 195 | 222 | 223 | 235 | 276 | 1,180 |
| Transmission Investment | | - | 99 | 107 | 181 | 183 | 974 | 1,544 |
| | Total | 70 | 476 | 621 | 825 | 833 | 2,662 | 5,486 |
| | O&M | 1 | 5 | 5 | 3 | 2 | 0 | 15 |

- ESIP represents a potential investment of approximately \$2.8 billion for Electric Distribution and \$1.2 billion for Gas Delivery over a 10 year period
- Transmission investment of approximately \$1.5 billion would be included in future FERC Formula Rate filings

environmentally responsible, forward-looking investments that enhance our energy infrastructure, create **economic activity** and **jobs**, while keeping **utility rates lower** than the rate of inflation



2008

- Named Most Reliable Electric Utility in the nation
- Solar loan program approved, breaking down barriers to installation
- Programs approved to offer home energy efficiency audits, programmable thermostats and CFL bulbs

2013

- Named Most Reliable Electric Utility in the nation – five time winner
- EEI Awards for Emergency Recovery and Outstanding Response to a Major Event (Sandy, Irene, Oct. 2011 snowstorm)
- Electric and gas infrastructure, transmission, solar, and energy efficiency investments create 8,600 jobs and related economic activity
- 160 MWs of solar – enough to power 27,000 homes and avoid emissions equal to taking 25,000 cars off the road for a year
- Energy efficiency investments save 160 GWhs – enough to power 23,000 homes – and save 5 million therms, equal to taking almost 6,000 cars off the road for a year

2018

- Investments in solar, energy efficiency, electric and gas infrastructure putting more than 7,500 people to work, creating hundreds of millions in related economic activity
- 393 MWs of solar – enough to power 65,000 homes and avoid emissions equal to taking 60,000 cars off the road for a year
- Energy efficiency investments save 640 GWhs – enough to power 90,000 homes – and 35 million therms, equal to taking 40,000 cars off the road for a year

ESIP and Transmission Hardening Scenario

Caroline Dorsa

Executive Vice President and Chief Financial Officer

ESIP Scenario Assumptions

Remove Unapproved Utility Programs

- Gas CIP III (\$1.4B)
- Solar 4 All extension (\$0.6B)
- Solar Loan III (\$0.1B)
- Energy Efficiency for All (\$0.2B)

Replace with:

- Electric Distribution Hardening \$1.4B
- Gas Distribution Hardening \$0.9B
- Transmission Hardening \$0.6B

Net \$0.6B increase in Capital Spending over the Plan horizon

Earnings profiles assume contemporaneous returns on Distribution investments and formula rates for Transmission investments

REDACTED

Enterprise Financial Results – ESIP Scenario

| | <u>2013</u> | <u>2014</u> | <u>2015</u> | <u>2016</u> | <u>2017</u> | <u>EPS CAGR</u> <u>2013-2017</u> |
|---|-------------|-------------|-------------|-------------|-------------|-------------------------------------|
| Operating EPS | | | | | | |
| PSE&G | | | | | | |
| Power | | | | | | |
| Holdings/Parent | | | | | | |
| PSEG | | | | | | |
| <i>Delta from Final Plan</i> | | | | | | |
| Earnings % from Regulated | | | | | | |
| <i>Delta from Final Plan</i> | | | | | | |
| Payout Ratio | | | | | | |
| <i>Delta from Final Plan</i> | | | | | | |
| ROIC | | | | | | |
| <i>Delta from Final Plan</i> | | | | | | |
| Power FFO/Debt | | | | | | |
| <i>Delta from Final Plan</i> | | | | | | |
| Investment Capacity (\$ in Billions) | | | | | | |
| <i>Delta from Final Plan</i> | | | | | | |

- Investments at PSE&G result in a rate base CAGR of [REDACTED] through 2015 and [REDACTED] through 2017 from year-end 2012 levels

Request for approval

- Request your approval to file the 5 year Energy Strong Infrastructure Program with the NJBPU on Feb 20, 2013
- Request approval for Electric Transmission investments as described

Appendix

Energy Strong Infrastructure Program (ESIP) – Hardening – Electric Distribution

| Program | Description | Actions | Length of Program* (years) | Distribution (\$ Million) | | Total Estimated Costs (\$ Million) |
|---|---|---|----------------------------|---------------------------|----------------|------------------------------------|
| | | | | Capital | O&M | |
| 1. Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA flood guidelines | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls | 10 | \$ 1,680.0 | \$ - | \$ 1,680.0 |
| 2. Outside Plant Higher Design and Construction Standards | This program will involve improvements to design standards to strengthen construction | Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) | 5 | \$ 65.0 | \$ - | \$ 65.0 |
| | | Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) | 5 | \$ 60.0 | \$ - | \$ 60.0 |
| | | Add spacer cable to eliminate open wire to targeted areas | 5 | \$ 10.0 | \$ - | \$ 10.0 |
| 3. Strengthening Pole Infrastructure | This program will involve accelerated pole replacements, additional construction hardening, including reduced pole span lengths, and increased pole diameters | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards | 5 | \$ 102.0 | \$ 10.0 | \$ 112.0 |
| | This program will evaluate the use of new non-wood material to replace wood poles in the future | Non-wood poles | 5 | \$ 3.0 | \$ - | \$ 3.0 |
| 4. Rebuild/Relocate Backyard poles | This program will consider the relocation and rebuilding of backyard pole lines to front lot and/or UG configuration | Rebuild backyard poles (including tree trimming) | 5 | \$ 100.0 | \$ - | \$ 100.0 |
| 5. Undergrounding | This program will consider the conversion of OH to UG in selected areas and the replacement of PM equipment with a submersible equivalent in targeted areas | A. Replace ATS switches/transformers with submersible switches | 5 | \$ 8.0 | \$ - | \$ 8.0 |
| | | B. Replace PM xfms with submersible xfms in target areas | 5 | \$ 8.0 | \$ - | \$ 8.0 |
| | | C. Convert certain OH areas to UG | 5 | \$ 60.0 | \$ - | \$ 60.0 |
| 6. Relocate critical operating centers | This program will relocate our critical dispatch operating centers to a higher level within the existing building, making it less susceptible flooding, etc | Relocate DERC/GSOC | 2 | \$ 15.0 | \$ 1.0 | \$ 16.0 |
| Sub Total | | | | \$ 2,111.0 | \$ 11.0 | \$ 2,122.0 |

Energy Strong Infrastructure Program (ESIP) – Resiliency – Electric Distribution

| Program | Description | Actions | Length of Program* (years) | Distribution (\$ Million) | | Total Estimated Costs (\$ Million) |
|--|---|---|----------------------------|---------------------------|------|------------------------------------|
| | | | | Capital | O&M | |
| Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | System Visibility 1a. Expand implementation of 26kV, 13kV, and 4kV Microprocessor Relays and SCADA field equipment (RTUs) to enable remote operation and position indication of each feeder circuit breaker, provide remote monitoring capabilities including circuit and transformer loading, circuit breaker position, load imbalance, will assist in fault location and more | 10 | \$ 250.0 | \$ - | \$ 250.0 |
| | | 1c. System to visualize, control, collect and analyze all monitored points from each Distribution station. This includes SCADA monitors and servers, dispatch consoles, communications switches and servers, historical serves with appropriate back-up and redundancy (DMS) | 10 | \$ 50.0 | \$ - | \$ 50.0 |
| | | Communication Network 2a. High Speed Fiber Optic Network (Backbone) - Distribution - Build fiber optic network from (91) of the (125) Distribution substations (Class A, B, C, CN, CS, etc) to facilitate the information transfer from the station to the new DMS system | 10 | \$ 73.0 | \$ - | \$ 73.0 |
| | | 2b. Evaluate Satellite Communication | 5 | \$ 3.0 | \$ - | \$ 3.0 |
| | | Storm Damage Assessment (need all items in System Visibility) 3a. Advanced Distribution Management System (ADMS) functionality to improve visibility of circuit operations in storm conditions and support restoration of customers. Integration of SCADA, DMS, OMS and GIS | 10 | \$ 15.0 | \$ - | \$ 15.0 |
| | | 3b. Enhance Storm Management Systems to improve plant damage assessment process, optimize restoration work plans, integrate mutual aid crews, and develop capability to provide predictive ETRs under complex storm conditions | 4 | \$ 50.0 | \$ - | \$ 50.0 |
| | | 3c. Expand communication channels to improve ability to communicate storm-related information to customers. (Outage Map, Mobile App, Preference Management, SMS, Mobile Web) | 3 | \$ 10.0 | \$ - | \$ 10.0 |
| Contingency Reconfiguration Strategies | This program refers to the ability of utilities to recover quickly from damage to any of its components | Establish contingency reconfiguration strategies by creating multiple sections, utilizing smart switches, smart fuses, and adding redundancy within our loop scheme | 5 | \$ 200.0 | \$ - | \$ 200.0 |
| Sub Total | | | | \$ 651.0 | \$ - | \$ 651.0 |

Energy Strong Infrastructure Program (ESIP) – Electric Distribution – Supplemental Projects

| Program | Description | Actions | Length of Program* (years) | Distribution | | Total Estimated Costs (\$ Million) |
|--|--|--|-------------------------------|--------------|-----|---------------------------------------|
| | | | | Capital | O&M | |
| Emergency Backup Generator and Quick Connect Stockpile | The program involves stockpiling generators which can be used to power critical business sectors during extended outages. Technologies exist whereby a connection can be made to a customer electric meter which allows the quick connection of a portable generator | PSE&G proposes a program to stockpile emergency generators and quick connects | TBD | TBD | TBD | TBD |
| Municipal Pilot Program | To improve resiliency of the electric system, particularly by engaging valuable municipal resources in the event of prolonged outages | Develop a municipal storm plan which addresses vegetation management and mobile field applications | TBD | TBD | TBD | TBD |

Energy Strong Infrastructure Program (ESIP) – Hardening – Gas Delivery

| Program | Description | Actions | Length of Program* (years) | Distribution | | Total Estimated Costs (\$ Million) |
|--|---|---|-------------------------------|-------------------|------|---------------------------------------|
| | | | | Capital | O&M | |
| Metering & Regulating Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA flood guidelines | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls | 8 | \$ 140.0 | \$ - | \$ 140.0 |
| Utilization Pressure Cast Iron (UPCI) | This program will consider accelerated UPCI main and associated services and district regulator replacements located within or in proximity of a flood hazard zone. | Replace existing UPCI main and associated district regulators with plastic or coated cathodically protected welded steel. Replace with high pressure and abandon regulators where feasible - 750 miles | 5 | \$ 870.0 | \$ - | \$ 870.0 |
| | | Replace existing unprotected steel services connected to the UPCI mains - 40,000 | 5 | \$ 170.0 | \$ - | \$ 170.0 |
| Gas Total | | | | \$ 1,180.0 | \$ - | \$ 1,180.0 |

Hardening and Resiliency - Transmission

| Program | Description | Actions | Length of Program* (years) | Transmission | | Total Estimated Costs (\$ Million) |
|-------------------------------------|---|---|----------------------------|-------------------|---------------|------------------------------------|
| | | | | Capital | O&M | |
| Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA flood guidelines | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls | 10 | \$ 1,520.0 | \$ - | \$ 1,520.0 |
| Relocate critical operating centers | This program will relocate our critical dispatch operating centers to a higher level within the existing building, making it less susceptible flooding, etc | Relocate ESOC/System Reliability | 2 | \$ 21.0 | \$ 1.5 | \$ 22.5 |
| Advanced Technologies | This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers | Evaluate Satellite Communication | 5 | \$ 3.0 | \$ - | \$ 3.0 |
| ED Transmission Total | | | | \$ 1,544.0 | \$ 1.5 | \$ 1,545.5 |

ESIP and Transmission Modeling Assumptions

ESIP assumptions

- Electric and gas distribution assets are placed in service monthly. Spending is assumed to start in July 2013 for both Electric and Gas projects
- The program's methodology and recovery of costs are modeled after the 2009 Capital Infrastructure Program (CIP I) providing contemporaneous returns and requesting our allowed ROE of 10.3% and cost of capital approved in our 2010 rate case

Transmission Hardening and Resiliency assumptions

- Transmission assets are placed in service on an annual basis. Spending is assumed to start in January 2014
- Transmission projects are assumed to receive the allowed ROE of 11.68% with no incentives

PSE&G – Current Developments and Initiatives

April 16, 2013

Ralph LaRossa

President and Chief Operating Officer, PSE&G



PSE&G – Initiatives

PSE&G Key Priorities

Operational Excellence

- Maintain top quartile operational results
 - Flawlessly execute capital investment programs
-

Financial Strength

- Successfully manage regulatory relationships
 - Continue execution of initiatives focused on cost control
-

Disciplined Investment

- Identification of additional Transmission investment opportunities
- **Approval and implementation of Energy Strong program (ES), Solar 4 All Extension (S4Ae) and Solar Loan III**
- Approval and implementation of Energy Efficiency 4 All* (EE4A)


*Program not filed with the New Jersey Board of Public Utilities

Energy Strong Update

- Filed Rates for Energy Strong on March 20, 2013
 - Customer bills expected to remain steady while making necessary improvements to reduce outages
- Established multi-tiered advocacy approach
 - Created PSEGAdvocacy.com website
 - Reaching out to employees, unions, customers, municipalities and businesses
 - Received support from Mayors, Chamber of Commerce and others
 - Quickly addressing questions and negative comments
- NJBPU response
 - Order establishing Generic Proceeding to review costs, benefits, and reliability impacts of major storm event mitigation efforts and review of Energy Strong petition
 - Order establishing Generic Proceeding to evaluate prudence of major storm event restoration costs for 2011 and 2012

Making New Jersey **energy strong**

environmentally responsible, forward-looking investments that enhance our energy infrastructure, create **economic activity** and **jobs**, while keeping **utility rates lower** than the rate of inflation



RESPONSE TO AARP
REQUEST: AARP-3
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
COST BENEFIT ANALYSIS

QUESTION:

Describe the internal cost benefit analysis conducted by PSE&G prior to filing the Energy Strong application. In your response, describe the internal analysis and identify the information that was provided to and led to internal management's approval of these proposed investments in each general category.

ANSWER:

No formal cost benefit analysis was performed prior to internal management approval. While no formal analysis was performed, each of the investments proposed address a specific issue experienced during the major storm event of the previous two years.

After experiencing the damaging effects of Superstorm Sandy, PSE&G developed this plan to harden the Company's infrastructure and increase the resilience of the system in the context of a major weather event. The Company believes that the programs proposed in the Energy Strong Petition are prudent investments, but that these investments do not need to be made in order to provide safe, adequate and proper service.

PSE&G Engineering associates were assembled to identify system enhancements that would accomplish hardening and resiliency benefits. The projects selected represent the best engineering judgment of PSE&G internal experts. PSE&G's internal management approved the proposed investments being submitted to the BPU as part of the overall Energy Strong Program.

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PROPOSED CONTINGENCY RECONFIGURATION STRATEGY

QUESTION:

Regarding page 31, lines 679 and 680 of Mr. Cardenas' Direct Testimony, through its proposed contingency reconfiguration strategy is the Company proposing to reconfigure its entire distribution system? If so, please explain. If not, please quantify the number of feeders and circuits targeted for loop reconfiguration.

ANSWER:

The contingency reconfiguration strategy does not propose to reconfigure the entire distribution system. The intent of this strategy is to optimally reconfigure those circuits that could benefit most from this program. The circuit selection criteria consists of the number of customers impacted, historical storm outage data, high profile customers such police, hospitals, sewage and water treatment facilities that have global impact on the community. After completion of the engineering design, the Company will determine the number of targeted circuits.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-82
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PROPOSED SUPPLEMENTAL VEGETATION MANAGEMENT PROGRAM

QUESTION:

Regarding pages 34 and 35, lines 752 and 754 of Mr. Cardenas' Direct Testimony, is the Company's proposed vegetation management program in addition to the Company's current vegetation management program? If so, please explain.

ANSWER:

The proposed vegetation management program is in addition to the Company's current vegetation management program. This would be a pilot program to establish a collaborative plan with a municipality on how vegetation will be managed around electric distribution facilities. The plan is to include educational components regarding utility line clearance trimming standards and the selection and placement of vegetation in close proximity to electric infrastructure. The plan will also develop a process to engage the municipality in identifying and removing danger trees that potentially compromise electric distribution facilities.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-E-86
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PSEG INVESTMENT EVALUATION SYSTEM

QUESTION:

For each project included in the Company's Energy Strong Program, please indicate if the project has been ranked in the PSEG Scorecard - Investment Evaluation System. If so, please indicate the ranking for the project, what the results mean, and when the analysis was conducted. If not, please explain why not.

ANSWER:

The Energy Strong programs were defined after the events of Superstorm Sandy, which occurred outside the normal prioritization process where the Investment Evaluation System (IES) is used. More importantly the Energy Strong investments are for improved storm response to extreme weather events, which fall beyond the scope of the current IES system. The IES system prioritizes projects using current scorecard metrics which do not reflect extreme weather events and therefore is not used to evaluate the Energy Strong investments.

RESPONSE TO AARP
REQUEST: AARP-10
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
WORKPAPERS ASSOCIATED WITH RCR-E-2.

QUESTION:

Provide the workpapers associated with the attachment provided in response to RCR-E-2.

ANSWER:

Please see the Excel workbook provided with this response for the workpapers associated with this response.

Table ES- 5. Estimated Average Electric Customer Interruption Costs US 2008\$ Anytin

| Interruption Cost | Interruption Duration | | |
|---------------------------------|-----------------------|------------|----------|
| | Momentary | 30 minutes | 1 hour |
| Medium and Large C&I | | 0.5 | 1 |
| Cost Per Event | \$6,558 | \$9,217 | \$12,487 |
| Cost Per Average kW | \$8.0 | \$11.3 | \$15.3 |
| Cost Per Un-served kWh | \$96.5 | \$22.6 | \$15.3 |
| Cost Per Annual kWh | \$0.0009 | \$0.0013 | \$0.0018 |
| Small C&I | | 0.5 | 1 |
| Cost Per Event | \$293 | \$435 | \$619 |
| Cost Per Average kW | \$133.7 | \$198.1 | \$282.0 |
| Cost Per Un-served kWh | \$1,604.1 | \$396.3 | \$282.0 |
| Cost Per Annual kWh | \$0.0153 | \$0.0226 | \$0.0322 |
| Residential | | 0.5 | 1 |
| Cost Per Event | \$2.1 | \$2.7 | \$3.3 |
| Cost Per Average kW | \$1.4 | \$1.8 | \$2.2 |
| Cost Per Un-served kWh | \$16.8 | \$3.5 | \$2.2 |
| Cost Per Annual kWh | \$0.0002 | \$0.0002 | \$0.0002 |

KW Load factor

Residential
 Small C&I
 Large C&I

ne By Duration and Customer Type

| 4 hours | | 8 hours | |
|-----------|--|-----------|--|
| 4 | | 8 | |
| \$42,506 | | \$69,284 | |
| \$52.1 | | \$85.0 | |
| \$13.0 | | \$10.6 | |
| \$0.0060 | | \$0.0097 | |
| 4 | | 8 | |
| \$2,623 | | \$5,195 | |
| \$1,195.8 | | \$2,368.6 | |
| \$298.9 | | \$296.1 | |
| \$0.1370 | | \$0.2700 | |
| 4 | | 8 | |
| \$7.4 | | \$10.6 | |
| \$4.9 | | \$6.9 | |
| \$1.2 | | \$0.9 | |
| \$0.0006 | | \$0.0008 | |

Source: FERC F

| | Average number of Customers |
|-----------------------------------|-----------------------------|
| Residential | |
| Residential Service RS | 1,846,380 |
| Residential Heating Service RHS | 12,297 |
| Water Heating Service WH | 2,046 |
| Water Heating Storage Service WHS | 26 |
| Residential Load Management RLM | 13,023 |
| | |
| Commercial and industrial | |
| Water Heating Service WH | 16 |
| General ltg and power service | 271,430 |
| Large Power and Ltg Service | 9,417 |
| High Tension Service HTS | 206 |

Total customers 2,162,684

Total PSE&G customers in 2013 from PSE&G 2,250,511

| Mix of customers in use | # of customers |
|-------------------------|----------------|
| Residential | 1,873,795 |
| Small C&I | 279,271 |
| Medium and Large C&I | 9,618 |
| Total | 2,162,684 |

From Berkeley's study

Sector Annual kWh

Medium and Large C&I 7,140,501

Small C&I 19,214

Residential 13,351

ORM 1 for 2012

| |
|---------------------------|
| KWh of Sales Per Customer |
| |
| 7,116 |
| 12,426 |
| 980 |
| 1,500 |
| 19,175 |
| |
| 1,313 |
| 28,798 |
| 1,592,205 |
| 23,143,539 |

| Mix of customers based on Form 1 | |
|----------------------------------|----------------|
| | # of customers |
| Residential | 1,873,772 |
| Small C&I | 271,446 |
| Medium and Large C&I | 9,623 |
| Total | 2,154,841 |

| |
|---------|
| |
| Percent |
| 86.64% |
| 12.91% |
| 0.44% |
| 1 |

Mix of customers from PSE&G

| | # of customers |
|--------------------------|----------------|
| Residential | 1,873,795 |
| Small and medium C&I | 279,271 |
| Large C&I | 9,618 |
| Lighting | 25,868 |
| Total | 2,188,551 |
| Total excluding lighting | 2,162,684 |

| | |
|---------|-------------|
| | |
| Percent | |
| | 86.64% |
| | 12.55% |
| | 0.44% |
| | 0.996373488 |

| Kwh used in a year | Rates |
|--------------------|-----------------|
| 13,463,591,430 | RS, WH,WHS, RLM |
| 7,914,259,281 | GLP and HS |
| 19,741,791,968 | LPL and HTS |
| 448,806,642 | PSAL/BPL/BPLPOF |
| 41,568,449,321 | |

| Customer class | Total KWH | Average customers | kwh/customer |
|----------------|----------------|-------------------|--------------|
| Residential | 13,543,739,382 | 1,871,632 | 7,236 |
| Commercial | 23,537,934,535 | 289,308 | 81,359 |
| Industrial | 4,221,149,930 | 9,046 | 466,632 |
| Lighting | 329,190,762 | 10,094 | 32,613 |
| Total | 41,632,014,609 | 2,180,080 | |

kwh/customer/hour

0.82

9.26

53.12

3.71

Title: Gross Domestic Product: Implicit Price Deflator
 Series ID: GDPDEF
 Source: U.S. Department of Commerce: Bureau of Economic Analysis
 Release: Gross Domestic Product
 Seasonal Adjustment: Seasonally Adjusted
 Frequency: Annual
 Aggregation Method: Average
 Units: Index 2005=100
 Date Range: 1990-01-01 to 2012-10-01
 Last Updated: 2013-03-28 8:01 AM CDT
 Notes: The number of decimal places reported varies over time. A Guide to the National Income and Product Accounts of the United States (NIPA) - (<http://www.bea.gov/national/pdf/nipaguid.pdf>)

| DATE | VALUE |
|------------|---------|
| 1990-01-01 | 72.263 |
| 1991-01-01 | 74.820 |
| 1992-01-01 | 76.592 |
| 1993-01-01 | 78.287 |
| 1994-01-01 | 79.935 |
| 1995-01-01 | 81.603 |
| 1996-01-01 | 83.154 |
| 1997-01-01 | 84.624 |
| 1998-01-01 | 85.579 |
| 1999-01-01 | 86.837 |
| 2000-01-01 | 88.718 |
| 2001-01-01 | 90.726 |
| 2002-01-01 | 92.194 |
| 2003-01-01 | 94.128 |
| 2004-01-01 | 96.779 |
| 2005-01-01 | 99.993 |
| 2006-01-01 | 103.228 |
| 2007-01-01 | 106.222 |
| 2008-01-01 | 108.589 |
| 2009-01-01 | 109.529 |
| 2010-01-01 | 110.989 |
| 2011-01-01 | 113.355 |
| 2012-01-01 | 115.383 |

Between 2008 and 2010 1.06

| Program | Actions |
|---|--|
| 1. Station Flood Mitigation | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. |
| 2. Outside Plant Higher Design and Construction Standards | Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) |
| | Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) |
| | Add spacer cable to eliminate open wire to targeted areas |
| 3. Strengthening Pole Infrastructure | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards |
| | Non-wood poles |
| 4. Rebuild/Relocate Backyard poles | Rebuild backyard poles (including tree trimming) |
| 5. Undergrounding | A. Convert certain OH areas to UG |
| | B. Replace PM xfmrs with submersible xfmrs in target areas |
| | C. Replace ATS switches/transformers with submersible switches |
| 6. Relocate ESOC/GSOC/DERC/SR | Relocate critical operating centers |

| | |
|--|--|
| Advanced Technologies | <p>System Visibility</p> <p>1a. Expand implementation of 26kV, 13kV, and 4kV Microprocessor Relays and SCADA field equipment (RTUs) to enable remote operation and position indication of each feeder circuit breaker, provide remote monitoring capabilities including circuit and transformer loading, circuit breaker position, load imbalance, will assist in fault location and more.</p> |
| | <p>1c. System to visualize, control, collect and analyze all monitored points from each Distribution station. This includes SCADA monitors and servers, dispatch consoles, communications switches and servers, historical serves with appropriate back-up and redundancy. (DMS)</p> |
| | <p>Communication Network</p> <p>2a. High Speed Fiber Optic Network (Backbone)- Transmission - Complete build out equating to approximately 30% of the total system (in-progress). Distribution - Build fiber optic network from (91) of the (125) Distribution substations (Class A, B, C, CN, CS, etc) to facilitate the information transfer from the station to the new DMS system.</p> |
| | <p>2b. Pilot Satellite Communication Program</p> |
| | <p>Storm Damage Assessment (need all items in System Visibility)</p> <p>3a. Advanced Distribution Management System (ADMS) functionality to improve visibility of circuit operations in storm conditions and support restoration of customers. Integration of SCADA, DMS, OMS and GIS.</p> |
| | <p>3b. Enhance Storm Management Systems to improve plant damage assessment process, optimize restoration work plans, integrate mutual aid crews, and develop capability to provide predictive ETRs under complex storm conditions.</p> |
| | <p>3c. Expand communication channels to improve ability to communicate storm-related information to customers. (Outage Map, Mobile App, Preference Management, SMS, Mobile Web)</p> |
| Contingency Reconfiguration Strategies | Establish contingency reconfiguration strategies by creating multiple sections, utilizing smart switches, smart fuses, and adding redundancy within our loop scheme |
| Emergency Backup Generator and Quick Connect Stockpile Program | PSE&G to deploy emergency generators to customers based on priorities driven by local municipal officials. In addition, PSE&G will maintain the supply of quick connects to be deployed as directed. |

| | |
|-------------------------|--|
| Municipal Pilot Program | Develop a municipal storm plan which addresses vegetation maintenance, mobile field applications and a combined heat and power (CHP) pilot for targeted critical municipal facilities meeting the high efficiency specifications for application of this technology. |
|-------------------------|--|

| Total Estimated Costs (\$ Million) | Number of Customers | Avoided Outages (Hrs) | Outage Duration Decrease (Hrs) | Total Customer Outage Reduction (Hrs) | Total Custom Custc |
|------------------------------------|---------------------|-----------------------|--------------------------------|---------------------------------------|--------------------|
| | | | | | Residential |
| \$ 1,678 | 748,500 | 29,640,600 | 8,982,000 | 41,496,840 | 29,482,064 |
| \$ 65 | 30,449 | 438,471 | 365,392 | 613,859 | 436,125 |
| \$ 60 | 29,873 | 1,075,437 | 358,479 | 1,182,981 | 840,467 |
| \$ 10 | 7,350 | 211,680 | 88,200 | 211,680 | 150,391 |
| \$ 102 | 50,634 | 72,913 | 607,611 | 72,913 | 51,802 |
| \$ 3 | 1,407 | 2,025 | 16,879 | 2,025 | 1,439 |
| \$ 100 | 36,973 | 1,331,028 | 443,676 | 1,464,131 | 1,200,587 |
| \$ 60 | 14,700 | 635,040 | 176,400 | 635,040 | 451,174 |
| \$ 8 | 1,894 | 122,731 | 22,728 | 122,731 | 87,196 |
| \$ 8 | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B |
| \$ 15 | 2,250,511 | 0 | 27,006,132 | 135,031 | 95,935 |

| | | | | | | |
|----|-----|------------------|------------------|------------------|------------------|------------------|
| \$ | 250 | 1,134,374 | 0 | 13,612,488 | 4,537,496 | 3,223,733 |
| \$ | 50 | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A |
| \$ | 73 | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A |
| \$ | 3 | 2,250,511 | 0 | 27,006,132 | 1,350,307 | 959,346 |
| \$ | 15 | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A |
| \$ | 50 | 2,250,511 | 0 | 27,006,132 | 9,002,044 | 6,395,640 |
| \$ | 10 | 2,250,511 | 0 | 27,006,132 | 0 | 0 |
| \$ | 200 | 245,824 | 1,769,933 | 2,949,888 | 3,362,872 | 2,389,204 |
| \$ | 2 | 200 | 0 | 2,400 | 9,600 | 6,820 |

| | | | | | |
|-----|-----|-----|-----|-----|-----|
| TBD | TBD | TBD | TBD | TBD | TBD |
|-----|-----|-----|-----|-----|-----|

| Customer Outage Reduction By Customer Types (hrs) | | Value (to customers) of Lost Load (\$ Million) | Cost/Benefit Ratio Per Action | Cost/Benefit Ratio Per Program |
|---|------------------|--|-------------------------------|--------------------------------|
| Small C&I | Large C&I | | | |
| 49,620,231 | 9,803,131 | \$ 15,750 | 0.11 | 0.11 |
| 734,027 | 145,017 | \$ 233 | 0.28 | 0.18 |
| 1,414,560 | 279,465 | \$ 449 | 0.13 | |
| 253,118 | 50,007 | \$ 80 | 0.12 | |
| 87,187 | 17,225 | \$ 28 | 3.69 | 3.69 |
| 2,422 | 478 | \$ 1 | 3.90 | |
| 0 | 0 | \$ 1 | 87.10 | 87.10 |
| 759,355 | 150,021 | \$ 241 | 0.25 | 0.26 |
| 146,757 | 28,994 | \$ 47 | 0.17 | |
| Combined with 5B | Combined with 5B | \$ - | Combined with 5B | |
| 161,464 | 31,899 | \$ 51 | 0.29 | 0.29 |

| | | | | |
|------------------|------------------|----------|------------------|------|
| 5,425,753 | 1,071,929 | \$ 1,722 | 0.15 | |
| Combined with 1A | Combined with 1A | \$ - | Combined with 1A | |
| Combined with 1A | Combined with 1A | \$ - | Combined with 1A | 0.08 |
| 1,614,642 | 318,994 | \$ 482 | Combined with 1A | |
| Combined with 1A | Combined with 1A | \$ - | Combined with 1A | |
| 10,764,278 | 2,126,625 | \$ 3,417 | 0.01 | |
| 0 | 0 | \$ - | Combined with 1A | |
| 4,021,186 | 794,438 | \$ 1,276 | 0.16 | 0.16 |
| 11,479 | 2,268 | \$ 4 | 0.55 | 0.55 |

| | | | | |
|-----|-----|-----|-----|-----|
| TBD | TBD | TBD | TBD | TBD |
|-----|-----|-----|-----|-----|

| Program | Description | Actions | Length of Program* (years) | Distribution First 60 Months (\$ Million) | Distribution Second 60 Months (\$ Million) | Total Estimated Costs (\$ 2012 Million) | Ranking | Assumptions in quantifying customers impacted by either elimination of outage or decrease in outage duration | Number of Customers | Source | Assumption in quantifying outages that are eliminated or reduced in duration | Outage Duration (hrs) | Assumptions in quantifying outages that are reduced in duration | Outage Duration Decrease | Total Customer Hours of Outage Avoided and Reduction for Residential (Billion) | Total Customer Hours of Outage Avoided and Reduction for Commercial (Billion) | Total Customer Hours of Outage Avoided and Reduction for Industrial (Billion) | Total Customer Hours of Outage Avoided and Reduction for Small C&I (Billion) | Total Customer Hours of Outage Avoided and Reduction for Large C&I (Billion) | Value (to customers) of cost avoided (\$ Million) | Cost/Benefit Ratio per action | Rank | Cost/Benefit ratio per program | BANK for cost/benefit ratio | Program RANK | Total Cost | | | | VOLLL Res | Small CI | Vol Large |
|--|---|--|--|---|--|---|-----------|--|--|--------------------------|--|--|--|--|--|---|---|--|--|---|-------------------------------|------------------|--------------------------------|-----------------------------|-----------------------------|---------------------|-----------------------|-----------------------|----------------------|--------------------|--------------------|-----------|
| | | | | | | | | | | | | | | | | | | | | | | | | | | 1st Billion | 2nd Billion | 3rd Billion | 4th Billion | | | |
| Electricity delivery Infrastructure Hardening Investments | 1. Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA Flood guidelines. | 10 | \$ 819.00 | \$ 819.00 | \$ 1,638.00 | | Number of customers supplied either directly or indirectly by the Station to be protected assuming each action will be impacted once | 748,300 | Station cost in File xxx | * 13% reduction in 5-day customer outages | 29,640,000 | With station supply in, customer cost out reduced from 5 Days to 4 days | 11,856,240 | 41,498,840 | 28,482,264 | 49,630,211 | 9,803,131 | 15,739 | 0.11 | 2 | 0.11 | 2 | 2 | \$ 631 \$ 188 \$ 227 \$ 652 | 28 | 15,612 | 110 | 15,750 | | | |
| | 2. Outside Plant Higher Design and Construction Standards | This program will involve improvements to design standards to strengthen construction | Change existing 48V OP distribution to 138V standards (this represents 5% of the OP infrastructure) | 5 | \$ 65.00 | \$ - | \$ 65.00 | 13 | 5% of Customers supplied by 48V | 30,448 | Customer Count Details for Assumptions | 20% Reduction of Outages | 488,471 | Due to reduced damage, restoration work will be less, assuming a 10% reduction in outage time of 3 days (7.2 hours) for Customers out of service | 175,388 | 613,859 | 436,125 | 734,027 | 145,017 | 231 | 0.28 | 9 | 0.18 | 4 | 10 | \$ 85 \$ - | 0 | 231 | 2 | | | |
| | | | Change existing 288V to 69V standards while still operating at 288V (this represents 35% of the 288V infrastructure) | 5 | \$ 60.00 | \$ - | \$ 60.00 | 7 | 5% of Customers supplied by 288V infrastructure | 29,871 | Customer Count Details for Assumptions - minus Federal Square Substation | 50% Reduction due to raised conductors | 1,075,417 | Due to reduced damage, restoration work will be less, assuming a 10% reduction in outage time of 3 days (7.2 hours) for Customers out of service | 107,544 | 1,182,961 | 840,467 | 1,414,560 | 279,465 | 448 | 0.13 | 4 | 0.18 | 4 | 6 | \$ 80 \$ - | 1 | 445 | 3 | | | |
| | | | Add spacer cable to eliminate open wire to targeted areas | 5 | \$ 10.00 | \$ - | \$ 10.00 | 12 | Assume 10 circuits, Average Customer/33KV section = 735 Customers/section x 10 Circuits | 7,350 | Customer Count Details for Assumptions | 40% Reduction due to increased ability to withstand weather events | 211,680 | No Benefit | 0 | 211,680 | 150,391 | 253,118 | 50,007 | 80 | 0.12 | 3 | 0.18 | 4 | 11 | \$ 10 \$ - | 0 | 80 | 1 | | | |
| | 3. Strengthening Pole Infrastructure | This program will involve accelerated pole replacements, additional construction hardening, including reduced pole span lengths, and increased pole diameters | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm geying standards. | 5 | \$ 102.00 | \$ - | \$ 102.00 | 10 | # of poles inspected/hot spots in system * Customers | 50,634 | | 2% Reduction in the number of Outages Due to Poles replaced. Value low due to low coincidence of possible damage with replaced poles | 72,911 | No Benefit | 0 | 72,911 | 51,802 | 87,187 | 17,225 | 28 | 3.69 | 12 | 3.69 | 8 | 13 | \$ 102 \$ - | 0 | 27 | 0 | | | |
| | | | This program will evaluate the use of new non-wood material to replace wood poles in the future. | 5 | \$ 3.00 | \$ - | \$ 3.00 | 16 | # of poles inspected/hot spots in system * Customers | 1,407 | | 2% Reduction due to Poles replaced. Value low due to low coincidence of possible damage with replaced poles. | 2,025 | No Benefit | 0 | 2,025 | 1,439 | 2,422 | 478 | 1 | 3.90 | 13 | 3.69 | 8 | 14 | \$ 3 \$ - | 0 | 1 | 0 | | | |
| | 4. Rebuild/Relocate Backyard poles | This program will consider the relocation and rebuilding of backyard pole lines to meet local and/or US configuration | Rebuild backyard poles (including tree trimming) | 5 | \$ 100.00 | \$ - | \$ 100.00 | 4 | Customers supplied by backyard circuits | 36,973 | | 50% Reduction | 1,831,028 | Due to better access and newer facilities restoration work will be decreased by 2-3 hours (50% of 3 days) for Customers out of service | 131,103 | 1,464,131 | 1,200,587 | 0 | 0 | 87.10 | 13 | 103 | 87.10 | 9 | 15 | \$ 26 \$ 74 | 1 | 0 | 0 | | | |
| | 5. Undergrounding | This program will consider the conversion of OH to UG in selected areas and the replacement of PM equipment with a submersible equivalent in targeted areas | A. Convert certain OH areas to UG | 5 | \$ 60.00 | \$ - | \$ 60.00 | 8 | Estimate # circuits that could be done to get customer count. Assume 1 mile per circuit, 20 Circuits with average of 735 Customers/circuit | 14,700 | | Assume 60% reduction due to damage being avoided on primary lines new Underground. | 635,040 | No Benefit | 0 | 635,040 | 451,174 | 759,355 | 150,021 | 241 | 0.25 | 8 | 0.26 | 5 | 9 | \$ 80 \$ - | 0 | 239 | 2 | | | |
| | | | B. Replace PM-eters with submersible eters in target areas | 5 | \$ 8.00 | \$ - | \$ 8.00 | 8 | Avg Customers per pad/transformer to customers in flood area | 1,884 | | Assume 100% reduction in PSE&G related outages due to storm surge. Outage duration of 3 days assumed. | 122,711 | No Benefit | 0 | 122,711 | 87,186 | 146,767 | 28,994 | 47 | 0.17 | 7 | 0.26 | 5 | 7 | \$ 8 \$ - | 0 | 46 | 0 | | | |
| | | | C. Replace ATS switches/transformers with submersible switches | 5 | \$ 8.00 | \$ - | \$ 8.00 | 8 | Customer benefit aligned with PM Transformer program as ATS typically supply PM in these areas | Combined with 5B | | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | 0.26 | 5 | 8 | \$ 8 \$ - | 0 | 46 | 0 | |
| 6. Relocate ESDC/SOC/DER/SOR | This program will relocate our critical Electrical & Gas dispatch operating centers to a higher level within the existing building, making it less susceptible flooding, etc. | Relocate critical operating centers | 2 | \$ 15.00 | \$ - | \$ 15.00 | 14 | Total number of Customers | 2,250,511 | | N/A | 0 | Low probability event. Assume 5% probability at a major event with Average 6 hour increase in overall restoration. | 135,031 | 135,031 | 95,935 | 161,464 | 31,999 | 16 | 0.29 | 10 | 0.29 | 6 | 12 | \$ 15 \$ - | 0 | 51 | 0 | | | | |
| Electricity delivery Infrastructure Resilience Investments | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | System Viability 2a. Expand implementation of 288V, 138V, and 48V Microprocessor Relays and SCADA field equipment (RTUs) to enable remote operation and position indication of each feeder circuit breaker, provide remote monitoring capabilities including circuit and transformer loading, circuit breaker position, load imbalance, will assist in fault location and more. | 10 | \$ 120.00 | \$ 120.00 | \$ 240.00 | 2* | # Customers in Stations | 1,134,374 | | No Benefit | 0 | Assume 4 hour improvement in overall restoration time due to indication of circuit outages, immediate load data for decision making and the ability to remotely set up circuits for work. | 4,537,496 | 4,537,496 | 3,221,731 | 5,425,713 | 1,071,029 | 1,729 | 0.15 | 5 | 0.08 | 1 | 1 | \$ 120 \$ 120 \$ - \$ - | 3 | 1,707 | 12 | | | | |
| | | 2a. System to visualize, control, collect and analyze all monitored points from each Distribution station. This includes SCADA, meters and servers, dispatch consoles, communications, switches and servers, historical tapes with appropriate back-up and redundancy (DMS) | 10 | \$ 24.00 | \$ 24.00 | \$ 48.00 | 2* | Benefits Aligned with 1A | Combined with 1A | | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | 0.08 | 1 | 1 | \$ 24 \$ 24 \$ - \$ - | | | | | |
| | | 2b. High Speed Fiber Optic Network (Backbone) - Transmission - Complete build out equating to approximately 10% of the total system program. Distribution - Build fiber optic network from 101 of the 1125 Distribution substations (Class A, B, C, CN, CL, etc) to facilitate the information transfer from the station to the new DMS system. | 10 | \$ 35.00 | \$ 38.00 | \$ 73.00 | 2* | Benefits Aligned with 1A | Combined with 1A | | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | 0.08 | 1 | 1 | \$ 35 \$ 38 \$ - \$ - | | | | | |
| | | 2b. Pilot Satellite Communication Program | 5 | \$ 3.00 | \$ - | \$ 3.00 | 15 | Total number of Customers | 2,250,511 | | No Benefit | 0 | Low probability event. Assume 5% probability at a major event with Average 12 hour increase in overall restoration. | 1,350,307 | 1,350,307 | 958,346 | 1,614,642 | 318,994 | 482 | Combined with 1A | 0.16 | 6 | 0.16 | 3 | 3 | \$ 3 \$ 3 \$ - \$ - | 1 | 508 | 4 | | | |
| | | 2b. Storm Damage Assessment (used all items in System Viability) 2a. Advanced Distribution Management System (ADMS) functionality to improve visibility of circuit operations in storm conditions and support restoration of customers. Integration of SCADA, OMS, and GIS. | 10 | \$ 9.00 | \$ 6.00 | \$ 15.00 | 2* | Benefits Aligned with 1A | Combined with 1A | | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | 0.08 | 1 | 1 | \$ 9 \$ 6 \$ - \$ - | | | | | |
| | | 2b. Enhance Storm Management Systems to improve plant damage assessment process, optimize restoration work plans, integrate mutual aid areas, and develop capability to provide predictive ETBE under complex storm conditions. | 4 | \$ 50.00 | \$ - | \$ 50.00 | 3 | Total number of Customers | 2,250,511 | | No Benefit | 0 | Through confirmed damage location visibility, optimized on-up process and automation of dispatch records restoration process will be improved. Assume 4 hour improvement in average restoration in overall storm work. | 9,002,044 | 9,002,044 | 6,395,640 | 10,764,278 | 2,126,625 | 1,417 | 0.01 | 1 | 0.08 | 1 | 1 | \$ 50 \$ - \$ - \$ - | 6 | 3,387 | 24 | | | | |
| | | 2c. Expand communication channels to improve ability to communicate storm related information to customers. (Outage Map, Mobile Apps, Preference Management, SMS, Mobile Web) | 3 | \$ 10.00 | \$ - | \$ 10.00 | 5 | Total number of Customers | 2,250,511 | | No Benefit | 0 | No Benefit | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.16 | 6 | 0.16 | 3 | 3 | \$ 10 \$ - \$ - \$ - | 0 | 0 | 0 |
| Contingency Reconfiguration Strategies | This program refers to the ability of utilities to recover quickly from damage to any of its components | Establish contingency reconfiguration strategies by creating multiple sections, utilizing smart switches, smart fuses, and adding redundancy within our loop scheme | 5 | \$ 200.00 | \$ - | \$ 200.00 | 4 | Using OP 2 Major Results of \$1.2B per circuit equal 167 138V circuits. Avg customer count of 1500 = 250,500 | 245,824 | | Due to reconfiguration of circuits, loop improvement and fusing, 10% reduction in outages. | 1,769,913 | With greater system redundancy restoration time on average will improve by 10% (7.2 hours) | 1,592,940 | 1,362,872 | 2,389,204 | 4,021,186 | 794,418 | 1,276 | 0.16 | 6 | 0.16 | 3 | 3 | \$ 45 \$ 69 \$ 86 \$ - | 2 | 1,245 | 9 | | | | |
| Supplemental Investment | Emergency Backup Generator and Quick Connect Stockpile Program | PSE&G to purchase and stockpile emergency backup generators to utilize during storm restoration. Technologies used whereby a generator can be made to a residential customer electric meter which allows the quick connection of a portable generator. | 1 | \$ 2.00 | \$ 0 | \$ 2.00 | 17 | Number of Generators | 200 | | No change in outage reduction | 0 | Assuming a two day implementation of these measures, outage time reduced by 2 days | 9,600 | 9,600 | 6,820 | 11,479 | 2,268 | 4 | 0.55 | 11 | 0.55 | 7 | 16 | \$ - \$ - \$ - \$ - | 0 | 4 | 0 | | | | |
| | Municipal Pilot Program | To improve resiliency of the electric system, particularly by engaging suitable municipal resources in the event of prolonged outages | TBD | TBD | TBD | TBD | 18 | TBD | TBD | | TBD | TBD | TBD | TBD | TBD | TBD | TBD | TBD | TBD | TBD | TBD | TBD | TBD | TBD | 17 | \$ - \$ - \$ - \$ - | | | | | | |
| Gas Projects | Metering & Regulating Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA Flood guidelines. | 8 | \$ 76.00 | \$ 64.00 | \$ 140.00 | | Summary | | | | | | | 45,771,925 | 75,016,460 | 14,820,490 | 23,783 | | | | | 4 | \$ 76 \$ 64 \$ - \$ - | 44 | 23,602 | 167 Total VOLLL | 23,813 | 0.991152 | | | |
| | Utilization Pressure Cast Iron (UPCI) | This program will consider accelerated UPCI main and associated services and district regulator replacements located within or in proximity of a Flood hazard zone. | 6 | \$ 830.00 | \$ 210.00 | \$ 1,040.00 | | | | | | | | | | | | | | | | | | 5 | \$ 830 \$ 210 \$ - \$ - | 1,873,795 | 279,271 | 9,618 Total Customers | 2,153,066 | 17,356 Avg Savings | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | 1000 | \$ 543 | \$ 269 | \$ 734 | 23 | 84,513 | 17,356 Avg Savings | |

Assumptions (not already listed):
Based on Sandy, average customer outage duration was 4 days (awaiting confirmation)
Each program was evaluated as an independent project (benefits may not be cumulative)
None where better input needed
Numbers or assumptions awaiting input for confirmation

| Actions | Total Estimated Costs (\$ Million) | Number of Customers affected | Avoided Outages (Hrs) |
|--|------------------------------------|------------------------------|-----------------------|
| Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | \$ 1,678 | 748,500 | 29,640,600 |
| Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) | \$ 65 | 30,449 | 438,471 |
| Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) | \$ 60 | 29,873 | 1,075,437 |
| Add spacer cable to eliminate open wire to targeted areas | \$ 10 | 7,350 | 211,680 |
| Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards | \$ 102 | 50,634 | 72,913 |
| Non-wood poles | \$ 3 | 1,407 | 2,025 |
| Rebuild backyard poles (including tree trimming) | \$ 100 | 36,973 | 1,331,028 |
| A. Convert certain OH areas to UG | \$ 60 | 14,700 | 635,040 |
| B. Replace PM xfmrs with submersible xfmrs in target areas | \$ 8 | 1,894 | 122,731 |
| C. Replace ATS switches/transformers with submersible switches | \$ 8 | Combined with 5B | Combined with 5B |
| Relocate critical operating centers | \$ 15 | 2,250,511 | 0 |

| Outage Duration Decrease (Hrs) | Total Customer Outage Reduction (Hrs) | Value (to customers) of Lost Load (\$ Million) | Cost/Benefit Ratio | Rank Based on Cost/Benefit Ratio |
|--------------------------------|---------------------------------------|--|--------------------|----------------------------------|
| 11,856,240 | 41,496,840 | \$ 15,750.42 | 0.11 | 1 |
| 175,388 | 613,859 | \$ 232.99 | 0.18 | 2 |
| 107,544 | 1,182,981 | \$ 449.01 | | |
| 0 | 211,680 | \$ 80.34 | | |
| 0 | 72,913 | \$ 27.67 | 3.69 | 5 |
| 0 | 2,025 | \$ 0.77 | | |
| 133,103 | 1,464,131 | \$ 1.15 | 87.10 | 6 |
| 0 | 635,040 | \$ 241.03 | 0.26 | 3 |
| 0 | 122,731 | \$ 46.58 | | |
| Combined with 5B | Combined with 5B | \$ - | | |
| 135,031 | 135,031 | \$ 51.25 | 0.29 | 4 |

| Program | Description | Actions | Assumptions in quantifying customers impacted by either elimination of outage or decrease in outage duration | Assumption in quantifying outages that are eliminated Outage duration is 3 days unless noted | Assumptions in quantifying outages that are reduced in duration |
|---|---|--|--|---|--|
| 1. Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA flood guidelines | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | Number of customers supplied either directly or indirectly by the Stations to be protected assuming each station will be impacted once | * 33% reduction in 5-day customer outages | With station supply in, customer still out reduced from 5 Days to 4 days |
| 2. Outside Plant Higher Design and Construction Standards | This program will involve improvements to design standards to strengthen construction | Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) | 5% of Customers supplied by 4kV | 20% Reduction of Outages | Due to reduced damage, restoration work will be less, assuming a 10% reduction in outage time of 3 days (7.2 Hours) for Customers out of service |
| | | Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) | 5% of Customers supplied by 26/4kV substations | 50% Reduction due to raised conductors. | Due to reduced damage, restoration work will be less, assuming a 10% reduction in outage time of 3 days (7.2 Hours) for Customers out of service |
| | | Add spacer cable to eliminate open wire to targeted areas | Assume 10 circuits. Average customers/13kV section = 735 Customers/section x 10 circuits | 40% Reduction due to increased ability to withstand weather events | No Benefit |
| 3. Strengthening Pole Infrastructure | This program will involve accelerated pole replacements, additional construction hardening, including reduced pole span lengths, and increased pole diameters | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards | # of poles impacted/total poles in system * customers | 2% Reduction in the number of Outages Due to Poles replaced. Value low due to low coincidence of possible damage with replaced poles. | No Benefit |
| | This program will evaluate the use of new non-wood material to replace wood poles in the future. | Non-wood poles | # of poles impacted/total poles in system * customers | 2% Reduction due to Poles replaced. Value low due to low coincidence of possible damage with replaced poles. | No Benefit |
| 4. Rebuild/Relocate Backyard poles | This program will consider the relocation and rebuilding of backyard pole lines to front lot and/or UG configuration | Rebuild backyard poles (including tree trimming) | Customers supplied by backyard circuits | 50% Reduction | Due to better access and newer facilities restoration work will be decreased by 7.2 hours(10% of 3 days) for Customers out of service |
| 5. Undergrounding | This program will consider the conversion of OH to UG in selected areas and the replacement of PM equipment with a submersible equivalent in targeted areas | A. Convert certain OH areas to UG | Estimate # circuits that could be done to get customer count. Assume 1 mile per circuit, 20 Circuits with average of 735 customers/section | Assume 60% reduction due to damage being avoided on primary lines now Underground. | No Benefit |
| | | B. Replace PM xfms with submersible xfms in target areas | Avg Customers per padmounted transformers in flood area | Assume 90% reduction in PSE&G equipment outages due to storm surge. Outage duration of 3 days avoided. | No Benefit |
| | | C. Replace ATS switches/transformers with submersible switches | Customer benefit aligned with PM Transformer program as ATS typically supply PM in these areas | Combined with 5B | Combined with 5B |
| 6. Relocate ESOC/GSOC/DERC/SR | This program will relocate our critical Electrical & Gas dispatch operating centers to a higher level within the existing building, making it less susceptible flooding, etc. | Relocate critical operating centers | Total number of Customers | No Benefit | Low probability event. Assume 1% probability in a major event with Average 6 hour increase in overall restoration. |

Program

Advanced Technologies

| Actions | Total Estimated Costs (\$ Million) | Number of Customers | Avoided Outages (Hrs) |
|---|------------------------------------|---------------------|-----------------------|
| System Visibility 1a. Expand implementation of 26kV, 13kV, and 4kV Microprocessor Relays and SCADA field equipment (RTUs) to enable remote operation and position indication of each feeder circuit breaker, provide remote monitoring capabilities including circuit and transformer loading, circuit breaker position, load imbalance, will assist in fault location and more. | \$ 250 | 1,134,374 | 0 |
| 1c. System to visualize, control, collect and analyze all monitored points from each Distribution station. This includes SCADA monitors and servers, dispatch consoles, communications switches and servers, historical serves with appropriate back-up and redundancy. (DMS) | \$ 50 | Combined with 1A | Combined with 1A |
| Communication Network 2a. High Speed Fiber Optic Network (Backbone)- Transmission - Complete build out equating to approximately 30% of the total system (in progress). Distribution - Build fiber optic network from (91) of the (125) Distribution substations (Class A, B, C, CN, CS, etc) to facilitate the information transfer from the station to the new DMS system. | \$ 73 | Combined with 1A | Combined with 1A |
| 2b. Pilot Satellite Communication Program | \$ 3 | 2,250,511 | 0 |
| Storm Damage Assessment (need all items in System Visibility) 3a. Advanced Distribution Management System (ADMS) functionality to improve visibility of circuit operations in storm conditions and support restoration of customers. Integration of SCADA, DMS, OMS and GIS. | \$ 15 | Combined with 1A | Combined with 1A |
| 3b. Enhance Storm Management Systems to improve plant damage assessment process, optimize restoration work plans, integrate mutual aid crews, and develop capability to provide predictive ETRs under complex storm conditions. | \$ 50 | 2,250,511 | 0 |
| 3c. Expand communication channels to improve ability to communicate storm-related information to customers. (Outage Map, Mobile App, Preference Management, SMS, Mobile Web) | \$ 10 | 2,250,511 | 0 |

| Outage Duration Decrease (Hrs) | Total Customer Outage Reduction (Hrs) | Value (to customers) of Lost Load (\$ Million) | Cost/Benefit Ratio |
|--------------------------------|---------------------------------------|--|--------------------|
| 4,537,496 | 4,537,496 | \$ 1,722 | 0.08 |
| Combined with 1A | Combined with 1A | \$ - | |
| Combined with 1A | Combined with 1A | \$ - | |
| 1,350,307 | 1,350,307 | \$ 482 | |
| Combined with 1A | Combined with 1A | \$ - | |
| 9,002,044 | 9,002,044 | \$ 3,417 | |
| 0 | 0 | \$ - | |

Program

Advanced Technologies

Description

1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers.

| Actions | Potential Customer Benefits |
|--|-----------------------------|
| <p>System Visibility 1a. Expand implementation of 26kV, 13kV, and 4kV Microprocessor Relays and SCADA field equipment (RTUs) to enable remote operation and position indication of each feeder circuit breaker, provide remote monitoring capabilities including circuit and transformer loading, circuit breaker position, load imbalance, will assist in fault location and more.</p> | # Customers in Stations |
| <p>1c. System to visualize, control, collect and analyze all monitored points from each Distribution station. This includes SCADA monitors and servers, dispatch consoles, communications switches and servers, historical serves with appropriate back-up and redundancy. (DMS)</p> | Benefits Aligned with 1A |
| <p>Communication Network 2a. High Speed Fiber Optic Network (Backbone)- Transmission - Complete build out equating to approximately 30% of the total system (in-progress). Distribution - Build fiber optic network from (91) of the (125) Distribution substations (Class A, B, C, CN, CS, etc) to facilitate the information transfer from the station to the new DMS system.</p> | Benefits Aligned with 1A |
| <p>2b. Pilot Satellite Communication Program</p> | Total number of Customers |
| <p>Storm Damage Assessment (need all items in System Visibility) 3a. Advanced Distribution Management System (ADMS) functionality to improve visibility of circuit operations in storm conditions and support restoration of customers. Integration of SCADA, DMS, OMS and GIS.</p> | Benefits Aligned with 1A |
| <p>3b. Enhance Storm Management Systems to improve plant damage assessment process, optimize restoration work plans, integrate mutual aid crews, and develop capability to provide predictive ETRs under complex storm conditions.</p> | Total number of Customers |
| <p>3c. Expand communication channels to improve ability to communicate storm-related information to customers. (Outage Map, Mobile App, Preference Management, SMS, Mobile Web)</p> | Total number of Customers |

| Avoided Outage Assumptions | Outage Duration Decrease Assumptions |
|----------------------------|---|
| No Benefit | Assume 4 hour improvement in overall restoration time due to indication of circuit outages, immediate load data for decision making and the ability to remotely set-up circuits for work. |
| Combined with 1A | Combined with 1A |
| Combined with 1A | Combined with 1A |
| No Benefit | Low probability event. Assume 5% probability in a major event with Average 12 hour increase in overall restoration. |
| Combined with 1A | Combined with 1A |
| No Benefit | Through confirmed damage location visibility, improved look-up process and elimination of duplicate records restoration process will be improved. Assume 4 hour improvement in average restoration in overall storm work. |
| No Benefit | No Benefit |

| Program Grouping | Program | Description | Actions | Cost/Benefit Ratio per action | Cost/Benefit ratio per program | RANK for cost/benefit ratio | Program RANK | \$1 Billion Program | \$1 Billion Program | \$1 Billion Program | \$1 Billion Program | |
|--|---|---|--|--|--------------------------------|-----------------------------|--------------|---------------------|---------------------|---------------------|---------------------|--|
| Electricity delivery Infrastructure Hardening Investments | 1. Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA flood guidelines | Review and identify stations in newly defined FEMA/NI DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | 0.11 | 0.11 | 2 | 2 | \$ 631 | \$ 188 | \$ 227 | \$ 632 | |
| | 2. Outside Plant Higher Design and Construction Standards | This program will involve improvements to design standards to strengthen construction | Change existing 4KV OP distribution to 13KV standards (this represents 5% of the 4KV infrastructure) | 0.28 | 0.18 | 5 | 10 | | \$ 65 | \$ - | | |
| | 2. Outside Plant Higher Design and Construction Standards | This program will involve improvements to design standards to strengthen construction | Change existing 20KV to 69KV standards while still operating at 26KV (this represents 5% of the 26KV infrastructure) | 0.13 | | | 6 | \$ 60 | \$ - | | | |
| | 2. Outside Plant Higher Design and Construction Standards | This program will involve improvements to design standards to strengthen construction | Add spacer cable to eliminate open wire to targeted areas | 0.12 | | | 11 | \$ 10 | \$ - | | | |
| | 3. Strengthening Pole Infrastructure | This program will involve accelerated pole replacements, additional construction hardening, including reduced pole span lengths, and increased pole diameters | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards | 3.69 | 3.69 | 8 | 13 | | \$ 102 | \$ - | | |
| | 3. Strengthening Pole Infrastructure | This program will evaluate the use of new non-wood material to replace wood poles in the future. | Non-wood poles | 3.90 | | | 14 | | \$ 3 | \$ - | | |
| | 4. Rebuild/Relocate Backyard poles | This program will consider the relocation and rebuilding of backyard pole lines to front lot and/or UG configuration | Rebuild backyard poles (including tree trimming) | 87.10 | 87.10 | 9 | 15 | | \$ 26 | \$ 74 | | |
| | 5. Undergrounding | This program will consider the conversion of OH to UG in selected areas and the replacement of PM equipment with a submersible equivalent in targeted areas | A. Convert certain OH areas to UG B. Replace PM xfmrs with submersible xfmrs in target areas C. Replace ATS switches/transformers with submersible switches | 0.25 0.17 Combined with 5B | 0.26 | 6 | 9 | | \$ 60 | \$ - | | |
| | 5. Undergrounding | | | 7 | | | \$ 8 | \$ - | | | | |
| | 5. Undergrounding | | | 8 | | | \$ 8 | \$ - | | | | |
| 6. Relocate ESOC/ESOC/DERC/SR | This program will relocate our critical Electrical & Gas dispatch operating centers to a higher level within the existing building, making it less susceptible flooding, etc. | Relocate critical operating centers | 0.29 | 0.17 | 4 | 12 | | \$ 15 | \$ - | | | |
| Electricity delivery Infrastructure Resilience Investments | Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | System Visibility 1a. Expand implementation of 26KV, 13KV, and 4KV Microprocessor Relays and SCADA field equipment (RTUs) to enable remote operation and position indication of each feeder circuit breaker, provide remote monitoring capabilities including circuit and transformer loading, circuit breaker position, load imbalance, will assist in fault location and more. | 0.15 | Combined with 1A | | | \$ 120 | \$ 130 | \$ - | \$ - | |
| | Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | 1c. System to visualize, control, collect and analyze all monitored points from each Distribution station. This includes SCADA monitors and servers, dispatch consoles, communications switches and servers, historical server with appropriate back-up and redundancy. (DMS) | | | | | \$ 24 | \$ 26 | \$ - | \$ - | |
| | Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | Communication Network 2a. High Speed Fiber Optic Network (Backbone) - Transmission - Complete build out equating to approximately 30% of the total system (in progress). Distribution - Build fiber optic network from 911 of the 1225 Distribution substations (Class A, B, C, CN, CS, etc) to facilitate the information transfer from the station to the new DMS system. | 0.08 | 1 | 1 | \$ 35 | \$ 38 | \$ - | \$ - | | |
| | Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | 2b. Pilot Satellite Communication Program | | Combined with 1A | | | \$ 3 | \$ - | \$ - | | |
| | Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | Storm Damage Assessment (need all items in System Visibility) 3a. Advanced Distribution Management System (ADMS) functionality to improve visibility of circuit operations in storm conditions and support restoration of customers. Integration of SCADA, OMS and GIS. | | Combined with 1A | | \$ 9 | \$ 6 | \$ - | \$ - | | |
| | Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | 3b. Enhance Storm Management Systems to improve plant damage assessment process, optimize restoration work plans, integrate mutual aid crews, and develop capability to provide predictive ETIs under complex storm conditions. | 0.01 | | | \$ 90 | | \$ - | \$ - | | |
| | Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, OMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | 3c. Expand communication channels to improve ability to communicate storm-related information to customers. (Outage Map, Mobile App, Preference Management, SMS, Mobile Web) | | Combined with 1A | | \$ 10 | | \$ - | \$ - | | |
| | Contingency Reconfiguration Strategies | This program refers to the ability of utilities to recover quickly from damage to any of its components | Establish contingency reconfiguration strategies by creating multiple sections, utilizing smart switches, smart fuses, and adding redundancy within our loop scheme | 0.16 | 0.16 | 3 | 3 | \$ 45 | \$ 69 | \$ 86 | \$ - | |
| | Supplemental Investment | Emergency Backup Generator and Quick Connect Stockpile Program | PSE&G to purchase and stockpile emergency backup generators to utilize during storm restoration. Technologies exist whereby a connection can be made to a residential customer electric meter which allows the quick connection of a portable generator. | PSE&G to deploy emergency generators to customers based on priorities driven by local municipal officials. In addition, PSE&G will maintain the supply of quick connects to be deployed as directed. | 0.55 | 0.55 | 7 | 16 | | \$ - | \$ 2 | |
| | | Municipal Pilot Program | To improve resiliency of the electric system, particularly by engaging valuable municipal resources in the event of prolonged outages | Develop a municipal storm plan which addresses vegetation maintenance, mobile field applications and a combined heat and power (CHP) pilot for targeted critical municipal facilities meeting the high efficiency specifications for application of this technology. | TBD | TBD | | 17 | | \$ - | \$ - | |
| Gas Hardening | Metering & Regulating Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA flood guidelines | Review and identify stations in newly defined FEMA/NI DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | | | | 4 | \$ 76 | \$ 64 | \$ - | | |
| | Utilization Pressure Cast Iron (UPCI) | This program will consider accelerated UPCI main and associated services and district regulator replacements located within or in proximity of a flood hazard zone. | Replace existing UPCI main and associated district regulators with plastic or coated cathodically protected welded steel. Replace with high pressure and abandon regulators where feasible - 750 miles | | | | 5 | | \$ 543 | \$ 263 | \$ 234 | |
| | | | | | | | | 1000 | 1000 | 1000 | 942 | |

| Program | Description | Actions |
|--|---|---|
| Contingency Reconfiguration Strategies | This program refers to the ability of utilities to recover quickly from damage to any of its components | Establish contingency reconfiguration strategies by creating multiple sections, utilizing smart switches, smart fuses, and adding redundancy within our loop scheme |

| | | |
|--|--|---|
| <p>Assumptions in quantifying customers Impacted by either elimination of outage or decrease in outage duration</p> | <p>Assumption in quantifying outages that are eliminated Outage duration is 3 days unless noted</p> | <p>Assumptions in quantifying outages that are reduced in duration</p> |
| <p>Using CIP 2 Results of \$1.2M per circuit equals 167 13kV circuits. Avg customer count of 1472</p> | <p>Due to reconfiguration of circuits, loop improvement and fusing, 10% reduction in outages.</p> | <p>With greater system redundancy restoration time on average will improve by 10% (7.2 Hours)</p> |
| | | |
| <p>Number of Customers affected</p> | <p>Avoided Outages (Hrs)</p> | <p>Outage Duration Decrease (Hrs)</p> |
| <p>245,824</p> | <p>1,769,933</p> | <p>1,592,940</p> |

| |
|--|
| Total Customer Outage Reduction (Hrs) |
| 3,362,872 |

| Program | Description | Actions | Assumptions in quantifying customers impacted by either elimination of outage or decrease in outage duration | Number of Customers | Assumption in quantifying outages that are eliminated Outage duration is 3 days unless noted | Avoided Outages (Hrs) | Number of Customer Outages Eliminated | Assumptions in quantifying outages that are reduced in duration | Outage Duration Decrease | Total Customer Hours Outage Reduction (Sum Of Outages Avoided and Duration Decreases) |
|--|---|--|--|---------------------|--|--|---------------------------------------|---|--------------------------|---|
| 1. Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA flood guidelines | Review and identify stations in newly defined FEMA/NI DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | Number of customers supplied either directly or indirectly by the Stations to be protected assuming each station will be impacted once | 748,500 | * 33% reduction in 5-day customer outages | 29,640,600 | 247,005 | With station supply in, customer still out reduced from 5 days to 4 days | 11,856,240 | 41,496,840 |
| 2. Outdate Plant Higher Design and Construction Standards | This program will evaluate improvements to design standards to strengthen construction | Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) | 5% of Customers supplied by 4kV | 30,449 | 20% Reduction of Outages | 438,471 | 6,090 | Due to reduced damage, restoration work will be less, assuming a 10% reduction in outage time of 3 days (7.2 Hours) for Customers out of service. | 175,388 | 613,859 |
| | | Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) | 5% of Customers supplied by 26/4kV substations | 29,873 | 50% Reduction due to raised conductors. | 1,075,437 | 14,937 | Due to reduced damage, restoration work will be less, assuming a 10% reduction in outage time of 3 days (7.2 Hours) for Customers out of service. | 107,544 | 1,182,981 |
| | | Add spacer cable to eliminate open wire to targeted areas | Assume 10 circuits. Average customers/33kV section = 735 Customers/section x 10 circuits | 7,350 | 40% Reduction due to increased ability to withstand weather events | 211,680 | 2,940 | No Benefit | 0 | 211,680 |
| 3. Strengthening Pole Infrastructure | This program will involve accelerated pole replacements, additional construction hardening, including reduced pole span lengths, and increased pole diameters This program will evaluate the use of new non-wood material to replace wood poles in the future. | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm goring standards | # of poles impacted/total poles in system * customers | 50,634 | 2% Reduction in the number of Outages Due to Poles replaced. Value low due to low coincidence of possible damage with replaced poles | 72,913 | 1,013 | No Benefit | 0 | 72,913 |
| | | Non-wood poles | # of poles impacted/total poles in system * customers | 1,407 | 2% Reduction due to Poles replaced. Value low due to low coincidence of possible damage with replaced poles | 2,025 | 28 | No Benefit | 0 | 2,025 |
| 4. Rebuild/Relocate Backyard poles | This program will consider the relocation and rebuilding of backyard pole lines to front lot and/or UG configuration | Rebuild backyard poles (including tree trimming) | Customers supplied by backyard circuits | 36,973 | 50% Reduction | 1,331,028 | 18,487 | Due to better access and newer facilities restoration work will be decreased by 7.2 hours(10% of 3 days) for Customers out of service | 133,103 | 1,464,131 |
| 5. Undergrounding | This program will consider the conversion of OH to UG in selected areas and the replacement of PM equipment with a submersible equivalent in targeted areas | A. Convert certain OH areas to UG | Estimate # circuits that could be done to get customer count. Assume 1 mile per circuit, 20 Circuits with average of 735 customers/section | 14,700 | Assume 60% reduction due to damage being avoided on primary lines now underground. | 635,040 | 8,820 | No Benefit | 0 | 635,040 |
| | | B. Replace PM xfmr's with submersible xfmr's in target areas | Avg. Customers per padmounted transformer in flood area | 1,894 | Assume 90% reduction in PSE&G equipment outages due to storm surge. Outage duration of 3 days avoided | 122,731 | 1,705 | No Benefit | 0 | 122,731 |
| | | C. Replace ATIS switches/transformers with submersible switches | Customer benefit aligned with PM Transformer program as ATIS typically supply PM in these areas | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B |
| 6. Relocate ESOC/GSOC/DERC/SR | This program will relocate our critical Electrical & Gas dispatch operating centers to a higher level within the existing building, making it less susceptible flooding, etc. | Relocate critical operating centers | Total number of Customers | 2,250,511 | N/A | 0 | 0 | Low probability event. Assume 1% probability in a major event with Average 6 hour increase in overall restoration. | 135,031 | Risk Item not included in hours saved |
| Advanced Technologies | 1. This program will utilize new and significantly enhanced technologies, including GIS, DMS, Mobile Solutions, Predictive Analytics, and Advanced Customer Communications solutions to improve storm and emergency response and enhance communications to customers. | System Visibility 1a. Expand implementation of 26kV, 13kV, and 4kV Microprocessor Relays and SCADA field equipment (RTUs) to enable remote operation and position indication of each feeder circuit breaker, provide remote monitoring capabilities including circuit and transformer loading, circuit breaker position, load imbalance, will assist in fault location and more. | # Customers in Stations | 1,134,374 | No Benefit | 0 | 0 | Assume 4 hour improvement in overall restoration time due to indication of circuit outages, immediate load data for decision making and the ability to remotely set-up circuits for work. | 4,537,496 | 4,537,496 |
| | | 1c. System to visualize, control, collect and analyze all monitored points from each Distribution station. This includes SCADA monitors and servers, dispatch consoles, communications switches and servers, historical server with appropriate back-up and redundancy (DMS) | Benefits Aligned with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A |
| | | Communication Network 2a. High Speed Fiber Optic Network (Backbone)- Transmission - Complete build out equating to approximately 30% of the total system (in progress). Distribution - Build fiber optic network from (B1) of the (125) Distribution substations (Class A, B, C, CN, CS, etc) to facilitate the information transfer from the station to the new DMS system. | Benefits Aligned with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A |
| | | 2b. Pilot Satellite Communication Program | Total number of Customers | 2,250,511 | No Benefit | 0 | 0 | Low probability event. Assume 5% probability in a major event with Average 12 hour increase in overall restoration. | 1,350,307 | Risk Item not included in hours saved |
| | | Storm Damage Assessment (read all items in System Visibility) 3a. Advanced Distribution Management System (ADMS) functionality to improve visibility of circuit operations in storm conditions and support restoration of customers. Integration of SCADA, DMS, OMS and GIS. | Benefits Aligned with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A | Combined with 1A |
| | | 3b. Enhance Storm Management Systems to improve plant damage assessment process, optimize restoration work plans, integrate mutual aid crews, and develop capability to provide predictive ETNs under complex storm conditions. | Total number of Customers | 2,250,511 | No Benefit | 0 | 0 | Through confirmed damage location visibility, improved look-up process and elimination of duplicate records restoration process will be improved. Assume 4 hour improvement in average restoration in overall storm work. | 9,002,044 | 9,002,044 |
| 3c. Expand communication channels to improve ability to communicate storm-related information to customers. (Outage Map, Mobile App, Preference Management, SMS, Mobile Vrs) | Total number of Customers | 2,250,511 | No Benefit | 0 | 0 | No Benefit | 0 | 0 | | |
| Contingency Reconfiguration Strategies | This program refers to the ability of utilities to recover quickly from damage to any of its components | Establish contingency reconfiguration strategies by creating multiple sections, utilizing smart switches, smart fuses, and adding redundancy within our loop scheme | Using CIP 2 Major Results of \$1.2M per circuit equal 167 13kV circuits. Avg customer count of 1500 = 250,500 | 245,824 | Due to reconfiguration of circuits, loop improvement and fusing, 10% reduction in outages. | 1,769,933 | 24,582 | With greater system redundancy restoration time on average will improve by 10% (7.2 Hours) | 1,592,940 | 3,362,872 |
| Emergency Backup Generator and Quick Connect Stockpile Program | PSE&G to purchase and stockpile emergency backup generators to utilize during storm restoration. Technologies exist whereby a connection can be made to a residential customer electric meter which allows the quick connection of a portable generator. | PSE&G to deploy emergency generators to customers based on priorities driven by local municipal officials. In addition, PSE&G will maintain the supply of quick connects to be deployed as directed. | Number of Generators | 200 | No Benefit | 0 | 0 | Assuming a two day implementation of these measures, outage time reduced by 2 days | 9,600 | 9,600 |
| Municipal Pilot Program | To improve resiliency of the electric system, particularly by engaging valuable municipal resources in the event of prolonged outages | Develop a municipal storm plan which addresses vegetation maintenance, mobile field applications and a combined heat and power (CHP) pilot for targeted critical municipal facilities meeting the high efficiency specifications for application of this technology. | TBD | TBD | TBD | TBD | TBD | TBD | TBD | TBD |
| Total Customer Hour Outage Reductions | | | | | | | | | | 62,714,213 |
| Total Customers | | | | | | | | | | 2,250,511 |
| Summary | | Number of Customer Outages Avoided | | 325,606 | | Average Outage Reduction Per Customer | | 28 | | |

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
SUBSTATION FLOOD MITIGATION COST

QUESTION:

For purposes of this request, please refer to RCR-ECON-8.

- a. Please provide all “office level estimates using PSE&G’s experience with substation construction projects.”
- b. Please provide yearly estimates of the total expenditures on substation construction projects over the last 5 years.

Please provide the estimated percent of expenditures on substation construction projects that were contracted to outside vendors for each of the last 5 years.

Please provide a list of all outside vendors utilized for substation construction projects over the last 5 years.

Please provide the physical address of each of these companies.

Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project over the last 5 years.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. Please see the Company’s response to S-PSEG-ES-79
- b. i.

| | |
|------------------------|--------------|
| Total \$\$ | \$57,861,465 |
| Contractor \$\$ | \$14,500,451 |
| % Contractor | 25% |

- ii-iv. See the confidential attachment for total share of contractor expenditures referenced above.

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
OUTSIDE PLANT HIGHER DESIGN AND CONSTRUCTION STANDARDS

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-10.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. Costs in the “other” category consists of traffic control costs.
- b.

| Project | Cost |
|-----------------------------|--------------|
| Bergen to River Rd(C.91008) | \$5,096,741 |
| Southampton(C.90814) | \$4,368,670 |
| Bergen-Englewood | \$11,874,259 |

- c. Bergen to River Rd(C.91008)
 - i. \$567,819 = 11.14%

Southampton(C.90814)
i. \$43,889 = 1.00%

Bergen-Englewood
i. \$1,893,995 = 15.95%

- ii-iv. See the confidential attachment for total share of contractor expenditures referenced above.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-31
WITNESS(S): CARDENAS
PAGE 1 OF 2
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
OPEN WIRE OVERHEAD CONSTRUCTION WITH SPACER CABLE

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-11.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. Costs in “other” category consist of traffic control costs.
- b. Bare wire replacement is generally a component of more complex construction upgrades. The projects below are two projects completed in the last five years that are predominantly bare wire replacement, although other facilities were replaced as well.

| Project | Cost |
|----------------------|-------------|
| MTL 8012 SAIFI Major | \$1,275,554 |
| BEA 8009 SAIFI Major | \$1,013,613 |

- c. MTL 8012 SAIFI Major
 - i. 44.9% = \$573,617
- BEA 8009 SAIFI Major
 - i. 43.6% = \$441,965
- ii-iv. See the confidential attachment for total share of contractor expenditures referenced above.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-32
WITNESS(S): CARDENAS
PAGE 1 OF 2
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
STRENGTHENING POLE INFRASTRUCTURE

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-12.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. The “other” costs are related to traffic control and pole contractors.
- b. SAIFI Improvement Pole Project - \$13,625,492
- c.
 - i. 58% = \$7,949,559
 - ii-iv. See the confidential attachment for total share of contractor expenditures referenced above.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-33
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
REBUILDING BACKYARD POLE LINES

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-13.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. Costs in “other” category consist of traffic control costs.
- b. Backyard pole lines have existed in PSE&G’s territory for decades. The Company has extensive experience constructing backyard poles in an emergency scenario but has not implemented a formal program in the past five years. The Company’s estimates are based on the time required to replace poles, wires, and equipment in a normal front of yard scenario as well as the special requirements to implement this work in a customer’s back yard, such as specialized equipment and altered work practices. Emergent work is not tracked as individual jobs; therefore, the specific information requested is not available.
- c. Please see above.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-34
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
TARGETED UNDERGROUNDING TO MITIGATE STORM IMPACTS

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-14.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. Costs in “other” category consist of traffic control costs.
- b. The Company has not converted any overhead circuits to underground construction in the past five years. The Company’s estimates are based on experience in constructing overhead and underground circuits.
- c. Please see above.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-35
WITNESS(S): CARDENAS
PAGE 1 OF 3
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
REPLACE PAD-MOUNTED SWITCHES

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-15.

- a. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- b. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. See attached list of projects
- b.
 - i. 0.71% = \$7,394
 - ii-iv. See the confidential attachment for total share of contractor expenditures referenced above.

| ORDERS | MAINTACTIVTYPE | Order_Desc | REF_NUMBER1 | TOTAL_ACT_COSTS |
|-----------|----------------|--|-------------|-----------------|
| 300323889 | BEQ | UG - INSTALL ATS PMH9 | 500221985 | \$ 36,026.47 |
| 300337217 | BEQ | GENE/FRAT. MEADOW/FLOW THRU SWITCH/SKETC | 500213495 | \$ 15,473.48 |
| 300343048 | BEQ | UG - PMH9 (PAD 956) | 500172074 | \$ 17,360.49 |
| 300352149 | BEQ | 5th Bldg Lockheed Martin - ug work | 500212491 | \$ 44,586.83 |
| 300352721 | BEQ | PAD#3069 - INSTALL PMH-9 SWITCH | 500230747 | \$ 17,177.80 |
| 300364407 | BMC | Repair ATS 464 Cooper & Delaware - CM | 500243871 | \$ 6,494.82 |
| 300371388 | BEQ | RTE 4 E/B W/O GRAND AVE EW. FLATROCK (NE | 500212902 | \$ 10,690.13 |
| 300371389 | BEQ | RTE 4 E/B W/O GRAND AVE EW. FLATROCK (NE | 500212903 | \$ 14,705.36 |
| 300371390 | BEQ | FLAT ROCK RTE 4 E/B AND W.SHEFFIELD AVE. | 500212905 | \$ 13,021.51 |
| 300380115 | BEQ | JS-FLOW THRU SWITCH | 500170434 | \$ 17,649.99 |
| 300387133 | BEQ | UG - PMH9 (ATS) | 500244253 | \$ 45,353.95 |
| 300387458 | BEQ | 9/22 start Inst. pmh9, PAD#3463 | 500251040 | \$ 17,883.86 |
| 300400769 | BEQ | SWITCH Scheduled for week of 09/16 | 500252650 | \$ 9,126.15 |
| 300421787 | BEQ | HILLTOP-3-PMH9 6463-6464-6465 | 500254768 | \$ 47,438.86 |
| 300430929 | BEQ | ATS Pad 2944 | 500280501 | \$ 51,895.09 |
| 300465111 | BEQ | ATS PAD 818 REPLACEMENT | 500279954 | \$ 60,766.10 |
| 300489165 | BEQ | Install PMH 12 Style Switch PMH# 2971 | 500306325 | \$ 15,667.53 |
| 300489534 | BEQ | INS & RMV 838/837 (SECTIONALIZER) | 500288939 | \$ 115,117.07 |
| 300495683 | BEQ | PAD#3469 & PAD#3470 - 2 PMH-9 SWITCHES | 500284388 | \$ 38,607.05 |
| 300499186 | BEQ | Replacement for switch 345 | 500324303 | \$ 4,809.16 |
| 300504188 | BEQ | PUMP STATION - BILLABLE ATS-SWITCH | 500332881 | \$ 48,926.00 |
| 300528815 | BEQ | STIMULUS BUD-1089 PE 47 | 500316052 | \$ 25,795.44 |
| 300542621 | BEQ | PAD#3480 - INS. PMH-9 SWITCH | 500375619 | \$ 37,711.00 |
| 300542723 | BEQ | PAD#3473 - INS. PMH-9 SWITCH | 500296345 | \$ 19,231.71 |
| 300548080 | BEQ | PAD#3475 - INSTALL PMH-9 SWITCH | 500360741 | \$ 17,149.71 |
| 300552980 | BEQ | (2) MANUAL PM SWITCH PADS -JC | 500366723 | \$ 40,152.28 |
| 300569174 | BEQ | Install ATS Auto Switch | 500379957 | \$ 20,931.13 |
| 300591570 | BEQ | INS/RMV ATS PAD5383 | 500245005 | \$ 62,157.94 |
| 300592638 | BEQ | REM/INS PMH-9 SWITCH | 500258069 | \$ 46,447.41 |
| 300604109 | BEQ | replace ats switches | 500408093 | \$ 32,619.44 |
| 300605670 | BEQ | SERVICE TO PAR @ LINDEN GEN | 500398779 | \$ 38,822.77 |
| 300636370 | BEQ | PEH 8008 DCR- ATS SWITCH & TERMINATORS | 500428042 | \$ 48,982.10 |

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-36
WITNESS(S): CARDENAS
PAGE 1 OF 18
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
REPLACE PAD-MOUNTED TRANSFORMERS

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-16.

- a. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- b. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. See attached list of projects
- b.
 - i. 0.55% = \$84,072
 - ii-iv. See the confidential attachment for total share of contractor expenditures referenced above.

| ORDERS | MAINTACTIVTYPE | Order Descr | REF_NUMBER1 | TOTAL_ACT_COSTS |
|-----------|----------------|--|-------------|-----------------|
| 300094593 | BEQ | Htown Phase 2 transformers/pme | 500044091 | \$ 158,355.33 |
| 300191615 | BEQ | TRANSF. FROM #1 TO #31FEHERVARI CT | 500115488 | \$ 29,574.14 |
| 300191619 | BEQ | TRANSF.FROM #10 TO #57 SPANGENBERG | 500115488 | \$ 20,848.45 |
| 300205591 | BEQ | 54 homes/3- TRANSFORMERS | 500126329 | \$ 12,936.02 |
| 300233915 | BEQ | transformers 2305- 2307 | 500143410 | \$ 32,092.98 |
| 300251248 | BEQ | BUD HEARTHSTONE @ HBT/10 transformers | 500148696 | \$ 33,886.89 |
| 300261626 | BEQ | PAD,TRF,ELBOWS | 500170149 | \$ 64,894.78 |
| 300262055 | BEQ | Switching,Transformers-Elbows,Pads-PSEG | 500102189 | \$ 99,489.19 |
| 300269935 | BEQ | INS XFMR BLDG A - 11-3-11 | 500179611 | \$ 12,004.22 |
| 300277984 | BEQ | PAULIUS WAREHOUSE- TRANSFORMER | 500192869 | \$ 36,184.40 |
| 300283577 | BEQ | TRANSFORMERS BLDG 1 & 2 | 500193881 | \$ 21,357.01 |
| 300302105 | BEQ | PADS, TRFS AND ELBOWS | 500084700 | \$ 25,769.38 |
| 300305077 | BEQ | Install Transformer 100kva - EH | 500211667 | \$ 6,347.28 |
| 300308203 | BEQ | 1 PH TRANSFORMER WORK | 500127463 | \$ 72,702.93 |
| 300312183 | BEQ | TRANSFORMERS- ph 1 | 500150401 | \$ 34,734.27 |
| 300315952 | BEQ | 150 KVA TRF | 500213668 | \$ 10,831.45 |
| 300321097 | BEQ | REPLACE/UPGRADE PADMOUNT TRANSFORMERS | 500217826 | \$ 68,146.49 |
| 300329151 | BEQ | JK-PINNACLE BUD 612 INSTALL MINI PADS | 500209176 | \$ 20,963.55 |
| 300333010 | BEQ | switching/transformers (elbows/pads) | 500180748 | \$ 57,115.94 |
| 300335776 | BEQ | SWITCHING/TRANSFORMERS | 500125647 | \$ 82,355.22 |
| 300339465 | BEQ | TRANSFORMERS FOR LARA & CORDA LN | 500095979 | \$ 5,018.29 |
| 300339575 | BEQ | PAD/TRF 4086 | 500229624 | \$ 11,070.78 |
| 300346311 | BEQ | JK-PAD MOUNT TRANSFORMER | 500235096 | \$ 11,001.84 |
| 300347350 | BEQ | TRANSFORMERS- ph 2 | 500150401 | \$ 37,306.70 |
| 300347517 | BEQ | transformer | 500216689 | \$ 6,658.94 |
| 300355259 | BEQ | TRANSFORMER ADDED - T1266 | 500213603 | \$ 2,587.10 |
| 300361778 | BEQ | INSTALLATION OF PADMOUNT TRANSFORMER | 500225051 | \$ 12,773.73 |
| 300364259 | BEQ | 1500Kva-trans., pad & elbows. | 500210172 | \$ 26,877.00 |
| 300367909 | BEQ | TRANSFORMERS - PHASE 2 released to order | 500174157 | \$ 23,222.14 |
| 300370033 | BEQ | XFMR - T-3599 (750 KVA) | 500232818 | \$ 23,205.08 |
| 300370040 | BEQ | XFMR - T-3601 (300 KVA) | 500232818 | \$ 12,207.17 |
| 300373745 | BEQ | Pad#147 Replacement | 500237371 | \$ 3,854.31 |
| 300373953 | BEQ | Replace Leaking 1000KVA PM Transformer | 500250851 | \$ 25,158.18 |
| 300379796 | BEQ | PT MANOR PH 3-BUD 1754-Inst Transformers | 500072541 | \$ 44,130.15 |
| 300387555 | BEQ | 1 ph transformers | 500232818 | \$ 20,543.75 |
| 300390455 | BEQ | INSTALL TRANSF #T2301 150KVA | 500143298 | \$ 13,420.25 |
| 300392491 | BEQ | INSTALL PADMOUNT TRANSFORMER | 500253475 | \$ 7,898.77 |
| 300393238 | BEQ | INSTALL T2297,2298,2299&2300 | 500143298 | \$ 19,332.63 |
| 300393368 | BEQ | TRANSFORMERS, ELBOWS,PERFORM SWITCHING | 500152413 | \$ 84,485.82 |
| 300396745 | BEQ | FRANKLIN GREENS SOUTH 50KVA REPLACEMENTS | 500263426 | \$ 19,121.51 |
| 300401874 | BEQ | Replace Def. Transformers T-14,T-13,T-12 | 500248296 | \$ 4,926.31 |
| 300404002 | BEQ | NEW PAD 3010 | 500264778 | \$ 3,496.42 |
| 300410094 | BEQ | BUD1042 HM /INST & REM TRFS. & ELBOWS | 500237370 | \$ 67,165.74 |
| 300412092 | BEQ | BUD1387 JEFFERSON AT EWING /Transformers | 500259221 | \$ 45,178.30 |
| 300421025 | BEQ | Install 4 X-formers | 500237923 | \$ 49,176.96 |
| 300423941 | BEQ | 500 KVA PAD | 500210511 | \$ 10,848.59 |
| 300424625 | BEQ | RIVEREDGE--50KVA LF13KV (2) - JC | 500266758 | \$ 5,722.81 |
| 300424626 | BEQ | RIVEREDGE--100KVA LF13KV (11)- JC | 500266758 | \$ 27,828.98 |
| 300424627 | BEQ | RIVEREDGE--167KVA LF13KV (1) | 500266758 | \$ 13,805.63 |
| 300429519 | BEQ | DARIO-INSTALL 1500KVA SEE TEXT | 500335717 | \$ 39,442.61 |
| 300430072 | BEQ | Relocate T3142 ON COPE COURT | 500280025 | \$ 3,780.96 |
| 300433382 | BEQ | INSTALL COFFIN PME & DBL PAD | 500227525 | \$ 65,955.02 |
| 300433443 | BEQ | INSTALLATION OF T-438 | 500234918 | \$ 16,357.46 |
| 300435869 | BEQ | 750 kva 277/480-4w 13kv rdf padmount | 500275996 | \$ 19,754.81 |

| | | | | | |
|-----------|-----|--|-----------|----|------------|
| 300443937 | BEQ | INSTALL 300KVA 120/208 4W PADMOUNT TRANS | 500259280 | \$ | 10,918.91 |
| 300445457 | BEQ | REPLACE TRANSF'S T290 + T291 + T287 | 500286188 | \$ | 17,889.75 |
| 300450643 | BEQ | INSTALL 100KVA T#1244 | 500222278 | \$ | 5,875.63 |
| 300450646 | BEQ | INSTALL 50KVA T#1247 | 500222278 | \$ | 2,924.48 |
| 300450647 | BEQ | INSTALL 100KVA T#1248 | 500222278 | \$ | 4,046.70 |
| 300450653 | BEQ | INSTALL 100KVA T#1251 | 500222278 | \$ | 4,556.41 |
| 300450660 | BEQ | INSTALL 167KVA T#1255 | 500222278 | \$ | 11,120.74 |
| 300450663 | BEQ | INSTALL 100KVA T#1257 | 500222278 | \$ | 4,093.17 |
| 300450664 | BEQ | INSTALL 100KVA T#1258 | 500222278 | \$ | 8,514.50 |
| 300450668 | BEQ | INSTALL 100KVA T#1260 | 500222278 | \$ | 3,358.84 |
| 300450670 | BEQ | INSTALL 100KVA T#1262 | 500222278 | \$ | 2,697.94 |
| 300450671 | BEQ | INSTALL 100KVA T#1263 | 500222278 | \$ | 3,358.85 |
| 300450673 | BEQ | INSTALL 100KVA T#1265 | 500222278 | \$ | 3,579.15 |
| 300454639 | BEQ | 3 PHASE TRANSFORMER 1283 | 500237581 | \$ | 13,526.54 |
| 300454640 | BEQ | 3 PHASE TRANSFORMER 1284 | 500237581 | \$ | 13,526.53 |
| 300454642 | BEQ | 50KVA TRANSFORMER 1286 | 500237581 | \$ | 10,300.50 |
| 300454743 | BEQ | 50KVA TRANSFORMER 1287 | 500237581 | \$ | 1,845.33 |
| 300454744 | BEQ | 50KVA TRANSFORMER 1288 | 500237581 | \$ | 1,845.33 |
| 300454745 | BEQ | 50KVA TRANSFORMER 1289 | 500237581 | \$ | 2,181.72 |
| 300454851 | BEQ | REPLACE XFMR'S T4 + T102 | 500292574 | \$ | 6,819.51 |
| 300457308 | BEQ | 750 kva 120/208-w pad mount | 500294228 | \$ | 23,032.16 |
| 300457737 | BEQ | Inst 100Kva pad mounted trans. Pad-3729 | 500276810 | \$ | 3,643.27 |
| 300464358 | BEQ | Transformers - Phase 3-5 | 500180748 | \$ | 26,328.51 |
| 300465855 | BEQ | REPLACE T-439 TO 100KVA | 500285672 | \$ | 4,449.78 |
| 300467287 | BEQ | REPL T-268/T-269/T-202/T-201/T-200 1/3 | 500300686 | \$ | 23,997.02 |
| 300470851 | BEQ | 750 KVA-PADMOUNT TRANSFORMER-120/208-4W | 500294208 | \$ | 1,410.81 |
| 300473383 | BEQ | REPLACE XFMR'S T953, T956 | 500298740 | \$ | 9,433.67 |
| 300473521 | BEQ | REPLACE XFMR T714 | 500298740 | \$ | 3,760.61 |
| 300474933 | BEQ | REPLACE 1 PHASE T-441 & T-442 | 500285672 | \$ | 10,406.25 |
| 300475612 | BEQ | 5 REPLACE T-103 AND T-85 | 500300688 | \$ | 10,113.72 |
| 300475614 | BEQ | 5 REPLACE T-70 AND T-341 | 500300688 | \$ | 5,421.52 |
| 300475616 | BEQ | 5 REPLACE T-342 AND T-335 | 500300688 | \$ | 7,988.74 |
| 300475618 | BEQ | 5 REPLACE T-340 AND T-343 | 500300688 | \$ | 5,550.78 |
| 300476382 | BEQ | INSTALL NEW T-3671 | 500273572 | \$ | 3,989.88 |
| 300478399 | BEQ | INSTALLATION OF T-3679 | 500291238 | \$ | 10,135.62 |
| 300478640 | BEQ | UG T-2167 REPL 750KVA 265/460V PAD MOUNT | 500277718 | \$ | 35,065.30 |
| 300478957 | BEQ | Sheet 1: TRANSFORMERS | 500315231 | \$ | 136,782.08 |
| 300478962 | BEQ | Sheet 2: TRANSFORMERS | 500315231 | \$ | 13,531.00 |
| 300479692 | BEQ | BUD#186 REPLACE 10 TRANSFORMERS | 500315229 | \$ | 24,781.53 |
| 300482139 | BEQ | INS/RMV TRANSF & HHs A-PH, SEC 1 | 500315232 | \$ | 28,164.54 |
| 300482231 | BEQ | INS/RMV TRANSF C-PH, SEC 1 | 500315232 | \$ | 20,302.30 |
| 300483035 | BEQ | Replace Trans. 260/261/262/264 Sheet A | 500317095 | \$ | 21,549.42 |
| 300483855 | BEQ | 3 REPLACE TWO TRANSFORMERS TASKS | 500315226 | \$ | 8,670.59 |
| 300484759 | BEQ | SHELTON-TRANSFORMER ORDER | 500289454 | \$ | 24,171.01 |
| 300484863 | BEQ | INS/RMV PME's & TRANF - B-PH SEC 2 | 500315232 | \$ | 6,085.99 |
| 300485374 | BEQ | SHEET 3 REPL XFORMERS NON LEAKERS | 500315235 | \$ | 27,507.73 |
| 300486395 | BEQ | SHEET 4 REPL XFORMERS NON LEAKER | 500315235 | \$ | 11,190.10 |
| 300486400 | BEQ | Sheet 1: Transformers | 500315233 | \$ | 21,203.06 |
| 300486415 | BEQ | PAD 1091 PAD REPLACEMENT | 500289445 | \$ | 5,184.63 |
| 300486470 | BEQ | Sheet 2: Transformers | 500315233 | \$ | 15,899.85 |
| 300486474 | BEQ | SHEET 5 REPL XFORMERS NON LEAKERS | 500315235 | \$ | 28,880.53 |
| 300486475 | BEQ | SHEET 3 REPL XFORMERS LEAKERS 339 & 264 | 500315235 | \$ | 3,940.83 |
| 300489390 | BEQ | (PS) 1090 Thomas Busch Hwy. /Repl. trf. | 500432924 | \$ | 20,248.86 |
| 300491277 | BEQ | PAD 2486 | 500308918 | \$ | 1,984.59 |
| 300491344 | BEQ | Replace XFMR T6 & T7 | 500285673 | \$ | 7,587.32 |

| | | | | | |
|-----------|-----|--|-----------|----|-----------|
| 300500700 | BEQ | PAD#4000 - INSTALL 150KVA 120/208V 4W | 500322587 | \$ | 10,952.00 |
| 300501763 | BEQ | UG PADMOUNTED TRANSFORMER | 500322568 | \$ | 33,248.32 |
| 300504080 | BEQ | PUMP STATION - TRANSFORMER | 500332881 | \$ | 8,990.53 |
| 300505281 | BEQ | Inst 1500Kva 277/480v & elbows Pad-1329 | 500257410 | \$ | 27,747.94 |
| 300505505 | BEQ | INS 500KVA RDF PMT PAD#2345 | 500331703 | \$ | 19,543.75 |
| 300506508 | BEQ | UG PAD XFORMER WORK (EXACT DATE: 8/14) | 500330943 | \$ | 9,862.38 |
| 300507302 | BEQ | Inst. 1000kVA 277/480v Pad | 500332507 | \$ | 20,362.12 |
| 300509901 | BEQ | DARIO-INSTALL 300KVA SEE TEXT | 500332913 | \$ | 14,652.03 |
| 300512999 | BEQ | 750 277/480v 3PH 13KV | 500335561 | \$ | 20,565.02 |
| 300514650 | BEQ | XFMRS - VILLAGES @ DELAWARE RUN-BUD 1940 | 500225973 | \$ | 18,847.09 |
| 300519193 | BEQ | Remove & Install Transformers - WOR8021 | 500340395 | \$ | 7,288.68 |
| 300519194 | BEQ | Remove & Install Transformers - LAF8011 | 500340395 | \$ | 9,325.29 |
| 300520100 | BEQ | Emergency transformer replacement for 1 | 500345506 | \$ | 23,748.93 |
| 300521485 | BEQ | padmount 189 upgrade 277/480 1000kva | 500346177 | \$ | 18,436.86 |
| 300521590 | BEQ | Stimulus-TRF'S | 500334477 | \$ | 51,991.37 |
| 300522084 | BEQ | Stimulus-TRF'S & PRI ENCLOSERS | 500334447 | \$ | 56,410.91 |
| 300522778 | BEQ | (BR) 361 Benigno Blvd / Repl Trf | 500440793 | \$ | 29,409.58 |
| 300523061 | BEQ | PAD#4150 300KVA 120/208V XFMR | 500340797 | \$ | 13,792.82 |
| 300523526 | BEQ | REPLACE T-86 WITH 50KVA | 500292579 | \$ | 5,136.70 |
| 300524783 | BEQ | Stimulus-REPLACE TRF'S AND RECLOSERS | 500334446 | \$ | 28,106.49 |
| 300527582 | BEQ | INSTALLATION OF T-1189 | 500336653 | \$ | 28,586.03 |
| 300527666 | BEQ | Inst. 2-2000kVA with PME | 500265650 | \$ | 75,142.97 |
| 300527828 | BEQ | Stimulus-BUD 28 - UG TRANSFORMERS | 500334478 | \$ | 63,980.72 |
| 300528743 | BEQ | T-135 2500KVA TRANS. | 500348331 | \$ | 38,080.91 |
| 300530012 | BEQ | rmv/ins transformer mayfield ave edison | 500351020 | \$ | 19,580.56 |
| 300530043 | BEQ | TRANSF FOR MURPHY DR | 500319540 | \$ | 8,360.50 |
| 300530044 | BEQ | TRANSF. FOR GALLIGEN & McCARLES | 500319540 | \$ | 25,169.87 |
| 300530153 | BEQ | (WW) BUD1966 Inst Transformers | 500228763 | \$ | 70,073.65 |
| 300530495 | BEQ | Stimulus-REPLACE TRANSFORMERS | 500334459 | \$ | 40,211.02 |
| 300531602 | BEQ | Replace Padmounts | 500350979 | \$ | 9,437.88 |
| 300534580 | BEQ | PAD#2900 - REPLACE TRANSFORMER 277/480V | 500353435 | \$ | 30,257.29 |
| 300535041 | BEQ | INSTALLATION OF T-3271 | 500343731 | \$ | 2,502.79 |
| 300535447 | BEQ | Stim BUD 38 REM/INS TRNASF | 500334481 | \$ | 70,832.38 |
| 300535713 | BEQ | INSTALL 300KVA PADMOUNT TRASF. W/ PAD | 500354015 | \$ | 10,727.95 |
| 300536090 | BEQ | PHASE 1-UG TRANSFORMERS | 500346569 | \$ | 20,693.67 |
| 300536140 | BEQ | CN HARBOUR - PHASE 6.UG PADS & SWITCHING | 500353947 | \$ | 22,775.50 |
| 300536433 | BEQ | INSTALL 300KVA 120/208V DR. @ PAD 1977 | 500345851 | \$ | 19,000.63 |
| 300536890 | BEQ | DARIO-I-2-PE'S & 500KVA | 500356450 | \$ | 33,523.88 |
| 300537031 | BEQ | PADS & PERFORM SWITCHING -PHASE 2B | 500341661 | \$ | 18,221.34 |
| 300537057 | BEQ | PADS & SWITCHING-PHASE 2C | 500350936 | \$ | 8,190.31 |
| 300537145 | BEQ | SINGLE PH & 3 PH UG TRANSFORMERS | 500317357 | \$ | 44,057.83 |
| 300537406 | BEQ | PADMOUNTED TRANSFORMERS | 500125880 | \$ | 33,316.94 |
| 300538942 | BEQ | UG PADS-PHASE 1 | 500317795 | \$ | 37,208.38 |
| 300539772 | BEQ | EQUIPMENT-500kva d/r 120/208-4w rdf | 500346073 | \$ | 14,663.48 |
| 300540091 | BEQ | UG PADMOUNT TRANSFORMER | 500356884 | \$ | 14,731.85 |
| 300540713 | BEQ | INSTALL 750 KVA PAD MOUNT TRANS | 500351720 | \$ | 19,297.91 |
| 300541729 | BEQ | (WW) Princeton Theological BLDG#2 Trf. | 500335315 | \$ | 18,129.38 |
| 300541730 | BEQ | (WW) Princeton Theological BLDG#3 Trf. | 500335316 | \$ | 16,435.37 |
| 300542773 | BEQ | Stim-BUD1084- UG to rem/inst 23 TRANSFOR | 500334448 | \$ | 66,164.49 |
| 300542906 | BEQ | PH 1-XFMRS CONDOS BLG 14 (2 xfmrs) | 500318279 | \$ | 14,667.72 |
| 300542910 | BEQ | PH 1 Xfmr's(3) TH Blg's: 9-7-5-6 | 500317417 | \$ | 10,785.42 |
| 300543362 | BEQ | Ph 4 Xfmr's(4) TH Blg's: 11-12-13-14 | 500317417 | \$ | 7,873.09 |
| 300543378 | BEQ | INSTALLATION OF T-541 | 500343036 | \$ | 19,326.70 |
| 300543425 | BEQ | PH 5&6 Xfmr's(4) TH Blg's: 8-10-17-18 | 500317417 | \$ | 9,819.86 |
| 300543618 | BEQ | PH 5/6-XFMRS Condo Blg's 9 & 10 | 500318279 | \$ | 28,779.78 |

| | | | | | |
|-----------|-----|--|-----------|----|-----------|
| 300543874 | BEQ | INSTALLATION OF NEW T-3696 | 500358121 | \$ | 28,834.49 |
| 300544835 | BEQ | transformer 500kva 120/208 | 500360722 | \$ | 9,850.55 |
| 300544837 | BEQ | 500 kva 120/208 transformer | 500360635 | \$ | 14,555.21 |
| 300544838 | BEQ | 500 kva transformer 120/208 | 500359881 | \$ | 12,010.94 |
| 300545427 | BEQ | REPLACE T-8 & T-5 WITH 100KVA | 500361765 | \$ | 4,003.70 |
| 300546219 | BEQ | repl padmounted xfmr 448 & 379 | 500309395 | \$ | 3,842.80 |
| 300547013 | BEQ | INSTALL 750 KVA PAD MOUNT TRANS | 500357843 | \$ | 19,100.73 |
| 300547180 | BEQ | INST. 750kVA DR 277/480V | 500336866 | \$ | 23,914.57 |
| 300547453 | BEQ | INSTALLATION OF NEW T-3697 | 500358536 | \$ | 29,646.02 |
| 300548079 | BEQ | PAD#3476 - 2500KVA 277/480V TRANSFORMER | 500360741 | \$ | 37,754.13 |
| 300548317 | BEQ | INS X-FRMR/CELL SITE 120/240V 1PH 200A | 500361807 | \$ | 4,664.80 |
| 300549296 | BEQ | PADMOUNT TRANSFORMERS - LEIA WAY | 500354529 | \$ | 21,158.41 |
| 300549301 | BEQ | PADMOUNT TRANSFORMERS - ELLA LANE | 500354529 | \$ | 13,318.15 |
| 300550068 | BEQ | PAD#2786 REP. 1500KVA w/ 2000KVA XFMR | 500362023 | \$ | 36,541.15 |
| 300550178 | BEQ | Pad mount transformers BUD# 1133 | 500367141 | \$ | 23,205.22 |
| 300550673 | BEQ | ENBC 1400 RIVER RD, EWR XFMR | 500356731 | \$ | 15,095.75 |
| 300550709 | BEQ | DARIO-PE & TRANSFORMER WORK | 500358040 | \$ | 6,630.43 |
| 300550841 | BEQ | Tenby Towne BUD 63 - DR-transformers | 500367224 | \$ | 42,739.06 |
| 300551019 | BEQ | INST T-1460 500KVA PAD MOUNT TRANS | 500361490 | \$ | 15,001.29 |
| 300551543 | BEQ | INS TRF & ELBOS/McD's 120/208V 3PH 1000A | 500360538 | \$ | 12,667.84 |
| 300552136 | BEQ | INSTALLATION OF T-1192 | 500360117 | \$ | 14,325.37 |
| 300552394 | BEQ | PAD/TRF 750 Kva | 500329645 | \$ | 21,260.27 |
| 300552622 | BEQ | Stim 2 Woodridge BUD 293 Transformer | 500367356 | \$ | 15,171.80 |
| 300552750 | BEQ | BUD636 (3-75KVA) -TS | 500352349 | \$ | 10,604.30 |
| 300552752 | BEQ | BUD636 (4-100KVA)- TS | 500352349 | \$ | 29,680.52 |
| 300552973 | BEQ | (5) 150KVA 3PHASE 120-208 PAD XFMR -JC | 500366723 | \$ | 40,095.34 |
| 300553020 | BEQ | RMV & INS XMERS FOR BUD-25 | 500353392 | \$ | 7,087.21 |
| 300553373 | BEQ | ins. pad. transf'r baekeland ave mid. | 500363811 | \$ | 9,322.46 |
| 300555749 | BEQ | INSTALL/REMOVE T-291 | 500308655 | \$ | 101.60 |
| 300556335 | BEQ | INS. 750KVA XFMR 277/480V @ PAD 1477 | 500365533 | \$ | 20,818.41 |
| 300557136 | BEQ | Transformers PH1 | 500368574 | \$ | 7,119.14 |
| 300557150 | BEQ | ins. padmount transformer rte 27 edison | 500367712 | \$ | 13,431.83 |
| 300557781 | BEQ | BUD# 1161 Padmount Transformers | 500371253 | \$ | 33,763.23 |
| 300557971 | BEQ | Inst 167Kva 120/240v 3w trans, Pad#1341 | 500365420 | \$ | 8,565.01 |
| 300558012 | BEQ | INS. 1500KVA XFMR @ PAD 2386 | 500368636 | \$ | 29,468.17 |
| 300558526 | BEQ | PAD TRF 750 KVA | 500332503 | \$ | 18,575.35 |
| 300558581 | BEQ | MCGOWEN TRANS WORK SEC.#1 | 500305792 | \$ | 60,929.57 |
| 300558816 | BEQ | BUD 109-INS&RMV XMERS | 500361764 | \$ | 20,311.97 |
| 300558829 | BEQ | 750 kva 120/208 D/R RDF | 500265838 | \$ | 27,201.72 |
| 300559013 | BEQ | 25kva Padmount and pad | 500364049 | \$ | 3,961.16 |
| 300559035 | BEQ | BUD 264 - INS&RMV TRANSFORMERS | 500340108 | \$ | 11,639.37 |
| 300559101 | BEQ | Inst. 4 LPF 13kv 750kVA pad mounts | 500363838 | \$ | 77,956.47 |
| 300559341 | BEQ | BUD 324 - INS & RMV TRANSFORMERS | 500361766 | \$ | 4,863.66 |
| 300559448 | BEQ | RMV & INS XMERS FOR BUD-105 | 500340397 | \$ | 27,067.20 |
| 300559615 | BEQ | INSTALLATION OF T-1286 | 500371951 | \$ | 10,535.48 |
| 300559750 | BEQ | PAD#3996 - 25KVA TRANSFORMER | 500371967 | \$ | 2,981.02 |
| 300561528 | BEQ | PAD#3477 - INS. 225KVA 120/208v XFMR | 500368893 | \$ | 12,808.11 |
| 300562158 | BEQ | PAD#3999 - INS. 500KVA 120/208v XFMR | 500372291 | \$ | 15,171.19 |
| 300562473 | BEQ | 500kva D/R 277/480-4W RDF | 500367309 | \$ | 4,886.97 |
| 300562531 | BEQ | replace existing 225kVA UG padmount tran | 500359840 | \$ | 16,004.61 |
| 300562774 | BEQ | Inst. PME & 2 - 1500kVA 277/480V Pads | 500360728 | \$ | 64,551.66 |
| 300562789 | BEQ | 750 kva 13kv RDF 277/480-4w | 500355339 | \$ | 18,669.24 |
| 300562916 | BEQ | (LM) 1594 Rte38 Miller Ford/Repl Trf | 500374381 | \$ | 11,821.68 |
| 300563818 | BEQ | Replace XFMR - Stimulus - canterbury - BUD14 | 500334484 | \$ | 44,519.39 |
| 300564053 | BCA | 1. Springdale - DL, UG P# 63256 (p) | 500361770 | \$ | 38,726.19 |

| | | | | | |
|-----------|-----|--|-----------|----|-----------|
| 300564183 | BEQ | UG-Inst 225Kva 120/208v 13Kv radial pad4 | 500374128 | \$ | 11,930.61 |
| 300565709 | BEQ | 357 RIVER RD, EW PDMT XFMR | 500371488 | \$ | 20,756.40 |
| 300565710 | BEQ | 357 RIVER RD, EW PDMT XFMR | 500371489 | \$ | 12,347.86 |
| 300566402 | BEQ | 277/480v 2500kva pad# 108 | 500373964 | \$ | 36,040.93 |
| 300566498 | BEQ | Inst 120/208v 500Kva radial & 3a pad1342 | 500374425 | \$ | 12,809.39 |
| 300566528 | BEQ | UG PADMOUNT TRANSFORMER | 500440527 | \$ | 15,302.59 |
| 300566529 | BEQ | PME & TRANSFORMERS FOR DAHLIA CT | 500356915 | \$ | 77,032.81 |
| 300566530 | BEQ | TRANSFORMERS FOR CROCUS CT | 500356915 | \$ | 1,870.61 |
| 300566535 | BEQ | TRANSFORMERS FOR CALADIUM CT | 500356915 | \$ | 2,562.18 |
| 300566636 | BEQ | INS PAD #3995-150 KVA/ 3ph 120/208v 400A | 500248721 | \$ | 10,168.85 |
| 300566694 | BEQ | PME & TRANSFORMERS FOR AMARYLLIS LANE | 500356915 | \$ | 8,302.80 |
| 300566695 | BEQ | TRANSFORMERS FOR LILY LANE | 500356915 | \$ | 22,155.09 |
| 300566696 | BEQ | TRANSFORMERS FOR BEGONIA COURT | 500356915 | \$ | 32,404.79 |
| 300566760 | BEQ | PAD#3998 - 1000KVA 277/480v XFMR | 500298596 | \$ | 19,539.64 |
| 300567231 | BEQ | rmv/ins padmount saw mill pond rd edison | 500375954 | \$ | 30,826.51 |
| 300567268 | BEQ | Padmount Xfmr. | 500359856 | \$ | 3,931.10 |
| 300567350 | BEQ | Ins Padmount Xfmrr | 500346199 | \$ | 7,345.35 |
| 300567584 | BEQ | UG PADMOUNT TRANSFORMER | 500341659 | \$ | 18,394.96 |
| 300568004 | BEQ | NEW ELEC SVC - 277/480V, 3 PH, 2500 AMPS | 500377661 | \$ | 31,021.19 |
| 300568166 | BEQ | transformer upgrade 500kva | 500377221 | \$ | 16,598.42 |
| 300568168 | BEQ | upgrade transformer 500 kva | 500375948 | \$ | 14,667.74 |
| 300568346 | BEQ | Inst 300Kva 120/208v 13Kv loopfeed | 500371821 | \$ | 11,401.20 |
| 300568467 | BEQ | UG-Inst 500Kva 120/208v radial 4Kv & pad | 500362446 | \$ | 19,007.22 |
| 300568616 | BEQ | INS PAD # 506 / 120/208V 3PH 2000 A | 500377355 | \$ | 14,612.93 |
| 300568673 | BEQ | UG-inst 300kva dual, pad 1343 | 500376945 | \$ | 14,295.81 |
| 300569801 | BEQ | 750 kva120/208-4w D/R padmount trans rdf | 500379160 | \$ | 27,699.39 |
| 300569865 | BEQ | 120/208-4w 300kva RDF padmount | 500365771 | \$ | 11,409.07 |
| 300569866 | BEQ | 120/208-4w 300kva RDF padmount | 500365772 | \$ | 10,066.88 |
| 300569905 | BEQ | Install 2000kVA 277/480V RDF | 500265981 | \$ | 34,117.87 |
| 300570070 | BEQ | Stim-BUD46-rem/inst TRANSFORM additional | 500334458 | \$ | 71,483.53 |
| 300570348 | BEQ | Install Pad Mount Transformer -EH | 500374019 | \$ | 24,080.31 |
| 300570993 | BEQ | NEW PAD/TRF #3369 | 500378905 | \$ | 3,324.50 |
| 300571175 | BEQ | UG PADMOUNT TRANSFORMERS | 500378813 | \$ | 11,959.06 |
| 300571332 | BEQ | INSTALLATION OF T-3709 | 500345582 | \$ | 25,375.63 |
| 300571337 | BEQ | INSTALLATION OF T-3710 | 500345583 | \$ | 23,211.53 |
| 300571346 | BEQ | INSTALLATION OF T-3711 | 500345584 | \$ | 26,270.31 |
| 300571748 | BEQ | INST. T-3277 1500KVA TRANS. 277/480 | 500374372 | \$ | 28,315.64 |
| 300572169 | BEQ | MUG - PADMT TRF WORK - BLDG# 43 | 500362045 | \$ | 12,498.83 |
| 300572248 | BEQ | INS. 1500KVA 277/480v LF XFMR | 500348853 | \$ | 27,866.36 |
| 300572469 | BEQ | ug xfmr | 500377375 | \$ | 28,674.59 |
| 300572614 | BEQ | TRANSFORMERS ON GRAPHITE DR-JC | 500163110 | \$ | 17,371.38 |
| 300573198 | BEQ | CHANGE OUT T-1420 WITH A SHUTDOWN | 500285932 | \$ | 11,071.24 |
| 300573199 | BEQ | INSTALLATION OF T-1423 | 500285932 | \$ | 12,495.73 |
| 300573272 | BEQ | INSTALLATION OF T-1465 | 500285931 | \$ | 12,963.11 |
| 300573809 | BEQ | Install Pad Mount Transformer-EH | 500267179 | \$ | 20,123.03 |
| 300574090 | BEQ | 150 kva padmount | 500367244 | \$ | 8,120.64 |
| 300574149 | BEQ | INS. 2000KVA XFMR @ PAD 2396 277/480V D | 500377665 | \$ | 14,627.02 |
| 300574431 | BEQ | Inst 150Kva 120/208 13Kv radial pad-2982 | 500378895 | \$ | 8,738.79 |
| 300574695 | BEQ | PAD/DOGHOUSE | 500380668 | \$ | 4,332.24 |
| 300574996 | BEQ | 750Kva radial 277/480v 1200a, 4Kv dual | 500372324 | \$ | 20,973.88 |
| 300575122 | BEQ | (DR) #2904 Rte130 / Inst Pad & Trf. | 500383655 | \$ | 11,175.17 |
| 300575928 | BEQ | UG Inst 1-ph pad mount transformer 167Kv | 500382980 | \$ | 5,692.91 |
| 300576604 | BEQ | UG PADMOUNT TRANSFORMER | 500377383 | \$ | 1,696.77 |
| 300576726 | BEQ | 500 KVA PAD/TRF | 500374457 | \$ | 13,316.42 |
| 300576846 | BEQ | UG 1000Kva 277/480v 13Kv trans, pad-1133 | 500381581 | \$ | 24,234.64 |

| | | | | | |
|-----------|-----|--|-----------|----|------------|
| 300577123 | BEQ | UG PADMOUNT TRANSFORMER | 500368875 | \$ | 12,069.87 |
| 300577271 | BEQ | UG PADMOUNT TRANSFORMER (LNB) | 500380642 | \$ | 23,094.72 |
| 300577452 | BEQ | BUD 636 (1-167kVA) -TS | 500352349 | \$ | 8,251.75 |
| 300577576 | BEQ | ins. padmount transformer runyons la ed. | 500367222 | \$ | 18,566.29 |
| 300578828 | BEQ | New 1000kVA 13kv 120/208V Padmount | 500386652 | \$ | 27,687.80 |
| 300578829 | BEQ | New 1000kVA 13kv 277/480V Padmount | 500386656 | \$ | 28,102.62 |
| 300579172 | BEQ | PAD#2791 - INS. 1500KVA 277/480V LOOP XF | 500357888 | \$ | 28,705.76 |
| 300579462 | BEQ | INS. 500KVA XFMR @ PAD #2308 | 500386679 | \$ | 19,023.01 |
| 300579907 | BEQ | Install Transformers - ADA8024 - PAGE1 | 500341999 | \$ | 7,014.09 |
| 300579958 | BEQ | Install XFMR'S - BEN8012 - PAGE2 | 500341999 | \$ | 27,864.23 |
| 300579973 | BEQ | Install Transformers - BEN8012 - PAGE1 | 500341999 | \$ | 9,193.54 |
| 300580074 | BEQ | New 150kVA 13kv Padmount Transformer | 500387161 | \$ | 13,626.24 |
| 300580090 | BEQ | DARIO-INSTALL 50KVA SEE TEXT | 500340478 | \$ | 4,801.07 |
| 300580139 | BEQ | UG EQUIPMENT -SHEET 1 | 500340702 | \$ | 16,342.82 |
| 300580145 | BEQ | UG PADMOUNT TRANSFORMER | 500371824 | \$ | 9,486.61 |
| 300580194 | BEQ | T-1437,RPL 100kVA,C-PH,Leaking | 500390673 | \$ | 6,425.31 |
| 300580448 | BEQ | (MO) BUD608 Repl. Trf. @ Pad665 | 500381539 | \$ | 25,697.43 |
| 300580483 | BEQ | PAD/TRF #3372 | 500383303 | \$ | 4,715.33 |
| 300580583 | BEQ | Transformer-Install pad #2933 25kva | 500390860 | \$ | 4,726.00 |
| 300581153 | BEQ | MUG - PADMT TRF WORK - CLUBHOUSE | 500362044 | \$ | 10,965.88 |
| 300581237 | BEQ | UG - PADMOUNT TRANSFORMER | 500364633 | \$ | 43,839.29 |
| 300581389 | BEQ | Ph 2: Transformers | 500368574 | \$ | 7,269.36 |
| 300581399 | BEQ | UPGRADE OF 3 PH PDMT XFMR T-324 | 500390657 | \$ | 30,109.81 |
| 300581882 | BEQ | Ins/Rem Pad845- Leaker | 500286490 | \$ | 17,368.49 |
| 300582193 | BEQ | UG XFMR | 500387774 | \$ | 9,473.55 |
| 300582226 | BEQ | straighten Transformer | 500358233 | \$ | 4,702.35 |
| 300582440 | BEQ | PAD#3077 - INS. 25KVA TRANSFORMER | 500389881 | \$ | 3,852.97 |
| 300582586 | BCA | UG XFMR | 500387272 | \$ | 14,215.72 |
| 300582938 | BEQ | GML-500KVA 277/480 PADMNT. TRANS. ORDER | 500387139 | \$ | 14,775.35 |
| 300582939 | BEQ | GML-500KVA 277/480 PADMNT. TRANS. ORDER | 500387139 | \$ | 17,515.78 |
| 300583234 | BEQ | INSTALL/REMOVE PAD#1206VT | 500286490 | \$ | 12,196.74 |
| 300583333 | BEQ | PAD#3532 - INS. 25KVA TRANSFORMER | 500377492 | \$ | 4,012.88 |
| 300583461 | BEQ | NEW PAD/TRF | 500387641 | \$ | 13,497.76 |
| 300583650 | BEQ | UG Equipment | 500386675 | \$ | 12,646.91 |
| 300583765 | BEQ | Install XFMR'S | 500360750 | \$ | 111,946.92 |
| 300583838 | BEQ | PAD#3075 - INS. 50KVA TRANSFORMER | 500377507 | \$ | 4,498.07 |
| 300583863 | BEQ | 300 kva UG padmount | 500286137 | \$ | 9,830.18 |
| 300583885 | BEQ | UG PADMOUNT TRANSFORMER | 500385878 | \$ | 10,472.82 |
| 300584382 | BEQ | PAD#3442 - INS. 500KVA 120/208v XFMR | 500355162 | \$ | 14,735.70 |
| 300584660 | BEQ | INSTALLATION OF NEW T-452 | 500390654 | \$ | 12,113.69 |
| 300585018 | BEQ | UG XFMR | 500388469 | \$ | 4,746.54 |
| 300585235 | BEQ | INSTALL & REMOVE TRANSFORMER -JC | 500388484 | \$ | 4,684.82 |
| 300585353 | BEQ | Replace Transformer T-2725 | 500368625 | \$ | 5,697.30 |
| 300585727 | BEQ | (BT)4 Manhattan Dr. Repl. Trf. Pad#1316 | 500395046 | \$ | 15,343.93 |
| 300586898 | BEQ | INST 1000KVA PADMOUNT | 500341751 | \$ | 21,338.47 |
| 300586998 | BEQ | UG Transformer Replacement Order For T30 | 500368649 | \$ | 4,147.75 |
| 300587309 | BEQ | 120/208-4w 300kva 13kv rdf | 500374210 | \$ | 11,903.95 |
| 300587615 | BEQ | Install 50KVA XFMR | 500353914 | \$ | 3,525.52 |
| 300587823 | BEQ | INST. T-138 277/480V | 500378901 | \$ | 11,002.29 |
| 300587849 | BEQ | Transformers - Phase 1 | 500365675 | \$ | 27,775.88 |
| 300588264 | BEQ | INS (2)50KVA & (1)75KVA - JD | 500134754 | \$ | 17,197.43 |
| 300588357 | BEQ | 500 PAULISON AVE,PC-Pad Xfmr-JK | 500394714 | \$ | 7,055.99 |
| 300588396 | BEQ | ug repl. Pad & Trf. | 500320612 | \$ | 10,735.44 |
| 300588588 | BEQ | INSTALL TEMP XFMR - JC | 500391050 | \$ | 4,340.08 |
| 300588779 | BEQ | install padmount xfmr wade st s. plfld | 500395519 | \$ | 18,308.74 |

| | | | | | |
|-----------|-----|--|-----------|----|-----------|
| 300588781 | BEQ | 1463 FINNEGANS LN - PADMOUNT | 500392783 | \$ | 12,457.81 |
| 300589167 | BEQ | INS PAD 6671 - JK | 500072019 | \$ | 4,624.15 |
| 300589513 | BEQ | UG TRANSFORMER 300KVA | 500390904 | \$ | 13,521.18 |
| 300589846 | BEQ | REPLACE 25KVA WITH 50KVA PDMT TRANSF. | 500398719 | \$ | 4,247.76 |
| 300589944 | BEQ | UG PADMOUNT TRANSFORMER | 500382998 | \$ | 29,116.99 |
| 300590010 | BEQ | Replace Transf.- Eastern Regional HS,VT | 500397877 | \$ | 18,495.27 |
| 300590046 | BEQ | UG-inst padmount transformer | 500389960 | \$ | 12,727.23 |
| 300590430 | BEQ | inst 300kva padmount (pad#470) | 500387548 | \$ | 10,323.53 |
| 300590640 | BEQ | INS. 1500KVA XFMR @ T-2459 277/480V | 500386531 | \$ | 55,765.90 |
| 300590641 | BEQ | INS. 1500KVA XFMR @ T-2460 277/480V | 500386531 | \$ | 3,840.32 |
| 300591189 | BEQ | (EH) 1309 Woodlane / Transformer | 500394823 | \$ | 14,103.00 |
| 300591252 | BEQ | UG PADMOUNT XFMR | 500392136 | \$ | 5,347.31 |
| 300592047 | BEQ | 2 PADMOUNT TRANSFORMERS FOR RIGGER CT | 500390943 | \$ | 5,745.30 |
| 300592177 | BEQ | PAD5935--150KVA 120/208 -JC | 500163110 | \$ | 12,002.93 |
| 300592182 | BEQ | inst 150kva 3-phase padmount | 500354194 | \$ | 8,420.27 |
| 300592244 | BEQ | Inst. 2500kva 277/480V 13kV Padmount | 500394648 | \$ | 47,140.60 |
| 300592716 | BEQ | Install (6) mini pads | 500313138 | \$ | 9,541.91 |
| 300593184 | BEQ | UG Transformer/pads/elbows | 500371770 | \$ | 12,598.75 |
| 300593213 | BEQ | Install 100kva mini pad | 500342880 | \$ | 3,400.90 |
| 300593962 | BEQ | 750KVA-13KV-277/480 PAD6676-JK | 500151033 | \$ | 19,712.47 |
| 300595173 | BEQ | 8 UG Trans.50KVA,1 100KVA | 500356969 | \$ | 41,341.30 |
| 300595796 | BEQ | INSTALL 50KVA & 100KVA PADMOUNT TRANS. | 500365687 | \$ | 39,905.26 |
| 300596340 | BEQ | INS PM TRANSFS - 4--100KVA & 1- 167KVA | 500383157 | \$ | 24,708.69 |
| 300596538 | BEQ | PADMOUNT TRANSFORMER | 500396863 | \$ | 11,364.13 |
| 300596585 | BEQ | 2300 RTE 130 - PDMNT TRANSFORMER | 500396834 | \$ | 12,256.46 |
| 300596600 | BEQ | 277/480 750 KVA PAD CO# 451519 | 500399528 | \$ | 19,418.49 |
| 300596627 | BEQ | 750 KVA 13KV RDF 277/480-4W | 500383431 | \$ | 19,641.69 |
| 300596800 | BEQ | REPLACE UG TRANSFORMER BUD 1100 T-10 | 500403414 | \$ | 5,777.48 |
| 300596830 | BEQ | 66 SICARD ST - PDMNT TRANSFORMER | 500395716 | \$ | 13,643.62 |
| 300596833 | BEQ | SOLAR/140 DOCKS CORNER RD-PDMNT XFRMR | 500400807 | \$ | 62,586.08 |
| 300597084 | BEQ | UG Transformer | 500310370 | \$ | 1,880.93 |
| 300597281 | BEQ | INS PAD # 4024 /WHSE 277/480V 800A MTR | 500400098 | \$ | 12,992.29 |
| 300597509 | BEQ | INS PAD #2935 / NEW SVC-NEW CONST'N | 500401725 | \$ | 4,797.03 |
| 300597522 | BEQ | UG PADMOUNT TRANSFORMER | 500383274 | \$ | 29,150.54 |
| 300598181 | BCA | Stimulus II BUD 238-1 - TERMS, SWITCHING | 500397071 | \$ | 21,498.09 |
| 300598360 | BEQ | INS. 750KVA XFMR @ PAD 2472 277/480V | 500401276 | \$ | 19,588.51 |
| 300598616 | BEQ | INS/RMV T-313 BUD 11 | 500245005 | \$ | 5,479.84 |
| 300598621 | BEQ | REPLACE UG TRANSFORMER, T-736,A-PH | 500403663 | \$ | 4,288.73 |
| 300598879 | BEQ | PAD#4009 - INS. 150KVA 277/480V XFMR | 500397896 | \$ | 9,787.49 |
| 300598888 | BEQ | (MTL) 554 FELLOWSHIP / PAD&TRF. | 500400146 | \$ | 9,911.32 |
| 300599334 | BEQ | DARIO-R-225KVA & I-300KVA SET AT 4KV | 500392664 | \$ | 17,448.89 |
| 300599410 | BEQ | INSTALL XFMR PAD#2620 | 500401372 | \$ | 21,431.38 |
| 300599487 | BEQ | INS. 1000KVA XFMR @ PAD 2473 120/208V 4W | 500358846 | \$ | 22,018.66 |
| 300599518 | BEQ | 441 ELIZABETH AVE - PDMNT XFRMR | 500227310 | \$ | 20,539.76 |
| 300599618 | BEQ | PAD#2632 - REM. 25KVA & INS. 50KVA XFMR | 500403517 | \$ | 8,197.61 |
| 300599732 | BEQ | INS 100KVA LDF PMT PAD#6673-JC | 500393303 | \$ | 13,898.05 |
| 300599909 | BEQ | INSTALL 1PH 75KVA PAD TRANSFORMER | 500385446 | \$ | 6,371.72 |
| 300600064 | BEQ | 1 INDUSTRIAL RD - PDMNT XFRMR | 500374050 | \$ | 32,776.30 |
| 300600121 | BEQ | T-116 QUINCY CIRCLE 100KVA LEAKER RPL | 500405561 | \$ | 5,077.01 |
| 300600365 | BEQ | INS PAD #4026 / UG Svc 3ph 277/480v 800A | 500387631 | \$ | 14,213.98 |
| 300600682 | BEQ | Inst 25kva padmount transformer Pad 3076 | 500360694 | \$ | 5,872.16 |
| 300600779 | BEQ | 484 BUNKER HILL RD - PDMNT XFRMR | 500401752 | \$ | 10,948.99 |
| 300600870 | BEQ | 666 SOMERSET ST - PDMNT XFRMR | 500403098 | \$ | 6,763.44 |
| 300600882 | BEQ | 50 W FERRIS ST - PDMNT XFRMR | 500385225 | \$ | 18,950.38 |
| 300600963 | BEQ | RPL 2 DEF XFORMERS HILLSIDE AVE | 500405561 | \$ | 3,397.77 |

| | | | | |
|-----------|-----|---|-----------|---------------|
| 300600977 | BEQ | INSTALL 6 - PADMNT TRANSF./ 1 PME | 500383160 | \$ 26,827.85 |
| 300601074 | BEQ | REPLACE PADMOUNT TRANSFORMER | 500383031 | \$ 3,451.66 |
| 300601140 | BEQ | BUD 112 - RMV/INS PAD1615--50KVA BPH -JC | 500245005 | \$ 2,037.58 |
| 300601340 | BEQ | (EP) 4225 Rte130 Bottom Dollar /UG XFMR | 500399803 | \$ 11,174.32 |
| 300601401 | BEQ | UG PAD TRANSFORMER (NEW ORDER) | 500382998 | \$ 35,447.41 |
| 300601431 | BEQ | INSTALL T-1472 300KVA PADMOUNT | 500402033 | \$ 11,462.06 |
| 300601578 | BEQ | JK- 410 HOWE AVE. PAD-XFMR | 500397700 | \$ 11,004.72 |
| 300601599 | BEQ | INSTALL PADMOUNT XFMR PD2588 | 500403355 | \$ 13,930.21 |
| 300601716 | BEQ | StimII BUD110G&H - Inst/Rmv Pad116 & 120 | 500367157 | \$ 28,817.10 |
| 300601988 | BEQ | UG TRANSFORMERS & PE WORK (PHASE I) | 500373269 | \$ 27,033.54 |
| 300604241 | BEQ | DURING FUTURE SCHEDULED SHUTDOWN (DUE TO | 500408798 | \$ 11,641.80 |
| 300604363 | BEQ | UG TRANSFORMER | 500391195 | \$ 9,471.76 |
| 300604451 | BEQ | (HP) 1924 Ark Rd / Padmount Trf. | 500380614 | \$ 11,143.91 |
| 300604538 | BEQ | 750kva 13kv 120/208-4w rdf | 500294208 | \$ 26,468.06 |
| 300604583 | BEQ | rmv/ins pad. transf. ethel rd edison | 500405727 | \$ 14,191.69 |
| 300604625 | BEQ | UG PADMOUNT TRANSFORMER WORK | 500394604 | \$ 6,733.72 |
| 300604925 | BEQ | (EH) Lina Lane / Pad & Trf, | 500391152 | \$ 16,046.20 |
| 300604949 | BEQ | INSTALL 300KVA 120/208V 13KV XFMR PDMT | 500400069 | \$ 14,729.96 |
| 300605181 | BEQ | Install (10) Padmounts | 500340601 | \$ 43,979.05 |
| 300605640 | BEQ | REPLACE LEAKING TRANSFORMER FOR MERCK DU | 500409315 | \$ 45,211.15 |
| 300605670 | BEQ | SERVICE TO PAR @ LINDEN GEN | 500398779 | \$ 38,822.77 |
| 300605824 | BEQ | BUD 450---PAD 6682 50 KVA-TS | 500403921 | \$ 4,791.39 |
| 300605945 | BEQ | REPL TRF / Res net meter | 500390924 | \$ 2,587.14 |
| 300606420 | BEQ | INS TRANSFORMERS - WILLINGBORO WALK PHAS | 500276925 | \$ 30,331.65 |
| 300606519 | BEQ | TRANSFORMER WORK | 500406914 | \$ 2,732.12 |
| 300606739 | BEQ | UG TRANSFORMER | 500407277 | \$ 19,294.84 |
| 300606824 | BEQ | + HERITAGE VILLAGE BUD 1884. | 500102189 | \$ 29,439.25 |
| 300606926 | BEQ | UG-Install padmount Transformer | 500385424 | \$ 3,375.69 |
| 300607361 | BEQ | PADMOUNT XFMR | 500200517 | \$ 30,367.82 |
| 300607563 | BEQ | HILLTOP CENROSE--(2) 750KVA 120/208-JC | 500387526 | \$ 47,943.31 |
| 300607767 | BEQ | PADMOUNT TRANSFORMER | 500402430 | \$ 4,092.85 |
| 300607850 | BEQ | INS PAD #4028 / NEW SHOPPING CTR | 500380911 | \$ 9,037.83 |
| 300608282 | BEQ | UG- INSTALL 50KVA PADMOUNT -#2 TRAFF LIG | 500401848 | \$ 2,791.76 |
| 300608403 | BEQ | UG INSTALL 50KVA TRANSF - #3 TRAFF LIGH | 500401850 | \$ 2,791.76 |
| 300608488 | BEQ | (CN) Hoeganas / Padmount Trfs. | 500392635 | \$ 43,464.53 |
| 300608597 | BEQ | XFMR-PAD#3015 BLG C 1500kva | 500310380 | \$ 27,775.70 |
| 300608600 | BEQ | INS TRANSFORMER - PRINCETON MANOR PHASE 3 | 500072541 | \$ 1,081.74 |
| 300608947 | BEQ | (BC) 1004 High St / UG TRF. | 500368868 | \$ 4,843.13 |
| 300608956 | BEQ | (BC) Burl Chevy / Pad & Trf | 500406432 | \$ 10,107.04 |
| 300609175 | BEQ | UG PADMOUNT TRANSFORMERS | 500383858 | \$ 149,819.35 |
| 300609312 | BEQ | INS/REM PAD/TRF'S | 500398750 | \$ 32,721.09 |
| 300609328 | BEQ | TRANSFORMER | 500408797 | \$ 18,280.01 |
| 300609365 | BEQ | REM/INS TRF'S/PADS | 500398750 | \$ 13,899.68 |
| 300609489 | BEQ | REPL 750KVA WITH 1000KVA TRANSFORMER | 500404062 | \$ 20,309.43 |
| 300609512 | BEQ | INST. 500kVA 277/480V PAD | 500413533 | \$ 13,411.81 |
| 300610053 | BEQ | BUD#600--INS 500KVA LDF PMT PAD#6238 - J | 500151210 | \$ 17,420.76 |
| 300610203 | BEQ | UG PADMOUN TRANSFORMERS | 500407247 | \$ 15,411.82 |
| 300612456 | BEQ | bud 602--300kva pads 5927 & 5928-JC | 500163110 | \$ 29,501.48 |
| 300612602 | BEQ | TRANSFORMER | 500404424 | \$ 24,185.48 |
| 300612783 | BEQ | (CN) Rte73 Trans Axle / Pad & Trf. | 500254300 | \$ 18,849.11 |
| 300612792 | BEQ | Stim II BUD 110 D -Pad#54 | 500367157 | \$ 10,346.75 |
| 300612816 | BEQ | TRANSFORMERS | 500408157 | \$ 14,690.19 |
| 300612849 | BEQ | install padmount transformer rte 27 ed. | 500391830 | \$ 15,678.16 |
| 300612927 | BEQ | STIM II BUD 63 Repl xfmr 74 & 80 | 500367224 | \$ 9,120.33 |
| 300612961 | BEQ | Replace (3) mini Pads | 500414779 | \$ 14,897.60 |

| | | | | |
|-----------|-----|--|-----------|--------------|
| 300612981 | BEQ | Replace leaking pad #2403 @ C/O W Grand | 500414411 | \$ 29,127.41 |
| 300614618 | BEQ | Stim II BUD 175 Ins/Rmv Transformers | 500397077 | \$ 9,010.69 |
| 300615055 | BEQ | 120/208-4W 300KVA 13KV RDF | 500403623 | \$ 10,220.64 |
| 300615217 | BEQ | UG Transformer | 500387550 | \$ 3,766.57 |
| 300615334 | BEQ | Repl 500kVA PAD @ GR Countert Club - JC | 500371245 | \$ 20,096.85 |
| 300615485 | BEQ | INSTALL PADMOUNT TRANSFORMERS | 500390927 | \$ 21,247.79 |
| 300615616 | BEQ | INS/REM PAD 41-HT | 500286490 | \$ 24,821.76 |
| 300615655 | BEQ | INS. 500KVA DR XFMR @ T-2401 277/480V | 500414345 | \$ 15,937.95 |
| 300615656 | BEQ | INS. 500KVA DR XFMR @ T-2400 277/480V | 500410828 | \$ 16,384.13 |
| 300615659 | BEQ | INS. 300KVA XFMR @ T-2464 120/208V | 500391687 | \$ 14,039.39 |
| 300615822 | BEQ | PAD 3309 Replace leaking 1500kva transfo | 500337913 | \$ 27,397.80 |
| 300616626 | BEQ | 3940 RTE 1 - PADMOUNT XFRMR | 500407563 | \$ 10,645.52 |
| 300616933 | BEQ | INS TRANSFORMERS, PH 2 | 500382865 | \$ 20,242.25 |
| 300617024 | BEQ | Repl. 750kVA with 1500kVA padmount | 500389680 | \$ 31,103.82 |
| 300617159 | BEQ | (BT) 3 Manhattan / Pad&Transformer | 500391713 | \$ 12,288.54 |
| 300617525 | BEQ | 277/480 500kva 13kv rdf | 500412927 | \$ 12,260.80 |
| 300618208 | BEQ | INSTALL PADMOUNT XFMR PAD#1738 | 500361170 | \$ 39,204.52 |
| 300618213 | BEQ | Stimulus II BUD 335 Xformer Repl | 500365603 | \$ 9,881.57 |
| 300618295 | BEQ | Stimulus II BUD 335 Pad #85 | 500365603 | \$ 5,701.89 |
| 300618419 | BEQ | INSTALL PADMOUNT XFMR PAD#60/RMV MAT#2 | 500414461 | \$ 16,418.02 |
| 300618462 | BEQ | TRANSFORMERS,545,546,547 | 500391613 | \$ 12,163.09 |
| 300619046 | BEQ | Pad 2727 Rusted, Wires Exposed | 500398274 | \$ 2,592.21 |
| 300619277 | BEQ | INS PAD# 3020 /New 120/208 3ph 1600A | 500419646 | \$ 14,060.77 |
| 300619350 | BEQ | Stimulus II BUD 238 LARCHMONT - RPL PADS | 500397071 | \$ 21,943.46 |
| 300620071 | BEQ | UG-3ph PADMOUNT 277/480V | 500402176 | \$ 12,317.02 |
| 300620242 | BEQ | ENCLOSURE#598 & PAD#240 | 500414337 | \$ 10,509.81 |
| 300620274 | BEQ | UG PADMOUNT TRANSFORMERS | 500361041 | \$ 80,937.90 |
| 300620310 | BEQ | install transformers,133,134,135 | 500328029 | \$ 10,866.78 |
| 300620701 | BEQ | 621 RT 18 BDLG-D - PDMNT TRANSFORMER | 500254348 | \$ 9,424.80 |
| 300620835 | BEQ | BUD1167 Greenbriar Xfmrs Repl-PT | 500399910 | \$ 21,012.06 |
| 300620964 | BEQ | UG INS XFMR | 500418215 | \$ 9,444.68 |
| 300621056 | BEQ | XFMR(5)-PH 1A OF WYNGATE IN BUD1939 | 500386613 | \$ 13,162.55 |
| 300621511 | BEQ | SCHINDLER CT TRANSFORMERS | 500115488 | \$ 10,199.48 |
| 300621623 | BEQ | INS PAD # 4030 / NEW ELEC SERVICE | 500417215 | \$ 24,930.90 |
| 300621773 | BEQ | NEW PADMOUNT TRANSFORMER WORK | 500409481 | \$ 13,375.64 |
| 300621805 | BEQ | INS. 750KVA XFMR @ PAD 2331 277/480V 4W | 500381560 | \$ 20,308.60 |
| 300621882 | BEQ | REPLACE LEAKING TRANSFORMER PAD T-774 (2 | 500421158 | \$ 25,701.13 |
| 300621945 | BEQ | 500KVA TRF/PAD | 500238086 | \$ 16,069.21 |
| 300621979 | BEQ | Inst. 75kVA 1ph. pad | 500306447 | \$ 11,115.97 |
| 300622289 | BEQ | install pad. transformer hadley rd ed. | 500418526 | \$ 20,295.22 |
| 300622400 | BEQ | TRANSFORMER - Stimulus II BUD 141 ROLLIN | 500397080 | \$ 5,333.42 |
| 300622993 | BEQ | (HP) 1261 Rte.38 /Inst. Pad & Trf. | 500420059 | \$ 13,489.79 |
| 300622995 | BEQ | 16 PATRICK ST EBW-PDMNT XFRMR | 500418672 | \$ 11,081.35 |
| 300623117 | BEQ | REPLACE ROTTED T-578,A-PH,50KVA,BUD#356 | 500422425 | \$ 4,090.19 |
| 300623120 | BEQ | REPLACE ROTTED T-670,B-PH,50KVA,BUD#356 | 500422425 | \$ 2,511.95 |
| 300623244 | BEQ | REPLACE ROTTED T-702,B-PH,50KVA,BUD#356 | 500422425 | \$ 3,362.94 |
| 300623374 | BEQ | REPLACE LEAKING T-706,13KV,B-PH,50KVA | 500422425 | \$ 2,548.46 |
| 300623912 | BEQ | (EH ST) 1043 OXMEAD / UG TRANSFORMER | 500404164 | \$ 3,974.49 |
| 300623920 | BEQ | INS PAD EQUIP PAD#986 PAD#98 PAD#988 | 500419740 | \$ 12,298.87 |
| 300623925 | BEQ | Stim II BUD141 ROLLING HILLS-REPL PAD#13 | 500397080 | \$ 7,660.04 |
| 300623997 | BEQ | INSTALL PADMOUNT XFMR PAD#63 | 500383091 | \$ 13,703.46 |
| 300624308 | BEQ | JC -INS 167KVA(5953) & 100KVA(5952) | 500163110 | \$ 12,450.30 |
| 300624430 | BEQ | UG PADMOUNTS XFMERS WORK | 500412430 | \$ 44,271.01 |
| 300624618 | BEQ | REPL. XFMR @ PAD 2429 WITH 750KVA 277/48 | 500374889 | \$ 22,684.69 |
| 300624708 | BEQ | 40C COTTERS LN EBW-PDMNT XFRMR | 500420426 | \$ 23,451.75 |

| | | | | | |
|-----------|-----|--|-----------|----|------------|
| 300624943 | BEQ | DARIO-R & I 50KVA TRANS. SET AT 4KV | 500392664 | \$ | 4,245.22 |
| 300624944 | BEQ | DARIO-R & I 50KVA TRANS. SET AT 4KV | 500392664 | \$ | 5,687.28 |
| 300625066 | BEQ | PME/TRANS FOR Ph. 2 | 500365675 | \$ | 34,458.57 |
| 300625249 | BEQ | INS. 300KVA XFMR @ T-2331 277/480V 4W | 500421432 | \$ | 13,773.32 |
| 300625341 | BEQ | Stimulus II BUD 238 - REPLACE PAD 1292 | 500397071 | \$ | 6,052.62 |
| 300625438 | BEQ | (WI) WI High Sch. / UG Transformer | 500420997 | \$ | 34,487.98 |
| 300625563 | BEQ | Inst. 500Kva 13kv 277/480V Padmount | 500421330 | \$ | 18,005.45 |
| 300626470 | BEQ | SEGMENT 1B - 1000KVA 277/480V 4W | 500394651 | \$ | 19,389.66 |
| 300626472 | BEQ | REPLACE Leaking T-1196,100kVA,B-PH | 500422425 | \$ | 4,813.12 |
| 300626478 | BEQ | REPLACE Leaking T-1033,100kVA,B-PH | 500422425 | \$ | 4,726.39 |
| 300626521 | BEQ | 2070 RTE 130 - PDMNT XFRMR | 500392732 | \$ | 9,809.93 |
| 300626805 | BEQ | TRANSFORMER | 500406017 | \$ | 10,257.07 |
| 300626864 | BEQ | INS PAD# 2723 /RETAIL UPGR 120/240V 600A | 500407409 | \$ | 5,003.87 |
| 300627016 | BEQ | TRANSFORMER - 1000 KVA | 500390904 | \$ | 23,533.48 |
| 300627070 | BEQ | TRANSFORMER INSTALLS | 500406842 | \$ | 168,123.92 |
| 300627092 | BEQ | INS PAD # 4037 | 500367717 | \$ | 3,375.82 |
| 300627415 | BEQ | REPLACE LEAKING PD1051, 13KV, 3 PH, 1000 | 500423829 | \$ | 20,860.99 |
| 300627511 | BEQ | INS. 2-1500 KVA 277/480V @ P-#2478 & #2 | 500423554 | \$ | 61,459.98 |
| 300627515 | BEQ | INS. 500 KVA 277/480V 800 amps @ T-2482 | 500402446 | \$ | 14,767.42 |
| 300627608 | BEQ | XFMR - INST -P#466-69 BUD1977 - | 500355303 | \$ | 13,998.58 |
| 300627655 | BEQ | Inst. 1500kVA RDF Padmount | 500421463 | \$ | 27,225.32 |
| 300627812 | BEQ | INSTALL 167KVA T#1255 | 500222278 | \$ | 5,360.60 |
| 300628445 | BEQ | UG-Inst 500kva padmount | 500420245 | \$ | 12,721.46 |
| 300628639 | BEQ | BUD-PADMOUNT TRANS.-EN | 500423298 | \$ | 26,304.88 |
| 300628688 | BEQ | Stim II BUD 238 - RPL PADS 1267 & 1272 | 500397071 | \$ | 7,098.08 |
| 300628698 | BEQ | INSTALL PADMOUNT XFMR PAD73 | 500418232 | \$ | 17,614.43 |
| 300629606 | BEQ | BUD223--PAD1401 75KVA RMV/INS-DP | 500245005 | \$ | 7,167.43 |
| 300629732 | BEQ | INS/RMV PAD 27 SURREY PL-JC | 500245005 | \$ | 8,730.56 |
| 300629805 | BEQ | UG TRANSFORMER | 500406720 | \$ | 12,868.51 |
| 300629998 | BEQ | (LM) Rte38 Bottom Dollar/ Transformer | 500424617 | \$ | 10,181.42 |
| 300630639 | BEQ | BUD238 - CHADBURY CT - RPL TRF'S | 500427553 | \$ | 19,358.84 |
| 300630650 | BEQ | INS. 500KVA XFMR DR @T-2481 277/480V | 500419690 | \$ | 16,504.93 |
| 300630667 | BEQ | 500 kva 120/208 13kv | 500421328 | \$ | 3,567.88 |
| 300630695 | BEQ | Pad mount xfmr - JK | 500423514 | \$ | 47,599.77 |
| 300630782 | BEQ | INSTALL NEW T-537 | 500420084 | \$ | 4,677.09 |
| 300630873 | BEQ | 120/208 500 d/r | 500412928 | \$ | 15,211.10 |
| 300630874 | BEQ | 300 kva 13kv rdf 120/208 | 500424446 | \$ | 13,430.22 |
| 300631297 | BEQ | UG PAD TRANSFORMERS | 500395666 | \$ | 15,235.10 |
| 300631349 | BEQ | 360 DEMOTT LN, FL - PDMNT XFRMR | 500424720 | \$ | 12,978.93 |
| 300631529 | BEQ | WEW8033,BUD325,RMV/INS PAD2671-RV | 500245005 | \$ | 23,183.64 |
| 300631634 | BEQ | UG XFMR | 500426168 | \$ | 10,146.47 |
| 300631964 | BEQ | INSTALL NEW 750KVA PDMT TRANSF. | 500406205 | \$ | 25,531.93 |
| 300631986 | BEQ | XFMR PAD#80 | 500424175 | \$ | 14,375.86 |
| 300632067 | BEQ | INSTALL AND REMOVE 3PH.XFRMR. #3566 | 500420450 | \$ | 5,431.77 |
| 300632326 | BEQ | Stim2 BUD52-Replace Padmounted Xfmr-405 | 500397072 | \$ | 4,279.38 |
| 300632344 | BEQ | BUD TRANSFORMER | 500422451 | \$ | 6,535.36 |
| 300632533 | BEQ | SHUTDOWN--RMV & INST PAD#2491-GRE4006-JK | 500417426 | \$ | 11,640.38 |
| 300632741 | BEQ | + HERITAGE VILLAGE BUD 1884. | 500102189 | \$ | 14,004.80 |
| 300632835 | BEQ | rmv/ins padmount xfmr'r edison | 500409926 | \$ | 13,943.27 |
| 300632847 | BEQ | BUD TRANSFORMER | 500359982 | \$ | 8,958.40 |
| 300633332 | BEQ | INS 50KVA XFMR'S-JC | 500383078 | \$ | 12,457.79 |
| 300633805 | BEQ | TRANSFORMERS | 500072542 | \$ | 16,095.32 |
| 300633896 | BEQ | replace t-2 transformer | 500428264 | \$ | 6,570.07 |
| 300634013 | BEQ | INST PADMOUNT TRANS. | 500260378 | \$ | 7,999.04 |
| 300634108 | BEQ | REPLACE T-4 100KVA DR | 500420107 | \$ | 7,044.73 |

| | | | | | |
|-----------|-----|--|-----------|----|-----------|
| 300634117 | BEQ | Stim II BUD110A Repl Pads PY Harbour | 500367157 | \$ | 14,463.25 |
| 300634244 | BEQ | rmv/ins pad xfrm'r st nicholas ave s.p. | 500418610 | \$ | 22,713.33 |
| 300634314 | BEQ | UG Install 3-ph padmount Transformer | 500412615 | \$ | 12,911.65 |
| 300634373 | BEQ | INSTALL 500kVA 277/480V PAD MOUNT | 500412521 | \$ | 13,067.49 |
| 300634458 | BEQ | Leaker-INS/REM PADMT#212-1656 Kaighns-CM | 500286490 | \$ | 14,296.65 |
| 300635204 | BEQ | REPLACE LEAKING PAD#1569--SAD8042/2-JK | 500417426 | \$ | 36,405.03 |
| 300635218 | BEQ | UG-TRANS.INSTALL/REM.-K | 500428614 | \$ | 49,972.65 |
| 300635226 | BEQ | 1112 CORPORATE RD - PDMNT XFRMR | 500401006 | \$ | 12,648.14 |
| 300635958 | BEQ | REPL 277/480 W/ 120/208 PDMNT XFRMR | 500403098 | \$ | 13,701.15 |
| 300636344 | BEQ | UG XFMR pads and elbos | 500425453 | \$ | 18,614.45 |
| 300636416 | BEQ | TRANSFORMER | 500426110 | \$ | 4,650.72 |
| 300636747 | BEQ | 1600 BERGEN TOWN CNTR RTE 4 EB E/O SPRIN | 500401064 | \$ | 15,552.72 |
| 300636752 | BEQ | 1600 BERGEN TOWN CNTR RTE 4 EB E/O SPRIN | 500401069 | \$ | 14,121.63 |
| 300636830 | BEQ | TRANSFORMER WORK | 500428220 | \$ | 18,159.89 |
| 300636950 | BEQ | UG Transformer replacement for 4kv 1500k | 500431433 | \$ | 40,373.67 |
| 300637528 | BEQ | UG XFMR | 500426205 | \$ | 19,099.36 |
| 300637966 | BEQ | UG Transformer | 500422743 | \$ | 22,714.99 |
| 300638000 | BEQ | TRANSFORMERS - WEST WINDSOR GARDENS BUD | 500228763 | \$ | 17,689.63 |
| 300638232 | BEQ | BUD605--PAD 6257 RAISE SINKING PAD-JC | 500429681 | \$ | 4,790.81 |
| 300638363 | BEQ | Install mini pads | 500207351 | \$ | 39,782.75 |
| 300638725 | BEQ | TRANSFORMER - replacing 4 service upgrad | 500420468 | \$ | 29,227.02 |
| 300638795 | BEQ | XFRMRS INSTALLS | 500419684 | \$ | 26,762.75 |
| 300639190 | BEQ | Install mini pads Phase II | 500207351 | \$ | 49,807.24 |
| 300639191 | BEQ | Install mini padmounts | 500392666 | \$ | 17,974.01 |
| 300639390 | BEQ | replace leaking transformer t-65 | 500433294 | \$ | 3,318.05 |
| 300639460 | BEQ | BUD 554 - REPL T-763 / PME 825 | 500433463 | \$ | 4,159.36 |
| 300639481 | BEQ | JC-BUD160-REPLACE PAD #10-100KVA-JC | 500245005 | \$ | 2,476.25 |
| 300639582 | BEQ | BUD 474 - REPLACE TRANSFORMER | 500433463 | \$ | 2,964.75 |
| 300639588 | BEQ | BUD 329 - REPLACE TRANSFORMER | 500433463 | \$ | 4,938.26 |
| 300639594 | BEQ | BUD 4 - REPLACE TRANSFORMERS | 500433463 | \$ | 28,182.36 |
| 300639600 | BEQ | BUD-24,REPLACE XFRMRS-14,15,16,17 | 500433463 | \$ | 12,087.64 |
| 300639602 | BEQ | BUD-24,REPLACE XFRMRS-19,20,31,32 | 500433463 | \$ | 23,455.57 |
| 300639646 | BEQ | BUD-24,REPLACE XFRMRS-27,28,29,30 | 500433463 | \$ | 21,466.82 |
| 300639647 | BEQ | BUD-24,REPLACE XFRMRS-26 | 500433463 | \$ | 3,399.57 |
| 300639651 | BEQ | BUD-24,REPLACE XFRMRS-21,22,23,24,25 | 500433463 | \$ | 25,063.36 |
| 300639657 | BEQ | BUD-24,REPLACE XFRMRS-33,34,35,36,37,38 | 500433463 | \$ | 24,855.01 |
| 300639664 | BEQ | BUD 68 REPL T-226 & 227 | 500433463 | \$ | 8,663.51 |
| 300639671 | BEQ | BUD 21 - REPL TRANS KUHN ST. | 500433463 | \$ | 10,432.77 |
| 300639858 | BEQ | BUD 5- REPLACE TRANSFORMERS | 500433463 | \$ | 34,062.06 |
| 300639859 | BEQ | BUD 397- TRANSFORMER REPLACEMEN | 500433463 | \$ | 53,717.10 |
| 300639900 | BEQ | INST 500KVA 277/480V RD W 3A PAD#2309 | 500430991 | \$ | 12,920.03 |
| 300639958 | BEQ | INST 750KVA, 120/208V, 13KV ON PAD# 201 | 500409185 | \$ | 19,116.81 |
| 300640074 | BEQ | BUD 21 HADLER DR. REPL. T-13 | 500433463 | \$ | 3,449.12 |
| 300640076 | BEQ | BUD 21 BERGER ST. REPL TRANS | 500433463 | \$ | 8,257.47 |
| 300640078 | BEQ | BUD 21 MAC AFEE RD REPL TRANS | 500433463 | \$ | 15,783.85 |
| 300640081 | BEQ | BUD 21 BOULDER LN REPL TRANS | 500433463 | \$ | 5,538.98 |
| 300640143 | BEQ | BUD 21 MEADE CT REPL T-1 | 500433463 | \$ | 7,289.21 |
| 300640176 | BEQ | BUD 1041, 1042, 1042a - REPL TRANS | 500433463 | \$ | 10,936.30 |
| 300640191 | BEQ | TRANSFORMER | 500432821 | \$ | 7,022.31 |
| 300640224 | BEQ | BUD 1041, 1042, 1042a - REPL TRAN | 500433463 | \$ | 5,997.70 |
| 300640787 | BEQ | BUD - TRANSFORMER | 500395537 | \$ | 13,605.99 |
| 300640869 | BEQ | UG-INSTALL PADMOUNT TRANSFORMER | 500424263 | \$ | 11,138.82 |
| 300641077 | BEQ | rmv/ins pad xfrm'r hadley rd south plfld | 500395786 | \$ | 19,789.54 |
| 300641493 | BEQ | BUD171--REPLACE 25KVA WITH 50KVA-TS | 500245005 | \$ | 20,003.70 |
| 300641621 | BEQ | D.Paris-UG transformer Order & set | 500420298 | \$ | 14,750.56 |

| | | | | | |
|-----------|-----|--|-----------|----|-----------|
| 300641781 | BEQ | TRANSFORMER | 500428667 | \$ | 35,900.87 |
| 300641838 | BEQ | INS & RMV PAD #3555/RELOCATE TRANSFORMER | 500433330 | \$ | 2,748.32 |
| 300642188 | BEQ | 1500 KVA DR 277/480V TRANSFORMER | 500433745 | \$ | 7,642.82 |
| 300642211 | BEQ | XFMR-REPL 50 W -167 KVA BUD 561 | 500423767 | \$ | 4,553.66 |
| 300642214 | BEQ | UG - INSTALL 300kVA LOOPED PADMOUNT | 500428589 | \$ | 11,994.97 |
| 300642291 | BEQ | 750KVA DR 277/480V TRANSFORMER | 500433650 | \$ | 20,648.21 |
| 300642395 | BEQ | xfmr-pri enclosure-switch | 500420981 | \$ | 27,790.19 |
| 300642396 | BEQ | ins transformer | 500420982 | \$ | 23,775.72 |
| 300642398 | BEQ | Bldg. G - Service #3 4000 amps | 500420983 | \$ | 23,118.04 |
| 300642695 | BEQ | D.Paris-UG transformer order | 500434747 | \$ | 24,201.95 |
| 300643111 | BEQ | INS TRF#4033 / SIGN 120/240V 1PH 60A | 500434849 | \$ | 6,107.45 |
| 300643508 | BEQ | MAI8011-1 BUD82 FAULT LOCATE PRIMARY | 500417426 | \$ | 4,008.34 |
| 300643516 | BEQ | UG-Install/Remove Transformer | 500406320 | \$ | 20,420.94 |
| 300643612 | BEQ | INST 750KVA DR, 120/208V 3A PAD 4KV BLG5 | 500412931 | \$ | 23,649.05 |
| 300643616 | BEQ | INST 750KVA DR, 120/208V 3A PAD 4KV BLG4 | 500412932 | \$ | 25,541.67 |
| 300644039 | BEQ | HNC 8021, BUD 186, RMV/INS XFMR-JC | 500245005 | \$ | 7,222.68 |
| 300644291 | BEQ | 1500kVA 13kV 277/480V Padmount | 500414662 | \$ | 32,532.41 |
| 300644293 | BEQ | 300kVA 13kV 120/208V Padmount | 500423126 | \$ | 10,456.56 |
| 300644347 | BEQ | (EH) 1309 Woodlane Rd / Repl Trf | 500394823 | \$ | 16,948.56 |
| 300644442 | BEQ | 300kVA 13kV 120/208V PADMOUNT | 500432057 | \$ | 11,913.07 |
| 300644530 | BEQ | 285 GEORGE ST - PDMNT XFMR | 500049879 | \$ | 40,615.12 |
| 300644665 | BEQ | INS. 300KVA XFMR @ PAD 2465 120/208V 4W | 500418687 | \$ | 12,659.31 |
| 300644678 | BEQ | INS. 1500KVA XFMR @ PAD 2485 277/480V 4W | 500166372 | \$ | 29,658.63 |
| 300644729 | BEQ | INS. 300KVA XFMR @ PAD 2402 120/208V 4W | 500433440 | \$ | 13,254.90 |
| 300644764 | BEQ | BUD82, REPLACE PAD 1658,1671,1660-BW | 500245005 | \$ | 22,802.42 |
| 300645157 | BEQ | ug pad/doghouse | 500430358 | \$ | 5,860.91 |
| 300645171 | BEQ | UG- INST XFMR PAD # 3071 | 500402484 | \$ | 4,437.65 |
| 300645340 | BEQ | UG TRANSFORMER | 500423716 | \$ | 3,886.50 |
| 300645757 | BEQ | UG PADMOUNT TRANSFORMER BLDG.1 | 500381577 | \$ | 18,105.38 |
| 300645857 | BEQ | Inst. 2000kva Pad mount | 500432356 | \$ | 34,639.81 |
| 300646617 | BEQ | UG-BUD-TRANS.INSTALL-NA | 500428613 | \$ | 13,814.15 |
| 300646629 | BEQ | INS. 750 KVA DR. XFMR @ PAD 2486 277/480 | 500430825 | \$ | 21,251.97 |
| 300646720 | BEQ | 2451 RTE 1 NBW - PDMNT XFMR | 500421502 | \$ | 24,852.66 |
| 300646918 | BEQ | INSTALL NEW T-3768 PDMT TRANSF. | 500435840 | \$ | 6,196.61 |
| 300647206 | BEQ | 750 KVA 13KV 277/480 RDF | 500435420 | \$ | 19,506.77 |
| 300647212 | BEQ | RIVER WALK/LENNAR BUD1988- INS XFMR | 500404144 | \$ | 46,591.51 |
| 300647675 | BEQ | TRANSFORMER 50KVA | 500432451 | \$ | 7,000.77 |
| 300647782 | BEQ | RELOCATE TRANSFORMER INS/RMV PAD | 500422933 | \$ | 5,553.40 |
| 300648023 | BEQ | REPLACE PAD#1569--SAD8042/2-RV | 500417426 | \$ | 4,123.43 |
| 300648072 | BEQ | INS TRF PAD # 4035 / 800Amps | 500436050 | \$ | 7,135.55 |
| 300648205 | BEQ | BUD 397 - REPLACE T-1046 | 500433463 | \$ | 1,019.57 |
| 300648331 | BEQ | INS PAD # 4034 100KVA 1PH /Cellsite 600A | 500438977 | \$ | 3,958.94 |
| 300648484 | BEQ | ENBC 1600 QUEEN ANNE RD, TN XFMR ORDER | 500438157 | \$ | 25,874.48 |
| 300648495 | BEQ | INS TRANSFORMER | 500421174 | \$ | 7,755.08 |
| 300648772 | BEQ | Inst. 2 - 1000kVA 13kV 277/480V Pads | 500379957 | \$ | 35,779.72 |
| 300648922 | BEQ | Fairways - BUD TRANSFORMER | 500425685 | \$ | 54,635.02 |
| 300649207 | BEQ | UG-inst padmount transformer & pad | 500426067 | \$ | 3,443.53 |
| 300649257 | BEQ | PH 2 - TRANSFORMER | 500346569 | \$ | 26,535.08 |
| 300649309 | BEQ | 750kVA 13kV 277/480V Padmount | 500395594 | \$ | 23,601.59 |
| 300649484 | BEQ | Install 25 Kva Padmount transformer | 500428005 | \$ | 5,366.23 |
| 300649494 | BEQ | RIVER WALK/LENNAR TRNSFRMRS 25s/75s/100s | 500404144 | \$ | 57,146.77 |
| 300649899 | BEQ | UG TRANSFORMER | 500427959 | \$ | 5,039.22 |
| 300650109 | BEQ | 471 DOREMUS AVE E/O RUTLAND RD GR. INSTA | 500368726 | \$ | 5,006.74 |
| 300650338 | BEQ | PAD#2718 - REM 25KVA & INS 50KVA | 500440752 | \$ | 9,047.38 |
| 300650926 | BEQ | UG PADMOUNT TRANSFORMERS | 500424354 | \$ | 17,925.30 |

| | | | | | |
|-----------|-----|--|-----------|----|-----------|
| 300650928 | BEQ | INST 2 PADMT TRANS | 500423547 | \$ | 7,923.88 |
| 300651080 | BEQ | TRANSFORMER | 500432461 | \$ | 31,225.85 |
| 300651089 | BEQ | Install XFMRs | 500439843 | \$ | 60,620.92 |
| 300651443 | BEQ | UG TO REPLACE LEAKING PAD T-1306 500 KVA | 500441463 | \$ | 20,455.62 |
| 300651793 | BEQ | PADMOUNT TRANSFORMER | 500439994 | \$ | 15,178.04 |
| 300652198 | BEQ | REPLACE T-11 | 500442345 | \$ | 5,975.65 |
| 300652363 | BEQ | 277/480 3 PH 1000 KVA 13KV RDF | 500433446 | \$ | 20,497.05 |
| 300652419 | BEQ | INS TRANSFORMER 500KVA 120/208 | 500385861 | \$ | 20,040.26 |
| 300652420 | BEQ | INS 500 KVA TRANSFORMER | 500385862 | \$ | 16,058.83 |
| 300652593 | BEQ | 3079 RTE 27 FL - PDMNT XFRMR | 500427561 | \$ | 12,344.15 |
| 300652661 | BEQ | INSTALL 300kVA, 120/208V, 3P PAD MOUNTED | 500305484 | \$ | 12,194.46 |
| 300652777 | BEQ | Inst 750kva padmount-PAD# 655 | 500435116 | \$ | 29,241.20 |
| 300652836 | BEQ | UG-Install 500kva padmount-PAD# 656 | 500435117 | \$ | 13,773.32 |
| 300653324 | BEQ | XFMRs 1 Phase BUD | 500425685 | \$ | 74,076.69 |
| 300653354 | BEQ | INS. 500 KVA XFMR. @ PAD 2466 277/480V 3 | 500439093 | \$ | 13,227.68 |
| 300654391 | BEQ | HANDLER ESTATES TRANSFORMERS | 500429714 | \$ | 17,230.39 |
| 300654632 | BEQ | UG PADMOUNT TRANSFORMER BLDG.2 | 500439083 | \$ | 18,796.64 |
| 300654724 | BEQ | UG-INST 2500KVA PADMOUNT PAD# 654 | 500423726 | \$ | 41,902.14 |
| 300654843 | BEQ | 4 PROGRESS RD, SB - PDMNT XFRMR | 500434961 | \$ | 18,245.29 |
| 300655176 | BEQ | UG PADMOUNTS XFMRs WORK | 500254514 | \$ | 60,347.39 |
| 300655216 | BEQ | INSTALL PADMOUNT XFMR PD#72 | 500442824 | \$ | 13,078.01 |
| 300655326 | BEQ | 45 River Rd/Bldg C2-L/EWR/Padmount | 500424611 | \$ | 12,407.46 |
| 300655361 | BEQ | WHITLOCK MILLS INS TRANSFORMERS.. | 500422777 | \$ | 9,406.18 |
| 300655554 | BEQ | INSTALL 15 - -50KVA PDMT TRANSFORMERS | 500443655 | \$ | 41,553.57 |
| 300655926 | BEQ | UG-inst 150kva 277/480v padmount transfo | 500434319 | \$ | 10,415.65 |
| 300656119 | BEQ | ug xfmr | 500440525 | \$ | 30,314.12 |
| 300656269 | BEQ | UG TRANSFORMER | 500392883 | \$ | 13,233.65 |
| 300656330 | BEQ | NDS 400 AMPS UNDERGROUND TRANSFORMER | 500439645 | \$ | 4,183.19 |
| 300656474 | BEQ | Stim. II BUD 95 B - RPL PAD 191 | 500397073 | \$ | 7,037.30 |
| 300656676 | BEQ | BUD 19 - REPLACE T-2 & T-3 | 500433463 | \$ | 7,427.81 |
| 300656677 | BEQ | BUD 19 - REPLACE T-4 | 500433463 | \$ | 3,372.45 |
| 300656679 | BEQ | BUD 19 - REPLACE T-6 | 500433463 | \$ | 3,030.97 |
| 300656714 | BEQ | BUD 6 - REPLACE T-2 | 500433463 | \$ | 6,968.44 |
| 300656715 | BEQ | BUD 6 - REPLACE T-3 | 500433463 | \$ | 3,713.51 |
| 300656716 | BEQ | BUD 6 - REPLACE T-4 & T5 | 500433463 | \$ | 2,719.09 |
| 300656718 | BEQ | BUD 6 - REPLACE T-6 | 500433463 | \$ | 1,359.54 |
| 300656719 | BEQ | BUD 6 - REPLACE T-7 & T8 | 500433463 | \$ | 5,535.56 |
| 300656720 | BEQ | BUD 8 - REPLACE T1 & T2 | 500433463 | \$ | 4,222.30 |
| 300656721 | BEQ | BUD 8 - REPLACE T3, T4, T5, T6, T7 & T8 | 500433463 | \$ | 14,336.64 |
| 300656722 | BEQ | BUD 8 - REPLACE T9 | 500433463 | \$ | 8,681.77 |
| 300656764 | BEQ | BUD 40-REPLACE T-188 | 500433463 | \$ | 5,595.12 |
| 300656766 | BEQ | BUD 36 CIVIC CENTER DR | 500433463 | \$ | 25,713.10 |
| 300656783 | BEQ | BUD 29 - REPLACE T-21 & T-22 | 500433463 | \$ | 9,847.13 |
| 300656784 | BEQ | BUD 29 - REPLACE T-25 & T-26 | 500433463 | \$ | 9,847.23 |
| 300656786 | BEQ | BUD 32 - REPLACE T-110 | 500433463 | \$ | 5,105.83 |
| 300657268 | BEQ | BUD602--INS 2 50KVA LDF PAD#5954 & 5955- | 500163110 | \$ | 7,716.01 |
| 300657637 | BEQ | INS. 750KVA XFMR @ PAD #2409 120/208V 4W | 500435754 | \$ | 20,659.01 |
| 300657774 | BEQ | INST. 1000kVA 277/480V T-1916 | 500402064 | \$ | 21,700.66 |
| 300657854 | BEQ | 45 River Rd/Bldg E2/EWR/Padmount | 500425824 | \$ | 18,887.36 |
| 300657991 | BEQ | BUD 44/45 - REPL. T-11, 8, 80, 7 | 500433463 | \$ | 19,101.35 |
| 300657995 | BEQ | BUD 44/45 - REPL. T-1 | 500433463 | \$ | 2,160.18 |
| 300658007 | BEQ | REPLACE RUSTY TRANSFORMER T-1 & T-2 | 500446638 | \$ | 9,845.53 |
| 300658008 | BEQ | INST. 2500kVA 13kv 277/480V | 500426114 | \$ | 37,442.37 |
| 300658050 | BEQ | T-2407&T-2408,RPL LEAKERS | 500446642 | \$ | 4,944.68 |
| 300658375 | BEQ | 277/480- 500 KVA 13KV RDF | 500442477 | \$ | 16,623.64 |

| | | | | | |
|-----------|-----|--|-----------|----|-----------|
| 300658450 | BEQ | Inst & Rem 1000kVA LPF | 500386652 | \$ | 26,122.41 |
| 300658804 | BEQ | INSTALL PDMT TRANSFORMERS & 2 PMEs | 500406205 | \$ | 10,382.24 |
| 300658818 | BEQ | INSTALL PDMT TRANSF. - DELROCCO CT | 500406205 | \$ | 27,985.37 |
| 300658982 | BCA | REPLACE TRANSFORMER | 500446900 | \$ | 4,566.36 |
| 300659036 | BEQ | BUD 44/45 - REPL T-24, T-25, T-26 | 500433463 | \$ | 5,891.65 |
| 300659039 | BEQ | BUD 44/45-REPL T-13,14,16-18,20,22,23,28 | 500433463 | \$ | 44,545.43 |
| 300659070 | BEQ | INSTALL PME'S & PDMT TRANSFORMERS | 500428056 | \$ | 18,436.44 |
| 300659138 | BEQ | Install XFMR #1056 Crab Shack | 500443058 | \$ | 13,833.13 |
| 300659176 | BEQ | INS. 100KVA TRANSFORMER | 500444727 | \$ | 7,190.48 |
| 300659271 | BEQ | UG TRANSFORMER | 500422861 | \$ | 4,288.99 |
| 300659360 | BEQ | RPL T-2377[BURIED PADMOUNT] | 500446642 | \$ | 8,220.12 |
| 300659375 | BEQ | UG TRANSFORMER WORK | 500442927 | \$ | 15,228.35 |
| 300659407 | BEQ | RPL T-2379[BURIED PADMOUNT] | 500446642 | \$ | 7,116.02 |
| 300659953 | BEQ | PADMOUNT TRANSFORMERS | 500218851 | \$ | 12,536.79 |
| 300660111 | BEQ | BUD 13 #3-4 | 500433463 | \$ | 11,720.05 |
| 300660113 | BEQ | BUD 13 #5-6 | 500433463 | \$ | 1,963.87 |
| 300660114 | BEQ | BUD-13 #212 | 500433463 | \$ | 3,823.76 |
| 300660215 | BEQ | Transformer replacement for 877 North Av | 500448267 | \$ | 40,466.88 |
| 300660409 | BEQ | REPLACE XFMR PD#145 | 500447060 | \$ | 21,970.88 |
| 300660456 | BEQ | INS/RMV XFMR BUD 436-JC | 500245009 | \$ | 11,093.61 |
| 300660481 | BEQ | INSTALL PADMOUNT XFMR PD#1135 | 500441272 | \$ | 15,324.29 |
| 300660736 | BEQ | ug padmount xfmr | 500439729 | \$ | 23,759.51 |
| 300661192 | BEQ | UG TRANSFORMER | 500420419 | \$ | 19,770.65 |
| 300661254 | BEQ | INS. 1500KVA XFMR @ PAD 2488 277/480V 13 | 500446694 | \$ | 22,382.60 |
| 300661452 | BEQ | 750 E MAIN ST, BWT - PDMNT XFRMR | 500438165 | \$ | 12,488.20 |
| 300661986 | BEQ | Temp 1200 amp 277/480 PDMT XFMR | 500444328 | \$ | 23,636.08 |
| 300662379 | BEQ | EQUIP-INS 300KVA 120/208 & 4 POS PE | 500435706 | \$ | 22,206.43 |
| 300662592 | BEQ | UG Transformer - replace leaking transfo | 500286490 | \$ | 5,340.07 |
| 300662945 | BEQ | INSTALL 300KVA 277/480V RD, IIA PAD | 500445784 | \$ | 12,838.17 |
| 300663959 | BEQ | PAD#2877 - INS. 50KVA TRANSFORMER | 500447554 | \$ | 6,534.53 |
| 300665531 | BEQ | GATEWAY BLVD. 50 KVA TRANS | 500420817 | \$ | 16,394.66 |
| 300665535 | BEQ | REED RD. 50 KVA TRANS | 500420817 | \$ | 22,088.60 |
| 300665536 | BEQ | HANKINS RD. 50 KVA TRANS | 500420817 | \$ | 2,387.87 |
| 300665783 | BEQ | INST. 300kVA 120/208V PAD MOUNT | 500424217 | \$ | 16,092.75 |
| 300665949 | BEQ | BUD 29 - REPLACE T-24 | 500433463 | \$ | 1,641.79 |
| 300666166 | BEQ | INS TRANSFORMERS | 500228763 | \$ | 8,813.06 |
| 300666925 | BEQ | bud534--INS 50KVA LDF PMT PAD#6761 - JC | 500313181 | \$ | 5,094.57 |
| 300667398 | BEQ | BUD 19 - REPLACE T-414 | 500433463 | \$ | 5,096.85 |
| 300667603 | BEQ | INS PAD #4036 / NEW HSE 300 AMPS | 500452802 | \$ | 3,570.87 |
| 300667688 | BEQ | INS/REM TRANSFORMER PAD 3976 | 500228763 | \$ | 4,990.54 |
| 300668533 | BEQ | Replace pad 2366 On Grasselli Ln & South | 500453314 | \$ | 50,701.15 |
| 300668630 | BEQ | INSTALL PDMT TRANSF - 14 TULSA CT | 500213603 | \$ | 5,796.80 |
| 300670675 | BEQ | INSTALL TRANSFORMER T-2962 - MURPHY DR | 500319540 | \$ | 5,151.11 |
| 300671024 | BEQ | UG-TRANS/PAD INSTALL-WR | 500452114 | \$ | 16,303.04 |
| 300672485 | BEQ | INSTALL NEW T-550 PDMT TRANSF. | 500451329 | \$ | 4,852.68 |
| 300672553 | BEQ | Ravenswood Padmount transformers work | 500423112 | \$ | 41,218.61 |
| 300672645 | BEQ | BUD602-INS 150KVA LDF PMT PAD#5961 -JC | 500163110 | \$ | 20,498.60 |
| 300672653 | BEQ | BUD602-INS 100KVA LDF PAD#5966 & 5960 -J | 500163110 | \$ | 15,707.07 |
| 300673621 | BEQ | INSTALL 1500KVA 277/480V T-551 | 500458447 | \$ | 32,657.42 |
| 300673653 | BEQ | Install PAD # 2354 | 500447455 | \$ | 2,143.01 |
| 300673784 | BEQ | T-2439 INSTALL | 500427933 | \$ | 5,020.72 |
| 300674009 | BEQ | COR8034, BUD207, PAD1341 INS/RMV-JC | 500245005 | \$ | 6,143.22 |
| 300674603 | BEQ | INS TRF PAD # 3385 / New Hampton Hotel | 500442886 | \$ | 13,260.16 |
| 300674772 | BEQ | PAD#2966 - REM & INS TRANSFORMER | 500453872 | \$ | 25,852.78 |
| 300675001 | BEQ | UG Transformer | 500422780 | \$ | 14,058.01 |

| | | | | | |
|-----------|-----|--|-----------|----|-----------|
| 300675222 | BEQ | UG TRANSFORMERS WORK (PHASE II) | 500373269 | \$ | 18,277.02 |
| 300675391 | BEQ | UG-INST 1500KVA 277/480&PAD | 500420677 | \$ | 23,004.13 |
| 300675639 | BEQ | UG PADMOUNT TRANSFORMER | 500425469 | \$ | 15,148.71 |
| 300676446 | BEQ | Replace Pad 66 @ Weldon Asphalt 2651 Mar | 500463231 | \$ | 14,772.17 |
| 300677603 | BEQ | UG Transformer | 500422778 | \$ | 34,842.15 |
| 300677604 | BEQ | UG Transformer | 500422779 | \$ | 14,058.01 |
| 300677652 | BEQ | GMS-TRANS ORDER 277/480 750 KVA | 500456324 | \$ | 19,153.21 |
| 300678280 | BEQ | 500KVA 277/480-13KV RDF | 500440843 | \$ | 12,827.15 |
| 300678441 | BEQ | D.Paris-Switch&Xfmr order | 500442650 | \$ | 19,306.92 |
| 300679042 | BEQ | PADMOUNT TRANSFORMER WORK | 500453902 | \$ | 10,949.31 |
| 300679280 | BEQ | 10 UNION ST NBK - PDMNT XFMR | 500453362 | \$ | 11,683.59 |
| 300679485 | BEQ | BUD # 13 TRANSFORMER PAD T-210 NEEDS INS | 500465603 | \$ | 6,692.59 |
| 300680455 | BEQ | XMFR PAD#876 | 500429966 | \$ | 7,533.56 |
| 300680485 | BEQ | REMOVE / INSTALL 167kVA T-16 | 500465892 | \$ | 12,417.51 |
| 300680496 | BEQ | TRANSFORMER WORK | 500440944 | \$ | 8,739.09 |
| 300681297 | BEQ | BUD-TRANS.INST.-LH | 500464928 | \$ | 10,217.13 |
| 300681864 | BEQ | INST/REM PAD3619 | 500468529 | \$ | 27,998.17 |
| 300682189 | BEQ | REPLACE 500KVA T-2075D | 500468480 | \$ | 16,679.23 |
| 300682487 | BEQ | UG-INST 500KVA 277/480V 4W PADMOUNT TRAN | 500462817 | \$ | 15,976.03 |
| 300682674 | BEQ | REPLACE T-1004 WITH 50KVA | 500406959 | \$ | 3,583.19 |
| 300682839 | BEQ | UG-INST 300KVA PADMOUNT | 500440654 | \$ | 13,668.91 |
| 300682999 | BEQ | UG XFMR | 500443781 | \$ | 3,539.57 |
| 300683008 | BEQ | REPLACE VADALIZED PADMT TRF PAD#498 | 500468835 | \$ | 4,826.75 |
| 300683266 | BEQ | ug xfmr 511 | 500438051 | \$ | 5,683.58 |
| 300683753 | BEQ | REPLACE 300 KVA 120/208 PAD-STORM DAMAGE | 500462851 | \$ | 19,517.23 |
| 300683875 | BEQ | CHANGE OUT 500 KVA TO 1000 KVA PADMOUNT | 500421328 | \$ | 28,380.29 |
| 300683930 | BEQ | INS XFMR | 500450892 | \$ | 7,402.02 |
| 300683986 | BEQ | REPLACE PDMT T-1185 | 500465715 | \$ | 3,583.19 |
| 300684638 | BEQ | INS TRANSFORMER | 500440716 | \$ | 28,878.89 |
| 300685444 | BEQ | RELOCATE T-3580 | 500166822 | \$ | 3,927.61 |
| 300685488 | BEQ | JC- INS (4)100 KVA PADMOUNT XFMR & (5)50 | 500432146 | \$ | 39,228.70 |
| 300685578 | BEQ | INS. 2000KVA XFMR @ PAD #2490 277/480V | 500462369 | \$ | 33,122.09 |
| 300685600 | BEQ | REPL T-7 & T-1034 100kVA | 500453678 | \$ | 8,344.79 |
| 300686024 | BEQ | UG - Pad&Transformer - SC | 500464293 | \$ | 4,250.87 |
| 300686079 | BEQ | 1500KVA PADMOUNT TRANSFORMER REPLACEMENT | 500466684 | \$ | 39,115.15 |
| 300686264 | BEQ | REPLACE 300 KVA PAD - HURRICAN SANDY | 500471339 | \$ | 16,412.10 |
| 300686549 | BEQ | INS TRANSFORMER | 500228763 | \$ | 15,261.60 |
| 300686916 | BEQ | GMS-750KVA 277/480V PDMNT. TRANS ORDER | 500471211 | \$ | 18,926.66 |
| 300686967 | BEQ | T-496 REPLACE DEF75KVA w/ NEW 100KVA | 500472648 | \$ | 3,039.96 |
| 300687058 | BEQ | UG XFMRs-Ph 1A-Heritage @ MF-BUD 1997 | 500447697 | \$ | 28,410.05 |
| 300687582 | BEQ | BUD602--INS (2)100KVA & (1) 50KVA -JC | 500163110 | \$ | 13,359.10 |
| 300687632 | BEQ | INS TRANSF/EQUIP, PH 1B-1 | 500439955 | \$ | 33,880.61 |
| 300687640 | BEQ | PAD#3067 - REM. 50KVA & INS. 167KVA XFMR | 500472285 | \$ | 3,436.67 |
| 300688188 | BEQ | GMS-TRANS ORDER 277/480 PDMNT - 500 KVA | 500464766 | \$ | 23,653.53 |
| 300689178 | BEQ | 4 MACINTOSH CT, EBW T-258 REPLACEMENT | 500474717 | \$ | 7,111.82 |
| 300689980 | BEQ | TS- replace 1-phase, 120/240v, 50kva pad | 500456503 | \$ | 5,709.20 |
| 300690250 | BEQ | 344 crosspoint leaker replacement | 500474717 | \$ | 8,113.48 |
| 300690304 | BEQ | PADMOUNT TRANSFORMER "BODY SHOP" | 500460671 | \$ | 10,427.95 |
| 300690343 | BEQ | 00-4888, 277/480 500kVA - JK | 500456503 | \$ | 7,407.37 |
| 300690405 | BEQ | replace t-237, t-238 & t-239 | 500474976 | \$ | 27,964.39 |
| 300691389 | BEQ | transformer installs,alerica lane | 500218756 | \$ | 12,904.98 |
| 300691546 | BEQ | INSTALL 2500KVA 13/4KV STEPDOWN | 500476443 | \$ | 7,745.71 |
| 300691799 | BEQ | 500KVA transformer | 500473391 | \$ | 13,170.78 |
| 300692038 | BEQ | UG-INSTALL 300 KVA PADMOUNT TRANSFORMER. | 500419747 | \$ | 10,084.22 |
| 300692090 | BEQ | INS TRANSFORMER | 500440716 | \$ | 4,286.04 |

| | | | | | |
|-----------|-----|---|-----------|----|-----------|
| 300692206 | BEQ | INST TRANSFORMERS | 500352089 | \$ | 13,480.46 |
| 300692980 | BEQ | D.Paris-Xfmr.changeout-defective | 500341771 | \$ | 20,791.47 |
| 300693158 | BEQ | REPLACE T-2155 | 500476878 | \$ | 8,337.32 |
| 300693596 | BEQ | 7 BURLINGTIN LANE RPL 100KVA T-6 | 500474717 | \$ | 5,662.58 |
| 300695124 | BEQ | UG PADMOUNT TRANSFORMER BLDG#46 | 500443025 | \$ | 8,704.87 |
| 300695125 | BEQ | UG PADMOUNT TRANSFORMER BLDG#40 | 500477079 | \$ | 8,704.87 |
| 300695846 | BEQ | INSTALL 100KVA PDMT TRANSFORMER | 500469943 | \$ | 6,540.45 |
| 300696833 | BEQ | WEW8022-2 PAD286 TRANSFORMER | 500456503 | \$ | 23,684.67 |
| 300698062 | BEQ | T-9 50KVA REPLACE 407 CRICKET LN | 500422690 | \$ | 7,603.16 |
| 300698369 | BEQ | D.Paris-Equip Work | 500454422 | \$ | 7,946.13 |
| 300698643 | BEQ | ENBC 989 RIVER RD, EWR BEQ | 500461121 | \$ | 16,640.85 |
| 300699048 | BEQ | T-6 100KVA RPL 967 HOOVER DR | 500474717 | \$ | 3,509.17 |
| 300699050 | BEQ | T-211 50KVA RPL 6 CURRIER RD | 500474717 | \$ | 3,088.27 |
| 300701447 | BEQ | REPLACE T-736 Dainel dr | 500474717 | \$ | 2,140.85 |
| 300702147 | BEQ | MAI 8014, BUD261 PAD1750 INS XFMR -JK | 500245005 | \$ | 2,586.92 |
| 300702237 | BEQ | HNC 8012, BUD146, PAD#153, RMV/INS XFMR | 500245005 | \$ | 1,012.36 |

RESPONSE TO RATE COUNSEL
 REQUEST: RCR-ECON-38
 WITNESS(S): CARDENAS
 PAGE 1 OF 3
 ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
SCADA/MICROPROCESSOR RELAYS

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-18.

- a. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- b. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

a.

| Project # | Name | Total Cost |
|------------------|--|-------------------|
| C.91238 | s0386 Install TMP- Kilmer Substation | \$2,606,405.72 |
| C.91239 | s0386 Install TMP- Meadow Rd Substation | \$1,414,419.36 |
| C.91257 | s0386 Install TMP- Jackson Rd Substation | \$2,698,754.91 |
| C.91258 | s0386 Install TMP- Marlton Substation | \$258,231.37 |
| C.91260 | s0386 Install TMP- Medford Substation | \$2,375,300.88 |
| C.91261 | s0386 Install TMP- MountLaurelSubstation | \$2,598,812.63 |
| C.91262 | s0386 Install TMP- Polhemus Substation | \$1,526,594.20 |
| C.91362 | s0506 Install TMP - Yardville Substation | \$36,028.21 |
| C.99200 | s0386 Install TMP - Bayway 132-1, 2 & 3 | \$68,125.56 |
| C.99201 | s0386 Install TMP-Linden PAR | \$111,768.50 |
| C.99202 | s0386 Install TMP-Clarksville Substation | \$51,967.82 |
| C.99203 | s0386 Install TMP-Greenbrook Substation | \$1,342,868.19 |
| C.99204 | s0386 Install TMP - Hawthorne Sw Station | \$49,291.39 |

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-38
WITNESS(S): CARDENAS
PAGE 2 OF 3
ENERGY STRONG PROGRAM

| Project # | Name | Total Cost |
|------------------|--|-------------------|
| C.99205 | s0386 Install TMP - Hinchmans Substation | \$54,596.56 |
| C.99206 | s0386 Install TMP - Maywood Substation | \$152,844.51 |
| C.99207 | s0386 Install TMP - Sewaren 220-1 | \$38,663.71 |
| C.99208 | s0386 Install - TMP - South Hampton Sub | \$117,254.12 |
| C.99211 | s0433.1 Install TMP - Waldwick 1 PAR | \$28,460.22 |
| C.99212 | s0433.2 Install TMP - Waldwick 2 PAR | \$23,489.27 |

- b. i. 65.45% = \$10,222,694
- ii-iv. See the confidential attachment for total share of contractor expenditures referenced above.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-39
WITNESS(S): CARDENAS
PAGE 1 OF 3
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
INSTALLATION OF A DMS

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-19.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. Costs in the “other” category are related to Outside Vendor Consulting and Implementation Services.
- b. PSE&G has implemented several major systems in the last 10-15 years, including Geographic Information System for the Company’s gas and electric systems, SAP Work Management Module, Computerized Maintenance Management System for substation asset management, Outage Management System, and a new customer information system. Experience related to implementing these systems was used in developing this estimate as well as consultations with outside vendors. The only project implemented in the last 5 years is the Customer Information System. The total cost was \$155.1M.
- c.
 - i. 53.3% - \$82.66
 - ii-iv. See the confidential attachment for total share of contractor expenditures referenced above.

RESPONSE TO RATE COUNSEL
 REQUEST: RCR-ECON-40
 WITNESS(S): CARDENAS
 PAGE 1 OF 3
 ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
IMPROVEMENTS TO COMMUNICATION NETWORK

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-20.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

a. The costs in “other” are related to traffic control

b.

| Customer | LIST_NAME2 | Total |
|-----------------|-------------------------------------|--------------|
| 5004202 | 69kV Bennett's-Rutgers Fiber | \$2,839.20 |
| 5004211 | Bennetts - Lawrence Fiber | \$309,004.83 |
| 5004219 | Runnemede Fiber | \$173,601.44 |
| 5004220 | Runnemede Fiber 2011 tap | \$13,290.20 |
| 5004278 | 69kV Fiber - Bergen Sw - River Rd. | \$319,751.34 |
| 5004284 | Deptford Fiber Transmission Project | \$417,131.89 |
| 5004325 | Fiber - Taps to FAV-TON-POL | \$30,413.57 |
| 5004334 | 69kV Cedar Grove - Hinchman's Fiber | \$461,889.01 |
| 5004369 | 69kV RIR-EAT Fiber | \$548,042.01 |
| 5004375 | Linden-Bayway TLC Project (Fiber) | \$192,556.00 |
| 5004409 | 69kV Bridgewater - DuPont Fiber | \$250,860.87 |

RESPONSE TO RATE COUNSEL
 REQUEST: RCR-ECON-40
 WITNESS(S): CARDENAS
 PAGE 2 OF 3
 ENERGY STRONG PROGRAM

| Customer | LIST_NAME2 | Total |
|-----------------|-------------------------------------|----------------|
| 5004410 | 69kV Lake Nelson - DuPont Fiber | \$91,927.62 |
| 5004476 | 69kV MAD-LAW Fiber | \$119,362.16 |
| 5004477 | 69kV MAD-CAS Fiber | \$458,599.01 |
| 5004524 | Transmission Fiber Fair Lawn Atheni | \$1,150,901.70 |
| 5004540 | 69kV Locust St Fiber 69kV | \$548,971.38 |
| 5004541 | 69kV Locust St Fiber LOC-GLO | \$395,284.34 |
| 5004585 | Transmission Fiber - Newark Grid | \$690,516.37 |
| 5004652 | 69kV Mountain Ave Fiber | \$576,584.69 |
| 5004725 | Montgomery 69kV Fiber | \$158,907.80 |
| 5004760 | H-2208 Fiber Project | \$8,419.67 |
| 5004822 | 69kV Kingsland-Ea. Rutherford Fiber | \$163,275.76 |
| 5004843 | 69kV ENG-TEA Fiber | \$166,486.20 |
| 5004844 | 69kV TEA-BEF Fiber | \$81,079.78 |

- c. i. 1.97% = \$144,076.79
- ii-iv. See the confidential attachment for total share of contractor expenditures referenced above.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-42
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
STORM DAMAGE ASSESSMENT

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-22.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

Please see the Response to RCR-ECON-39.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-43
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
MOBILE PLANT DAMAGE FIELD APPLICATION

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-23.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

Please see the Response to RCR-ECON-39.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-44
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
EXPAND COMMUNICATION CHANNELS FOR CUSTOMERS

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-24.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

Please see the Response to RCR-ECON-39.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-45
WITNESS(S): CARDENAS
PAGE 1 OF 2
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
CONTINGENCY RECONFIGURATION STRATEGIES

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-25.

- a. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- b. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. CIP2 Project ED2-006 SAIFI Improvement Program
Estimated Cost- \$49,659,815
- b.
 - i. 20.9% = \$10,397,152
 - ii.-iv. See the confidential attachment for total share of contractor expenditures referenced above.

RESPONSE TO RATE COUNSEL
REQUEST: RCR-ECON-41
WITNESS(S): CARDENAS
PAGE 1 OF 1
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
SATELLITE COMMUNICATIONS

QUESTION:

For purposes of this request, please refer to response to part (a) of RCR-ECON-21.

- a. Please provide a breakdown of all major costs in the “other” category.
- b. Please provide a list of all “similar type projects” that have been completed over the last 5 years and the estimated cost of these projects.
- c. Please provide a breakdown of costs for each of these projects including the following:
 - i. Please provide the estimated percent of expenditures on these projects that were contracted to outside vendors.
 - ii. Please provide a list of all outside vendors utilized for these projects.
 - iii. Please provide the physical address of each of these companies. If the physical address is not available, please provide just the city and state where the company is located.
 - iv. Please provide the estimated relative share of expenditures that was spent on each of these outside vendors for each project.

Please provide all supporting workpapers and source documents supporting the Company’s response in electronic spreadsheet form with all links and formulas intact, source data used, and explain all assumptions and calculations used. To the extent that data requested is not available in the form requested, please provide the information in the form that most closely matches what has been requested.

ANSWER:

- a. “Other” costs are related to Outside Vendor Consulting and Implementation Services
- b&c. PSE&G has experience with many communication technologies for relaying, station telecommunications and pole mounted solar panels and therefore has technical background related to communications infrastructure. The company has not implemented a communications system pilot in the last five years but leveraged this expertise in developing estimates for this program.

RESPONSE TO STAFF
REQUEST: S-PSEG-ES-2
WITNESS(S): CARDENAS
PAGE 1 OF 5
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
RANKING OF ELECTRIC SUB-PROGRAMS

QUESTION:

Regarding the Electric Delivery Infrastructure Hardening Investments proposed under Energy Strong, list the subprograms in order of benefit and impact to storm mitigation. Quantify these rankings based on cost/benefit ratio, outage decrease, and outage duration decrease.

ANSWER:

The attached chart shows the associated rankings of the Electric Delivery Infrastructure Hardening Investments. The rankings are based on estimates of the number of customers benefiting from the program, the hours of outages avoided and the hours of outages reduced due to the proposal.

The benefits to the customer were evaluated looking at each investment in isolation. The benefits of the different programs are not necessarily additive.

Customer benefits were approximated using the value of lost load (VOLL) metric as described below:

A primary benefit associated with reduced levels of power outages is accrued by customers and can be measured by the value that they place on avoiding the loss of electric service. Specifically, the loss of power causes disruptions as well as the incurrence of costs and/or the loss of revenues; customers place a value on avoiding a loss of power and thus avoid disruptions, costs and/or lost revenues. The notion of such a VOLL, has been studied by economists and engineers and used in regulatory and policy proceedings. A current and widely accepted VOLL analysis was conducted by the Lawrence Berkeley National Laboratory (Berkeley).¹ The Interruption Cost Estimate Calculator web site that is funded by the U.S. Department of Energy² (DOE) utilizes this study as its basis for calculations.

The Berkeley/DOE study provides an indication of the VOLL by class of customer (i.e., residential, commercial and industrial) by time of year and day (as well as for an average day)

¹ Sullivan, M., Mercurio, M., and Schellenberg, J. (2009) Estimated Value of Service Reliability for Electric Utility Customers in the United States. Lawrence Berkeley National Laboratory available at: <http://certs.lbl.gov/pdf/lbnl-2132e.pdf>.

² ICECalculator.com: "The Interruption Cost Estimate (ICE) Calculator is a tool designed for electric reliability planners at utilities, government organizations or other entities that are interested in estimating interruption costs and/or the benefits associated with reliability improvements."

and for various durations of outages (from momentary outage through outages lasting eight hours).³ The VOLLs by customer class for an outage of eight hour duration is shown below.

Table 1
Estimated Value of Lost Load For an Outage of Eight Hour Duration By Customer Class
(2008 \$ Per Un-served kwh)

| | |
|---------------------------------|---------|
| Medium and Large C&I | \$10.6 |
| Small C&I | \$296.1 |
| Residential | \$0.9 |

PSE&G’s proposed Energy Strong investments concern hardening assets and adding resiliency into its electric system in order to mitigate prolonged outages (i.e., longer than eight hours in duration). The Company used the VOLL estimates included in the Berkeley/DOE study for durations of eight hours to calculate the value of lost load associated with each of the proposed investment programs, because it represents the VOLL for the longest power outage duration available. (To our knowledge, based on research concerning VOLL studies, VOLL estimates are not available for outage durations of greater than eight hours.) This is a conservative approach because it is likely that the VOLL for longer outage events (say, outages of 48 hours or more) will be higher than VOLLs for outages of shorter durations; prolonged outages result in major disruptions and costs to all customer classes and lost revenues and productivity to business customers.

The calculation of VOLL benefits that are accrued to customers is based on four steps. First, we estimate the hours of avoided and reduced outages. The assumptions underlying the estimate of hours of avoided and reduced outages are included in Table 2. Second, we allocate the hours to customer classes. All customer classes are impacted by many of the proposed Energy Strong programs, so the hours are allocated to customer classes based on PSE&G average mix of customers in 2012 (i.e., roughly 87% to residential customers, roughly 13% to small commercial and industrial customers, and less than 0.5% to large commercial and industrial customers).⁴ Third, we estimate the number of unserved kWhs for each customer class by considering the hours (above), the average load demand (kW) for each customer class and the average load factor for each customer class.⁵ Fourth, we multiply the total hours of customer interruptions avoided by the per unserved kWh VOLL for each customer class.⁶ The values of lost loads for

³ The Berkeley study used research and results from 28 customer value of service reliability studies conducted by 10 major US electric utilities over the 16 year period from 1989 to 2005. The 28 studies considered used very similar methods (i.e., interruption cost estimation or willingness-to-pay/accept) to estimate VOLL. These results were integrated into a “meta-database” which was then used in two-part regression model that estimated VOLL. Specifically, the study provides estimates of the VOLL and for various durations of interruptions. VOLL is calculated on an event basis; that is, the various customer estimates of cost or willingness to pay are expressed in terms of events (i.e., outages) of various durations. The study also converts these VOLLs into per kW, per unserved kWh and per annual kWh terms.

⁴ Based on PSE&G’s 2012 FERC Form 1.

⁵ Based on data used in rate proceedings.

⁶ To be consistent (with cost dollars), we escalated the VOLL estimates, which are in 2008, by the GDP deflator in order to reflect 2012 dollars.

RESPONSE TO STAFF
REQUEST: S-PSEG-ES-2
WITNESS(S): CARDENAS
PAGE 3 OF 5
ENERGY STRONG PROGRAM

each customer class are then summed to provide the VOLL for each Energy Strong program segment are included in Table 3. The cost/benefit ratio for each Hardening Investment subprogram is calculated as the total estimated cost for the subprogram divided by its respective VOLL, and the results are shown in Table 3. A cost-benefit ratio less than one indicates that the benefits of the investment from one major storm event is greater than the cost for the subprogram.

Looking at the individual programs, the majority of the projects are cost-beneficial based on a single major event (cost/benefit ratio below 1.0). The analysis was done to demonstrate the value of each investment for a single major storm event, but in practice these investments will help in storm events of any magnitude. By hardening the overall system, the value of each program will increase with each additional storm event by reducing future outages and/or limiting the damage experienced. The pole related investments that do not meet the standard of payback in a single event should not be viewed as non-beneficial, but rather having less relative value to the other projects. Pole damage is typically the most resource and time consuming aspect of restoration activities, particularly when it occurs in backyard services. While difficult to quantify in terms of a major storm event, limiting pole damage will free up resources to concentrate on other restoration work.

| TABLE 2 | | | | | |
|---|---|--|--|---|---|
| Program | Description | Actions | Assumptions in quantifying customers impacted by either elimination of outage or decrease in outage duration | Assumption in quantifying outages that are eliminated Outage duration is 3 days unless noted | Assumptions in quantifying outages that are reduced in duration |
| 1. Station Flood Mitigation | This program will target appropriate stations for raising infrastructure, building flood walls and revising standards based on new FEMA flood guidelines | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | Number of customers supplied either directly or indirectly by the Stations to be protected assuming each station will be impacted once | * 33% reduction in 5-day customer outages | With station supply in, duration on average reduced by 1 day |
| 2. Outside Plant Higher Design and Construction Standards | This program will involve improvements to design standards to strengthen construction | Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) | 5% of Customers supplied by 4kV | 20% Reduction of Outages | Due to reduced damage, restoration work will be decreased by 7.2 hours(10% of 3 days) for Customers out of service |
| | | Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) | 5% of Customers supplied by 26/4kV substations | 50% Reduction due to raised conductors. | Due to reduced damage, restoration work will be decreased by 7.2 hours(10% of 3 days) for Customers out of service |
| | | Add spacer cable to eliminate open wire to targeted areas | Assume 10 circuits. Average customers/13kV section = 735 Customers/section x 10 circuits | 40% Reduction due to increased ability to withstand weather events | N/A |
| 3. Strengthening Pole Infrastructure | This program will involve accelerated pole replacements, additional construction hardening, including reduced pole span lengths, and increased pole diameters | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards | # of poles impacted/total poles in system * customers | 2% Reduction in the number of Outages Due to Poles replaced. Value low due to low coincidence of possible damage with replaced poles. | N/A |
| | This program will evaluate the use of new non-wood material to replace wood poles in the future. | Non-wood poles | # of poles impacted/total poles in system * customers | 2% Reduction due to Poles replaced. Value low due to low coincidence of possible damage with replaced poles. | N/A |
| 4. Rebuild/Relocate Backyard poles | This program will consider the relocation and rebuilding of backyard pole lines to front lot and/or UG configuration | Rebuild backyard poles (including tree trimming) | Customers supplied by backyard circuits | 50% Reduction | Due to better access and newer facilities restoration work will be decreased by 7.2 hours(10% of 3 days) for Customers out of service |
| 5. Undergrounding | This program will consider the conversion of OH to UG in selected areas and the replacement of PM equipment with a submersible equivalent in targeted areas | A. Convert certain OH areas to UG | Estimate # circuits that could be done to get customer count. Assume 1 mile per circuit, 20 Circuits with average of 735 customers/section | Assume 60% reduction due to damage being avoided on primary lines now Underground. | N/A |
| | | B. Replace PM xfms with submersible xfms in target areas | Avg Customers per padmounted transformers in flood area | Assume 90% reduction in PSE&G equipment outages due to storm surge. Outage duration of 3 days avoided. | N/A |
| | | C. Replace ATS switches/transformers with submersible switches | Customer benefit aligned with PM Transformer program as ATS typically supply PM in these areas | Combined with SB | Combined with SB |
| 6. Relocate ESOC/GSOC/DERC/SR | This program will relocate our critical Electrical & Gas dispatch operating centers to a higher level within the existing building, making it less susceptible flooding, etc. | Relocate critical operating centers | Total number of Customers | N/A | Duration on average reduced by 6 hours. Very low probability event. Assume 1% probability in a major event. |

TABLE 3

| Program | Actions | Total Estimated Costs (\$ Million) | Number of Customers affected | Avoided Outages (Hrs) | Outage Duration Decrease (Hrs) | Total Customer Outage Reduction (Hrs) | Value (to customers) of Lost Load (\$ Million) | Cost/Benefit Ratio | Rank Based on Cost/Benefit Ratio |
|---|--|------------------------------------|------------------------------|-----------------------|--------------------------------|---------------------------------------|--|--------------------|----------------------------------|
| 1. Station Flood Mitigation | Review and identify stations in newly defined FEMA/NJ DEP flood elevations and develop mitigation plans where appropriate. This will include raising/rebuilding infrastructure and installing flood walls. | \$ 1,678 | 748,500 | 29,640,600 | 11,856,240 | 41,496,840 | \$ 15,750.42 | 0.11 | 1 |
| 2. Outside Plant Higher Design and Construction Standards | Change existing 4kV OP distribution to 13kV standards (this represents 5% of the 4kV infrastructure) | \$ 65 | 30,449 | 438,471 | 175,388 | 613,859 | \$ 232.99 | 0.18 | 2 |
| | Change existing 26kV to 69kV standards while still operating at 26kV (this represents 5% of the 26kV infrastructure) | \$ 60 | 29,873 | 1,075,437 | 107,544 | 1,182,981 | \$ 449.01 | | |
| | Add spacer cable to eliminate open wire to targeted areas | \$ 10 | 7,350 | 211,680 | 0 | 211,680 | \$ 80.34 | | |
| 3. Strengthening Pole Infrastructure | Accelerate pole replacements including increased pole diameters and reduced span lengths where appropriate. Enhanced storm guying standards | \$ 102 | 50,634 | 72,913 | 0 | 72,913 | \$ 27.67 | 3.69 | 5 |
| | Non-wood poles | \$ 3 | 1,407 | 2,025 | 0 | 2,025 | \$ 0.77 | | |
| 4. Rebuild/Relocate Backyard poles | Rebuild backyard poles (including tree trimming) | \$ 100 | 36,973 | 1,331,028 | 133,103 | 1,464,131 | \$ 1.15 | 87.10 | 6 |
| 5. Undergrounding | A. Convert certain OH areas to UG | \$ 60 | 14,700 | 635,040 | 0 | 635,040 | \$ 241.03 | 0.26 | 3 |
| | B. Replace PM xfmr's with submersible xfmr's in target areas | \$ 8 | 1,894 | 122,731 | 0 | 122,731 | \$ 46.58 | | |
| | C. Replace ATS switches/transformers with submersible switches | \$ 8 | Combined with 5B | Combined with 5B | Combined with 5B | Combined with 5B | \$ - | | |
| 6. Relocate ESOC/GSOC/DERC/SR | Relocate critical operating centers | \$ 15 | 2,250,511 | 0 | 135,031 | 135,031 | \$ 51.25 | 0.29 | 4 |

RESPONSE TO STAFF
REQUEST: S-PSEG-ES-5
WITNESS(S): CARDENAS
PAGE 1 OF 2
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PSE&G CAPITAL EXPENDITURE COMMITMENT

QUESTION:

If PSE&G is granted all or a portion of the funding requested in the Petition, what commitment will PSE&G make to capital expenditures, outside of this program, over the next ten (10) years?

ANSWER:

While the Company does not have any commitments to capital spending other than electric distribution for 2013, the attached confidential table shows the Company's expected electric and gas distribution capital spending over the next five years. Note: The table shows a "Total Net of NB" (New Business) since New Business spending is out of the Company's control.

Distribution of the attached table is limited to those parties that receive material designated as confidential in this docket.

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
STRENGTHENING POLE INFRASTRUCTURE

QUESTION:

Referencing Paragraphs 37-43, with respect to Subprogram 3, Strengthening Pole Infrastructure, please explain how the proposed mitigation efforts exceed the normal operations and maintenance efforts associated with the provision of safe, reliable, and adequate utility service, including but not limited to:

- a. A detailed explanation of the normal pole inspection and replacement program currently conducted by PSE&G;
- b. A detailed explanation of how the proposed mitigation measures exceed the normal pole inspection and replacement programs;
- c. A detailed analysis providing empirical evidence indicating how the enhanced pole infrastructure programs are likely to mitigate against the need for future recovery efforts; and
- d. A detailed study comparing the number of poles replaced after Hurricane Irene to the number of poles replaced after Superstorm Sandy, including a discussion of how many poles replaced after Hurricane Irene were subsequently destroyed by Superstorm Sandy, and evidence that mitigation efforts would reduce the reoccurrence of pole damage from a subsequent Major Storm Event.

ANSWER:

New Jersey is located within the heavy loading zone as defined by Section 250 of the North America by the National Electric Safety Code (NESC). The PSE&G overhead electric distribution system is constructed as compliance requires. Span lengths are dictated by field conditions and when possible they will be reduced to provide an overall system hardening. It is recognized that spans leading up to the dead end of a pole line or a junction are the most critical and will be addressed as the highest priority. Although NESC compliant, additional high stress points on the overhead distribution system will be reinforced with additional guying and anchoring to reduce the occurrence of cascading pole failures. Composite poles will be installed on pole lines serving critical customers to absorb the energy from wind loads and reduce cascading pole failures. They will also be evaluated as a replacement to wooden poles for installation during a storm restoration event.

- a. PSE&G inspects wood poles on a 10 year cycle. Poles are inspected for groundline decay and visual defects, and chemical preservatives and inspect treatments are applied as needed. Based upon the remaining circumference and pole strength, steel re-enforcement trusses are added to restore pole strength as appropriate. If excessive decay is present, or if other defects deem it appropriate, the pole is scheduled for replacement. PSE&G coordinates inspection and treatment of joint poles with Verizon.

RESPONSE TO STAFF
REQUEST: S-PSEG-ES-9
WITNESS(S): CARDENAS
PAGE 2 OF 2
ENERGY STRONG PROGRAM

- b. Based upon the remaining strength, the enhanced program will replace all identified poles and not use typical reinforcement methods such as pole trusses. New poles are better able to withstand wind load because of their consistent structure and are more resilient to storm failure.
- c. PSE&G's storm recovery efforts are dependent upon many factors including access to damage areas. During the period between 10/29/12 and 11/16/12 (Superstorm Sandy) there were 1,115 blocked road conditions, as reported by customers. Experience has shown that this is typical during any major storm restoration effort. Roads are blocked mainly by fallen trees, but also by flooding and downed utility poles/wires. Improving the overhead electric support structures and guying will allow these facilities to support smaller trees and limbs rather than failing resulting in faster recovery efforts due to fewer downed poles/wires and better road access to damage areas.
- d. During the August 2011 (Irene) storm restoration effort, PSE&G replaced 599 poles in the service territory. During the October / November 2012 (Sandy) restoration effort, PSE&G replaced 2,500 poles. A concise pole by pole comparison is not available, however since the two storms had different location impacts, it is not likely that the damage had any location duplications. Sandy had more than double the customer outages and caused more than four times as many pole problems. PSE&G anticipates that the pole hardening efforts proposed under the Energy Strong Program (pole replacement, guying, and composite poles) will reduce the reoccurrence of pole damage in future major storms.

REDACTED PUBLIC VERSION

RESPONSE TO STAFF
REQUEST: S-PSEG-ES-14
WITNESS(S): CARDENAS
PAGE 1 OF 233
ENERGY STRONG PROGRAM

PUBLIC SERVICE ELECTRIC AND GAS COMPANY PSE&G'S FLOOD MITIGATION STUDY

QUESTION:

Please provide a copy of the PSE&G's flood mitigation study cited in Paragraph 17.

ANSWER:

See attachment documents:

- Preliminary Substation Flood Impact Report
- Flood Impact Study For New Milford Switching Station
- Flood Impact Study For Cranford Substation
- Flood Impact Study For Hillsdale Substation
- Flood Impact Study For River Edge Substation
- Flood Impact Study For Rahway Substation
- Flood Impact Study For Somerville Substation
- Flood Impact Study For Jackson Road Substation
- Flood Impact Study For Marion Switching Station
- Flood Impact Study For Ewing Substation
- Flood Impact Study For Belmont Substation
- Substation Flood Protection - Summary Evaluation Report

PRELIMINARY SUBSTATION FLOOD IMPACT REPORT

Public Service Electric & Gas

31 OCTOBER 2012



Table of Contents

| | | |
|------------|---|----------|
| 1.0 | Executive Summary | 1 |
| 2.0 | Summary of Flood Impact Studies..... | 5 |
| 2.1 | Substation Flood Protection Report (March 2, 2012)..... | 5 |
| 2.2 | Selected Sites for Flood Impact Studies | 7 |
| 2.3 | Water Surface Profile Models..... | 7 |
| 2.4 | Flood Impact Study Results..... | 8 |
| 2.5 | Implementation Considerations | 8 |

List of Tables

| | | |
|----------|--|---|
| Table 1. | Summary of Flood Impacts | 3 |
| Table 2. | Summary of Substation Flood Protection Requirements..... | 6 |

List of Appendices

| | |
|--|---|
| Appendix A - Individual Flood Studies 1..... | 9 |
|--|---|

1.0 Executive Summary

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing substantial impact to some electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. As a result of Hurricane Irene, as well as prior flooding events, Black & Veatch was engaged to prepare a "Substation Flood Protection Report" for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, March 2, 2012). The Substation Flood Protection Report presents the results of evaluations that were performed to determine the maximum observed flood water elevations and flood depths at each site and provides preliminary recommendations for providing appropriate flood protection measures.

Flood protection measures that were considered consisted of earthen berms, sheetpile barriers and concrete floodwalls. In general, earthen berms were selected for flood protection when sufficient space existed at the substation site as this is the lowest cost alternative, and sheetpile barriers were selected for use at sites where sufficient space does not exist for use of berms. Due to high cost, concrete floodwalls were not selected for any of the sites. Based on the preliminary evaluations, the total estimated cost for providing the recommended flood protection at all sites is \$10,115,000 in 2012 dollars. The estimated cost at each site varies considerably based on the height of flood protection required and the perimeter length of the protected area.

It is recognized that the magnitude of potential upstream flood impacts, in terms of increased water surface elevations upstream of the sites resulting from implementation of the recommended flood protection measures, will be an important factor during project permitting. In order to determine the potential for upstream flood impacts, Black & Veatch was engaged to perform detailed Flood Impact Studies for ten of the twelve substation sites. Flood impact studies are unnecessary for Bayway, where the site is not in the floodplain and is located behind the City of Elizabeth Levee, or for Garfield where any improvements would be performed within the existing perimeter wall of the site.

The ten stations that were studied further in this Flood Impact Study are listed below.

Central Division

Cranford Substation
Rahway Substation
Somerville Substation

Metro Division

Belmont Substation
Jackson Road Substation

Palisades Division

New Milford Switching Station
River Edge Substation
Hillsdale Substation
Marion Switching Station

Southern Division

Ewing Substation

In general, the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S. Army Corps of Engineers Hydraulic Engineering Center, was used to develop a hydraulic model for the river or stream adjacent to each substation site. The HEC-RAS program is the accepted state of the practice software by regulatory agencies. Updated, site specific topographic survey data provided by PSE&G was used in augmenting the existing NJDEP and FEMA flood modeling data for each of the substation sites and for development of the flood impact computer models. Models and data used by FEMA and the NJDEP to establish the existing flood mapping in the region were used as the baseline for the updated HEC-RAS hydraulic models.

Black & Veatch provided Technical Memoranda presenting the results of the detailed flood impact studies at each substation site to PSE&G as the individual studies were completed. These memoranda provide comprehensive summaries of the studies at each site and are included in the Appendix to this report.

The results of the flood impact studies are summarized in the Table 1. Five of the ten substations have been characterized as having upstream impacts resulting from construction of the flood protection measures. Two of the sites, Cranford and Ewing, would have very small increases in upstream water surface elevation. However, NJDEP regulations state that “no” water surface elevation increase can result from new flood protection construction. The level of accuracy that the NJDEP will apply to model results will need to be clarified. B&V has followed state of the practice methodologies and reported water surface elevations to one-hundredth of a foot accuracy.

The Preliminary Flood Protection Report estimated site locations using large scale FEMA flood mapping. The recent, detailed site surveys have shown that only one station is located within a floodway. The floodway is considered the extended channel of higher velocity flows during a flood event, and also incurs a higher degree of scrutiny and permitting restrictions. The only station located in the floodway is Ewing, but additional modeling shows no impact under that criteria. There have been no changes to the NJDEP Riparian buffer requirements.

TABLE 1. FLOOD PROTECTION SUMMARY

| Site | Max WSEL Impact Upstream (ft) | Upstream Impact Distance (ft) | Wall Height (ft) | Permitting Considerations | NJDEP Riparian Buffer Impact | Site Specific Considerations | Cost |
|-------------|-------------------------------|-------------------------------|------------------|---------------------------------------|-----------------------------------|--|-------------|
| New Milford | n/a | n/a | 4.0 | Standard | Yes | n/a | \$1,900,000 |
| Cranford | 0.03 | 2600 | 4.7 | Updated model approval from NJDEP | Yes | n/a | \$525,000 |
| Hillsdale | 0.27 | 1000 | 4.0 | Upstream Impacts | Yes | n/a | \$1,525,000 |
| River Edge | n/a | n/a | 2.5 | Standard | Yes | n/a | \$450,000 |
| Rahway | 1.0 | 3000 | 4.3 | Updated model approval from NJDEP | Yes | Flood level lower than existing mapping | \$730,000 |
| Somerville | n/a | n/a | 4.0 | Updated model approval from NJDEP | No | n/a | \$750,000 |
| Jackson Rd. | 0.21 | 400 | 2.2 | Upstream Impacts | Yes | Includes site expansion | \$1,170,000 |
| Marion | n/a | n/a | 3.9 | Standard | Hackensack Meadowlands Commission | Re-Assess Surge Analysis and wall height | \$1,715,000 |
| Ewing | 0.05 | 1180 | 4.7 | Floodway Approval from NJDEP | No | Located in Floodway | \$570,000 |
| Belmont | n/a | n/a | 9.0 | Standard | Yes | Deep flooding | \$320,000 |
| Bayway | n/a | n/a | 3.0 | Verify City of Elizabeth Levee status | Yes | n/a | \$310,000 |
| Garfield | n/a | n/a | n/a | Standard | n/a | Rehabilitation of existing flood wall | \$150,000 |

Notes:

1. All sites except Belmont will utilize sheetpile wall flood protection as cited in B&V Preliminary Substation Protection Report, March 2, 2012.
2. Ewing Substation is located within the floodway, which could require more rigorous permitting activities.
3. Upstream Impact Distance indicates where the Water Surface Elevation (WSEL) returns to existing conditions.
4. Wall heights are one foot higher than the maximum observed storm or NJDEP Flood Hazard Limit, whichever is greater.
5. Belmont cost will need to be revised to reflect new flood wall type.

Jackson Road and Hillsdale will have increases of approximately 2.5 to 3.5 inches directly upstream. There will likely be more detailed permitting discussion required with the NJDEP regarding these substations, to address the small increase in water surface elevation.

The Rahway analysis results in an increased water surface elevation of 1 foot for several thousand feet upstream of the site. This result, however, has only been realized through the updated modeling performed by Black & Veatch that takes into account a small length of the channelized Rahway River. The increase that we have calculated lies within the established NJDEP Flood Hazard Limits, which were developed in a more conservative (“worst case”) model. So while there is an estimated increase from construction of the recommended flood protection measures using the new model, the resulting flood level is actually a foot less than what is presented in the current flood mapping the NJDEP and FEMA for this area.

During the permitting process, discussion and collaboration with the NJDEP and FEMA regarding the sites would be appropriate where the Black & Veatch model has changed the flood elevation results. In all cases where there are elevation changes due to revised modeling, we believe that the Black & Veatch models more accurately depict the actual site conditions. The regulating agencies will, however, need to recognize and accept the updated model results.

This Flood Impact Study addresses the potential for upstream flood impacts that would result from construction of the recommended flood protection scheme at each site. It is intended that the results of this study will be used by PSE&G in evaluating the implementation of the flood protection measures at each site, and will support the eventual permitting process. It is recognized that review and supplemental input to the flood studies will likely be required to support the permitting process moving forward since the majority of the sites are located within the NJDEP Flood Hazard Limit.

Subsequent activities associated with implementation of the flood protection measures at one or more sites would include permitting, site subsurface investigations, engineering design, and construction. These activities could be conducted for all substation sites together, or could be conducted over a period of time to provide for a phased implementation of the flood protection measures at selected sites.

It is noted that other approaches to providing the desired level of flood protection may be considered during subsequent evaluations. These alternate approaches may include, but are not limited to, strategic substation relocations or protection of only the critical portions and components of the substation site such as the control building. A risk analysis has not been performed as part of this study, and should be considered for subsequent evaluations if needed to support PSE&G’s business case for the flood protection measures to be implemented. The flood protection measures considered in this study have been developed to a conceptual level of detail. A site specific practicality/constructability review should be completed during preliminary design to identify site specific flood protection requirements.

2.0 Summary of Flood Impact Studies

2.1 SUBSTATION FLOOD PROTECTION REPORT (MARCH 2, 2012)

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing substantial impact to some electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. As a result of Hurricane Irene, as well as prior flooding events, Black & Veatch was engaged to prepare a "Substation Flood Protection Report" for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, March 2, 2012). The Substation Flood Protection Report presents the results of evaluations that were performed to determine the maximum observed flood water elevations and flood depths at each site and provides preliminary recommendations for providing appropriate flood protection measures.

Flood protection measures that were considered consisted of earthen berms, sheetpile barriers and concrete floodwalls. In general, earthen berms were selected for flood protection when sufficient space existed at the substation site as this is the lowest cost alternative, and sheetpile barriers were selected for use at sites where sufficient space does not exist for use of berms. Due to high cost, concrete floodwalls were not selected for any of the sites. Based on the preliminary evaluations, the total estimated cost for providing the recommended flood protection at all sites is \$10,115,000 in 2012 dollars. The estimated cost at each site varies considerably based on the height of flood protection required and the perimeter length of the protected area.

Based on the detailed site surveys recently performed by PSE&G, each site's baseline elevation and proposed flood protection elevation have been updated in reference to the detailed flood studies herein. The NJDEP Flood Hazard Limit (FHL) is the more conservative measure used in New Jersey that applies an increase of 25% to the FEMA 100-yr flood flows. The NJDEP FHL criterion supersedes the FEMA 100-year flood plain elevations referenced in the Preliminary Flood Protection Report, and is the baseline for the projects in this report and moving forward.

For each site, the most recently observed flooding from Hurricane Irene was compared to the NJDEP FHL in determining the updated top of flood protection elevations. For the sites, we recommend that flood protection extend one foot above the NJDEP FHL or observed Hurricane Irene flood elevation, whichever is greater. In the case of Marion, where the Hackensack River is tidally influenced, a storm surge assessment was performed to determine the appropriate water surface elevations. Based on the events of Hurricane Sandy on October 29-30, 2012, this will need to be re-assessed.

The Belmont substation flood protection would not result in an increase in the water surface elevation, however the updated survey has indicated that the site will be inundated by 8 feet of water for the NJDEP FHL. The flood protection approach and estimated costs presented in the preliminary report will need to be re-evaluated in light of this greater depth. The updated site details are presented in the table below.

Table 1. Summary of Substation Flood Protection Requirements

| SITE ELEVATION SUMMARY | | | | | | | |
|------------------------|-------------------------------------|------------------------------------|----------------------------------|----------------------------|-------------------------------|--|-------------|
| Site | Surveyed Minimum Site EL. (NAVD 88) | Maximum Observed Flood EL. (PSE&G) | NJDEP Flood Hazard EL. (NAVD 88) | Max. Observed Storm | Proposed Flood Protection EL. | Reference | Wall Height |
| New Milford | 8.5 | 11.5 | 9.2 | Greater than NJDEP FHL | 12.5 | 1 ft over observed | 4.0 |
| Cranford | 60.5 | 63.5 | 64.2 | Less than NJDEP FHL | 65.2 | 1 foot over NJDEP | 4.7 |
| Hillsdale | 63.0 | 66.0 | 63.8 | Greater than NJDEP FHL | 67.0 | 1 ft over observed | 4.0 |
| River Edge | 6.5 | 8.0 | 7.3 | Greater than NJDEP FHL | 9.0 | 1 ft over observed | 2.5 |
| Rahway | 10.0 | 13.0 | 13.33 | Less than NJDEP FHL | 14.33 | 1 ft over NJDEP | 4.3 |
| Somerville | 46.0 | 49.0 | 48.4 | Greater than NJDEP FHL | 50.0 | 1 ft over observed | 4.0 |
| Jackson Rd. | 175 | 176.2 | 175.3 | Greater than NJDEP FHL | 177.2 | 1 ft over observed | 2.2 |
| Marion | 5.0 | 6.5 | 7.9 | FEMA 100 year and Max Tide | 8.9 | 1 ft over FEMA 100 yr flow and 1% tide level | 3.9 |
| Ewing | 72.5 | 74.5 | 76.2 | Less than NJDEP FHL | 77.2 | 1 ft over NJDEP | 4.7 |
| Belmont | 14.5 | 17 | 22.5 | Less than NJDEP FHL | 23.5 | 1 ft over NJDEP | 9.0 |

2.2 SELECTED SITES FOR FLOOD IMPACT STUDIES

In order to determine the potential for upstream flood impacts as result of implementation of the recommended flood protection measures, Black & performed detailed Flood Impact Studies for ten of the previously considered twelve substation sites. Flood impact studies are unnecessary for Bayway, where the site is not in the floodplain and is located behind the City of Elizabeth Levee, or for Garfield where any improvements would be performed within the existing perimeter wall of the site.

The ten stations that were studied further in this Flood Impact Study are listed below.

Central Division

Cranford Substation
Rahway Substation
Somerville Substation

Palisades Division

New Milford Switching Station
River Edge Substation
Hillsdale Substation
Marion Switching Station

Metro Division

Belmont Substation
Jackson Road Substation

Southern Division

Ewing Substation

2.3 WATER SURFACE PROFILE MODELS

In general, the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S. Army Corps of Engineers Hydraulic Engineering Center, was used to develop a hydraulic model for the river or stream adjacent to each substation site. The HEC-RAS program is the accepted state of the practice software by regulatory agencies. Updated, site specific topographic survey data provided by PSE&G was used in augmenting the existing NJDEP and FEMA flood modeling data for each of the substation sites and for development of the flood impact computer models. Models and data used by FEMA and the NJDEP to establish the existing flood mapping in the region were used as the baseline for the updated HEC-RAS hydraulic models.

In order to achieve the goals of this study, four geometry models were generally considered for each site as follows.

- The first model was the Effective Model. This model is the HEC-RAS model with its saved results as provided by NJDEP. The results of the Effective Model provide the New Jersey Department of Environmental Protection (NJDEP) 100-year flood levels.

The remaining three other models were copies of NJDEP's HEC-RAS model: the Duplicate Effective Model, the Existing Conditions Model, and the Proposed Conditions Model.

- The Duplicate Effective Model is a copy of the NJDEP HEC-RAS model with no modifications, but rerun to ensure similar results and proper calibration.
- The Existing Conditions Model was based on the Duplicate Effective Model, but includes additional cross-sections in the vicinity of the site and modifications to some cross-sections.

- The Proposed Conditions Model was based on the Existing Conditions Model and includes proposed flood protection.

The flood elevation differences between proposed conditions and existing conditions throughout the modeled length along the river were used to represent the potential flood impact associated with the proposed improvements.

The Black & Veatch models are accurate and appropriately characterize the each site and associated water body. The largest of the calibration differentials were found several thousand feet upstream of the sites, near the start of the model where boundary conditions can cause the numerical shift due to the iterative nature of the calculations. The model differential is also typically found at bridge crossings, where the constriction of the channel and other obstructions create numerical variation.

2.4 FLOOD IMPACT STUDY RESULTS

Black & Veatch provided Technical Memoranda presenting the results of the detailed flood impact studies at each substation site to PSE&G as the individual studies were completed during the course of the studies. These memoranda provide comprehensive summaries of the studies at each site and are included in the Appendix to this report. The potential flood impacts are indicated in Table 1 above.

2.5 IMPLEMENTATION CONSIDERATIONS

Subsequent activities associated with implementation of the flood protection measures at one or more sites would include permitting, site subsurface investigations, engineering design, and construction. These activities could be conducted for all substation sites together, or could be conducted over a period of time to provide for a phased implementation of the flood protection measures at selected sites.

Specific site logistics such as fence relocation, replacement, and temporary security fencing during construction will need to be considered during design and construction. Construction staging areas for the smaller sites may require additional consideration. Work planning should be performed in accordance with PSE&G safety and operations criteria.

It is noted that other approaches to providing the desired level of flood protection may be considered during subsequent evaluations. These alternate approaches may include, but are not limited to, strategic substation relocations or protection of only the critical portions and components of the substation site such as the control building. A risk analysis has not been performed as part of this study, and should be considered for subsequent evaluations if needed to support PSE&G's business case for the flood protection measures to be implemented. The flood protection measures considered in this study have been developed to a conceptual level of detail. A site specific practicality/constructability review should be completed during preliminary design to identify site specific flood protection requirements.

Appendix A - Individual Flood Studies 1

FLOOD IMPACT STUDY NEW MILFORD SWITCHING STATION

Public Service Electric & Gas

11 OCTOBER 2012



Table of Contents

- 1.0 Background1**
- 2.0 Data Review and Hydraulic Modeling.....2**
 - Data Review 2
 - Hydraulic Model Development 2
 - Hydraulic Model Scenarios 3
 - Preliminary Flood Impacts 4
- 3.0 Conclusions and Recommendation.....6**

1.0 Background

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing significant impact to electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. Based on this and prior flooding events a "Flood Protection Report" was completed for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, 2012). The Report defines the preliminary requirements to provide flood protection at the twelve flood prone substation sites. Since most of the substation sites are located within either the FEMA 100-year floodplain or the defined floodway area, construction of flood protection facilities at these sites could potentially impact upstream flood water elevations.

Flood Impact Studies will be performed for ten of the twelve substation sites, and will be based on the recommendations for flood protection measures included in the Black & Veatch, Flood Protection Report. Flood impact studies are not required for two of the twelve sites as they are either a) not in the FEMA 100-year floodplain (Ewing) or b) the proposed flood protection facilities will be located behind existing site floodwall protection (Garfield). PSE&G has provided guidance as to the order in which they would like the substations studied. This prioritization is denoted in the list below in parentheses after the substation name. The ten substations to be studied are as follows:

Central Division

1. Cranford Substation (2)
2. Rahway Substation (5)
3. Somerville Substation (6)

Metro Division

4. Belmont Substation (10)
5. Jackson Road Substation (7)

Palisades Division

6. New Milford Switching Station (1)
7. River Edge Substation (4)
8. Hillsdale Substation (3)
9. Marion Switching Station (8)

Southern Division

10. Ewing Substation (9)

This Flood Impact Study addresses the potential for flooding upstream of the New Milford Switching Station. It describes the upstream flood impacts resulting from construction of the recommended flood protection facilities. It is intended that the results of this study will be used by PSE&G in evaluating the implementation of the flood protection measures at this site. It is recognized that additional flood studies will likely be required to support the permitting process if the recommended mitigation methods are chosen.

The New Milford Switching Station is located on Henley Avenue, west of River Road. Primary gated access is from Henley Avenue. The north side is open for access, however all

other sides of the site are not easily accessible. The entire site is approximately 8 acres. Elevations along the Hackensack River during Hurricane Irene were reportedly higher, possibly due to flood gate releases from the Oradell Dam, upstream of the site. The site is located within the NJDEP Riparian Buffer Zone.

2.0 Data Review and Hydraulic Modeling

DATA REVIEW

The following documents were utilized in the development of the hydraulic model for the New Milford Switching Station.

- 1) NJDEP. HEC-2 Input and Output Printouts from 22 September 2006 (Hackensack_River_New_Milford_FW_Hacknmfy3.pdf)
- 2) NJDEP. HEC-2 Input and Output Printouts from 9 April 1981 (Hackensack_River_Amended_Run_FW.pdf)
- 3) Site survey of the New Milford Switching Station (17 May 2012)
- 4) Black & Veatch. 2012 Substation Flood Protection – Summary Evaluation Report. 2 March 2012.

The HEC-2 Input and Output printouts (documents 1 and 2) were the basis of the model development. Cross-sectional characteristics were obtained directly from these documents. The site survey (document 3) was used to refine ground elevations at the site and distances to the river, and to append existing hydrologic cross-sections along the site. The Substation Flood Protection Report (document 4) provided the estimated height for the flood protection measures. The vertical datum for all elevations reported in the HEC-2 files (documents 1 and 2) is NGVD 29, while the vertical datum for documents 3 and 4 is NAVD 88. NAVD 88 is one foot below NGVD 29 elevation. All elevations presented in this report are NAVD 88.

Based on this report, the flood protection wall at the New Milford Switching Station will have a top elevation 2 feet above the 100-year flood level. Based on documents 1 and 2, the 100-year flood elevation in the vicinity of the site ranges from 8.80 ft near the northern end to 8.55 ft near the southern end. The top of the wall was modeled at EL. 11.0.

HYDRAULIC MODEL DEVELOPMENT

Black & Veatch used the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S. Army Corps of Engineers Hydraulic Engineering Center, to develop a hydraulic model for the Hackensack River in the vicinity of the New Milford Substation. The hydraulic model was based on hardcopy printouts of NJDEP's HEC-2 input data (documents 1 and 2) and included cross-sections 104000 through 109530.

The NJDEP HEC-2 file from 2006 (document 1) indicates that cross-section 108930 is at the downstream face of River Edge Road. Upstream and downstream cross-sections were located based on centerline distances between cross-sections as indicated in the HEC-2 files. See Figure 1 for the location of River Edge Road relative to the New Milford Site and the locations of the modeled cross-sections, shown in white.

In addition to Station and Elevation data, the following variables were also obtained from the HEC-2 files (documents 1 and 2) for each of the modeled cross-sections: Downstream Reach Lengths; Manning's n Values; Main Channel Bank Stations; and Contraction and Expansion Coefficients. The downstream boundary condition in the model was set as a "Known Water Surface Elevation" (WSE) equal to the 100-year flood level at cross-section 104000, 8.03 feet (NAVD 88) as reported in the 1981 NJDEP HEC-2 output printout (document 2). The River Edge Road Bridge was also modeled as indicated in the HEC-2 files.

Four cross-sections were added to the hydraulic model in the vicinity of the New Milford Site, and one NJDEP existing cross-section (106850) was modified in order to more accurately reflect recent survey data at the site. The added and modified cross-sections are shown in yellow in Figure 1.

The following flows were considered:

- 6,900 cfs – Hackensack River, 100-year flood flow
- 8,625 cfs – Flood Hazard Limit Criterion = 125% of the Hackensack River, 100-year flood flow

HYDRAULIC MODEL SCENARIOS

In order to achieve the goal of this study, four geometry models are considered.

- The first model was the Effective Model. This was developed from the NJDEP HEC-2 files including input and results. The results of the Effective Model provide the New Jersey Department of Environmental Protection (NJDEP) 100-year flood levels.

The remaining three other models were prepared using the HEC-RAS software: the Duplicate Effective Model, the Existing Conditions Model, and the Proposed Conditions Model.

- The Duplicate Effective Model was the HEC-RAS model which is based entirely on the Effective Model information from the HEC-2 printouts.
- The Existing Conditions Model was based on the Duplicate Effective Model, but includes additional cross-sections and slightly modified cross-sections in order to more accurately describe topography in the vicinity of the site.
- The Proposed Conditions Model was based on the Existing Conditions Model and includes proposed changes, which in this case was sheet pile walls for flood protection, at the New Milford Site. This was modeled as blocked obstructions in the HEC-RAS model. Figures 2 through 6 illustrate the impacted cross-sections in the HEC-RAS model both with and without the obstruction to flow.

The flood elevation differences between proposed conditions and existing conditions throughout the modeled length along the river will represent the potential flood impact associated with the proposed improvements.

PRELIMINARY FLOOD IMPACTS

The Duplicate Effective Model yields results that are very similar to those of the Effective Model especially in the vicinity of the New Milford Site, downstream of River Edge Road. In this reach, WSEs in the Duplicate Effective model vary by 0.0 to 0.03 foot from the Effective Model results. Based on the existing data and the model output, the Black & Veatch model is properly calibrated and accurately estimates the flows and elevations within the Hackensack River. Table 1 presents the results from the four models. River stations in bold indicate the additional cross-section added to the model at the site.

Table 1: Hydraulic Model Results - FEMA 100-year Flood (6,900 cfs)

| | 1 | 2 | 3 | 4 | 4-3 |
|---------------|------------------------|---------------------|---------------------|---------------------|--------------|
| River Station | Effective Model | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 109530 | 10.02 | 10.3 | 10.37 | 10.36 | -0.01 |
| 109032 | 9.57 | 9.77 | 9.86 | 9.85 | -0.01 |
| 108968 | 9.27 | 9.42 | 9.53 | 9.53 | 0 |
| 108967 | River Edge Road Bridge | | | | |
| 108930 | 9.29 | 9.29 | 9.41 | 9.4 | -0.01 |
| 108880 | 9.22 | 9.27 | 9.38 | 9.38 | 0 |
| 108580 | 9.2 | 9.22 | 9.34 | 9.34 | 0 |
| 108100 | 9.09 | 9.11 | 9.24 | 9.24 | 0 |
| 107955 | 8.76 | 8.78 | 8.91 | 8.9 | -0.01 |
| 107860 | 8.7 | 8.72 | 8.86 | 8.85 | -0.01 |
| 107765 | 8.74 | 8.77 | 8.91 | 8.9 | -0.01 |
| 107625 | 8.8 | 8.83 | 8.97 | 8.96 | -0.01 |
| 107610 | n/a | n/a | 8.97 | 8.96 | -0.01 |
| 107510 | n/a | n/a | 8.91 | 8.9 | -0.01 |
| 107140 | n/a | n/a | 8.83 | 8.83 | 0 |
| 106850 | 8.63 | 8.66 | 8.74 | 8.74 | 0 |
| 106665 | n/a | n/a | 8.49 | 8.5 | 0.01 |
| 106560 | 8.55 | 8.58 | 8.58 | 8.58 | 0 |
| 106100 | 8.41 | 8.43 | 8.43 | 8.43 | 0 |
| 105700 | 8.39 | 8.41 | 8.41 | 8.41 | 0 |
| 105080 | 8.25 | 8.26 | 8.26 | 8.26 | 0 |
| 104500 | 8.12 | 8.13 | 8.13 | 8.13 | 0 |
| 104000 | 8.03 | 8.03 | 8.03 | 8.03 | 0 |

The Existing Conditions Model, which includes additional cross-sections in the vicinity of the site, yielded flood levels that are similar to those in the Duplicate Effective Model. The Proposed Conditions Model includes the sheet pile walls for flood protection in the right bank of the model starting at the 8-foot contour line in the vicinity of the site. This model

yielded flood levels that are 0.00 to 0.01 feet different than those in the Existing Conditions Model. The maximum rise seen in the vicinity of the site was 0.01 feet at cross-section 106665. These results indicate that the proposed flood protection facility will not significantly impact 100-year flood levels in the Hackensack River floodplain. Table 2 presents the results for the NJDEP Flood Hazard Criteria with flows at 8,625 cfs.

Table2: Hydraulic Model Results – NJDEP Flood Hazard Flows (8,625 cfs)

| | 3 | 4 | 4-3 |
|---------------|------------------------|---------------------|--------------|
| River Station | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) |
| 109530 | 11.11 | 11.09 | -0.02 |
| 109032 | 10.53 | 10.51 | -0.02 |
| 108968 | 10.15 | 10.11 | -0.04 |
| 108967 | River Edge Road Bridge | | |
| 108930 | 10.03 | 9.98 | -0.05 |
| 108880 | 9.99 | 9.95 | -0.04 |
| 108580 | 9.94 | 9.89 | -0.05 |
| 108100 | 9.83 | 9.78 | -0.05 |
| 107955 | 9.35 | 9.29 | -0.06 |
| 107860 | 9.28 | 9.22 | -0.06 |
| 107765 | 9.35 | 9.29 | -0.06 |
| 107625 | 9.44 | 9.38 | -0.06 |
| 107610 | 9.44 | 9.37 | -0.07 |
| 107510 | 9.34 | 9.3 | -0.04 |
| 107140 | 9.19 | 9.21 | 0.02 |
| 106850 | 9.05 | 9.09 | 0.04 |
| 106665 | 8.72 | 8.73 | 0.01 |
| 106560 | 8.85 | 8.85 | 0 |
| 106100 | 8.64 | 8.64 | 0 |
| 105700 | 8.6 | 8.6 | 0 |
| 105080 | 8.39 | 8.39 | 0 |
| 104500 | 8.19 | 8.19 | 0 |
| 104000 | 8.03 | 8.03 | 0 |

Based on model results, the proposed sheetpile flood wall around New Milford Switching Station has little impact on water surface elevations in the Hackensack River Floodplain under Flood Hazard Flow Conditions. The maximum rise as a result of the sheetpile wall is 0.04 feet.

Black & Veatch modeled the observed flooding condition of approximately EL. 10.5 to 11 feet reported by PSE&G during Hurricane Irene. In order to realize an inundation of that depth at the site, a flow of approximately 12,500 to 16,500 cfs would be necessary. According to USGS flow data from instrumentation more than a mile upstream of the New


Milford site, Hurricane Irene had a recurrence interval greater than the 100-year storm, with flood flows estimated at 10,500 cfs.


3.0 Conclusions and Recommendation

The proposed flood protection facilities will not impact flooding upstream of the New Milford Switching Station. If PSE&G proceeds with the design and construction of the proposed flood mitigation measures for the New Milford Switching Station, there will be no significant upstream impacts to existing structures. Hydraulically and shown through the models, this same conclusion applies to adjacent and downstream structures as well.


Because the flow and inundation from Hurricane Irene were greater than the required FEMA 100-year and NJDEP Flood Hazard flows, the top of flood protection elevation is 1 foot above the maximum elevation observed during Hurricane Irene. This will provide flood protection greater than the 100-year flood recurrence interval, but appropriately conservative to protect the site during extreme storm events.

| ELEVATION SUMMARY | | | | |
|-------------------|----------------------------|------------------------------------|----------------------------------|-------------------------------|
| Site | Minimum Site EL. (NAVD 88) | Maximum Observed Flood EL. (PSE&G) | NJDEP Flood Hazard EL. (NAVD 88) | Proposed Flood Protection EL. |
| New Milford | 8.5 | 11.5 | 9.2 | 12.5 |






North End of Site (XS 107610): Existing conditions.




North End of Site (XS 107610): Proposed Condition - Sheetpile Flood Protection Installed.

Figure 2: Cross-sectional view from Upstream End of Site looking downstream.
PF1 = FEMA 100-yr flow 6,900 cfs; PF2 = NJDEP Flood Hazard flow 8,625 cfs.




XS 107510: Existing conditions.




XS 107510: Proposed Condition – Sheetpile Flood Protection Installed.

Figure 3: Cross-sectional view from XS 107510 looking downstream.
PF1 = FEMA 100-yr flow 6,900 cfs; PF2 = NJDEP Flood Hazard flow 8,625 cfs.




XS 107140 (Added XS): Existing conditions




XS 107140 (Added XS): Proposed Condition – Sheetpile Flood Protection Installed

Figure 4: Cross-sectional view from XS 107140 looking downstream.
PF1 = FEMA 100-yr flow 6,900 cfs; PF2 = NJDEP Flood Hazard flow 8,625 cfs.




XS 106850 (Modified XS): Existing conditions




XS 106850 (Modified XS): Proposed Condition – Sheetpile Flood Protection Installed

Figure 5: Cross-sectional view from XS 106850 looking downstream.
PF1 = FEMA 100-yr flow 6,900 cfs; PF2 = NJDEP Flood Hazard flow 8,625 cfs.



XS 106665 (Added XS): Existing conditions



XS 106665 (Added XS): Proposed Condition – Sheetpile Flood Protection Installed

Figure 6: Cross-sectional view from XS 106665 looking downstream.
PF1 = FEMA 100-yr flow 6,900 cfs; PF2 = NJDEP Flood Hazard flow 8,625 cfs.

FLOOD IMPACT STUDY FOR CRANFORD SUBSTATION

Public Service Electric & Gas

11 OCTOBER 2012



Table of Contents

- 1.0 Background1**
- 2.0 Data Review and Hydraulic Modeling.....2**
 - Data Review 2
 - Hydraulic Model Scenarios 2
 - Hydraulic Model Development 3
 - Preliminary Flood Impacts 4
- 3.0 Conclusions and Recommendation.....8**

1.0 Background

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing significant impact to electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. Based on this and prior flooding events a "Flood Protection Report" was completed for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, 2012). The Report defines the preliminary requirements to provide flood protection at the twelve flood prone substation sites. Since most of the substation sites are located within either the FEMA 100-year floodplain or the defined floodway area, construction of flood protection facilities at these sites could potentially impact upstream flood water elevations.

Flood Impact Studies will be performed for ten of the twelve substation sites, and will be based on the recommendations for flood protection measures included in the Flood Protection Report. Flood impact studies are not required for two of the twelve sites as they are either a) not in the FEMA 100-year floodplain (Ewing) or b) the proposed flood protection facilities will be located behind existing site floodwall protection (Garfield). PSE&G has provided guidance as to the order in which they would like the substations studied. This prioritization is denoted in the list below in parentheses after the substation name. The ten substations to be studied are as follows:

Central Division

1. Cranford Substation (2)
2. Rahway Substation (5)
3. Somerville Substation (6)

Metro Division

4. Belmont Substation (10)
5. Jackson Road Substation (7)

Palisades Division

6. New Milford Switching Station (1)
7. River Edge Substation (4)
8. Hillsdale Substation (3)
9. Marion Switching Station (8)

Southern Division

10. Ewing Substation (9)

This Flood Impact Study addresses the potential for flooding upstream of the Cranford Substation. It describes the upstream flood impacts resulting from construction of the recommended flood protection facilities. It is intended that the results of this study will be used by PSE&G in evaluating the implementation of the flood protection measures at this site. It is recognized that additional flood studies will likely be required to support the permitting process if the recommended mitigation methods are chosen.

The Cranford Substation is located on South Avenue east of High Street, at the Rahway River. The site is bounded to the north by a high NJ Transit retaining wall; the Rahway River

to the east; South Avenue to the south; and an adjacent driveway to the east. On the east side of the site there is a 12" thick concrete retaining wall at the crest of the river bank. PSE&G equipment is 15 feet from the edge of the river bank, and access to the east side of the site is limited. The site is located within the NJDEP Riparian Buffer Zone.

2.0 Data Review and Hydraulic Modeling

DATA REVIEW

The following documents were utilized in the development of the hydraulic model for the Cranford Substation.

- 1) NJDEP. HEC-RAS model for the Rahway River from 13 November 2002 (111302Rahway.prj)
- 2) NJDEP. Delineation of Floodway and Flood Hazard Area: Plans – Township of Cranford, NJ. 8 December 1981.
- 3) Kennon Surveying Services, Inc (KSS). Boundary and Topographic Survey - Cranford Substation (6 June 2012)
- 4) Black & Veatch (B&V). 2012 Substation Flood Protection – Summary Evaluation Report. 2 March 2012.

NJDEP's HEC-RAS model (document 1) was the basis of the model development. The site survey (document 3) assisted in determining ground elevations at the site and distances to the river, and to append the existing hydrologic cross-sections along the site. The Substation Flood Protection Report (document 4) provided the estimated height for the flood protection measures. The vertical datum for all elevations reported in the HEC-RAS model (document 1) is NGVD 29, while the vertical datum for documents 3 and 4 is NAVD 88. NAVD 88 is one foot below NGVD 29 elevations. All elevations presented in this report are NAVD 88.

Based on recommendations presented in the Substation Flood Protection – Summary Evaluation report (document 4), the flood protection wall at the Cranford Substation will have a top elevation 2 feet above the 100-year flood level. Based on references 1 and 2, the 100-year flood level in the vicinity of the site is 62.8 ft (NAVD 88) near its northeastern edge. The top of the wall was modeled at 65 ft (NAVD 88).

HYDRAULIC MODEL SCENARIOS

Black & Veatch used the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S Army Corps of Engineers Hydraulic Engineering Center, to develop a hydraulic model for the Rahway River in the vicinity of the Cranford Substation. The hydraulic model used for this study was a copy of NJDEP's HEC-RAS floodway model for the entire Rahway River.

In order to achieve the goal of this study, four geometry models were considered.

- The first model was the Effective Model. This model is the HEC-RAS model with its saved results as provided by NJDEP. The results of the Effective Model provide the New Jersey Department of Environmental Protection (NJDEP) 100-year flood levels.

The remaining three other models were copies of NJDEP's HEC-RAS model: the Duplicate Effective Model, the Existing Conditions Model, and the Proposed Conditions Model.

- The Duplicate Effective Model is a copy of the NJDEP HEC-RAS model with no modifications, but rerun to ensure similar results and proper calibration.
- The Existing Conditions Model was based on the Duplicate Effective Model, but includes additional cross-sections in the vicinity of the site and modifications to some cross-sections.
- The Proposed Conditions Model was based on the Existing Conditions Model and includes proposed flood protection.

The flood elevation differences between proposed conditions and existing conditions throughout the modeled length along the river will represent the potential flood impact associated with the proposed improvements.

HYDRAULIC MODEL DEVELOPMENT

A profile of the river indicating exact cross-section locations was not provided. Hence, the cross-section locations had to be estimated based on available information within NJDEP's HEC-RAS model. The existing NJDEP model indicates that cross-section 11.916 is just downstream of the Central Railroad Bridge, while cross-section 11.873 is at the upstream face of the South Avenue Bridge. The distance between the railroad bridge and the South Avenue Bridge is approximately 220 feet. These cross-sections are shown in white in Figure 1. Profile views of these cross-sections are presented in Figure 2. As these were the only two cross-sections modeled in this reach, the flow was allowed to expand onto the site from the right bank (west side) of the Central Railroad Bridge to the extent of the downstream cross-section. The extent of the effective flow in this reach of the NJDEP model is shown as a green-line labeled EF_EC_NJDEP (Effective Flow-Existing Conditions-NJDEP) in Figure 1.

In development of the Existing Conditions Model (Model 3), cross-sections were added at the site and modifications were made to the decking of the South Avenue Bridge and its bounding upstream cross-section. As shown in Figures 3 and 4, the decking at the South Avenue Bridge and the west bank profile at cross-section 11.837 were modified to match 2012 survey information (KSS, 2012). In the NJDEP model, the decking on the west side of South Avenue Bridge was modeled as below the grade of the bounding upstream cross-section (11.837), which is inconsistent with survey data and site inspection. Figure 5 presents the Boundary and Topographic Survey.

Three additional cross-sections transecting the Cranford site were added to the Existing Conditions Model and were also based on the KSS site survey (KSS, 2012). The additional cross-sections are shown in yellow on Figure 1.

Ineffective flow markers were placed in these cross-sections to maintain consistency with the flow expansion ratio as modeled in the NJDEP model. However, the existing building on site should be taken into consideration as it will limit the flow area and the ability of the water to effectively expand to the west upon exiting the railroad bridge. The building was not included as part of the NJDEP model; therefore lower than realistic WSEL result from the NJDEP model. The extent of the effective flow in the Existing Conditions Model is

illustrated in Figure 1 by the green line labeled EF-EC_rev1 (Effective Flow – Existing Conditions_revion1). Figures 6 through 8 illustrate the placement of the non-effective flow markers and blocked obstructions (representing the existing building) in each of the added cross-sections.

In Figure 6 – Existing Conditions Model, the ineffective flow area is presented as the green hatched area on the west bank, which is the site of Cranford Substation. Although this area would likely experience flooding under the modeled flow conditions, the flow would have little to no velocity. This area is pooled water, which is typical at the edges of flood plains. This effect is especially prevalent at Cranford, where the railroad viaduct bounds the northern end of the site.

In development of the Proposed Conditions Model (Model), the proposed flood protection was inserted on the west bank in each of the three added cross-sections. At the south end of the Cranford Substation Site, where the sheet piling would end, flows were allowed to expand out to the full width of cross-section 11.837. The extent of the effective flow in the Proposed Conditions Model is illustrated in Figure 1 by the green line labeled EF-PC (Effective Flow – Proposed Conditions).

Expansion and contraction coefficients at cross-sections 11.916, 11.907 and 11.896 were set to 0.1 and 0.3 respectively, as the potential for flow expansion is limited by the sheet pile flood protection wall. The expansion and contraction coefficients at cross-section 11.889, where the sheet pile flood protection wall ends, were set to 0.6 and 0.8 respectively. However, these values have a minor impact on the model results as the South Avenue Bridge is acting as a weir providing downstream control at this reach. The resultant backwater condition reduces velocities hence reducing the influence of any contractions or expansions.

The following flows were considered:

- 6,170 cfs - The Rahway River's FEMA 100-year flood flow in the vicinity of the Cranford Site.
- 7,713 cfs – NJDEP Flood Hazard Limit Criterion = 125% of the Rahway River, 100-year flood flow

During Hurricane Irene, the Cranford Substation was flooded up to an approximate WSEL of 63.5 ft. Based on the HEC-RAS model; this would correspond with a Rahway River flow of approximately 7,500 cfs in the vicinity of the substation, in the range of a 100-year storm flow.

PRELIMINARY FLOOD IMPACTS

The Duplicate Effective Model yields results that are equivalent to those of the Effective Model. However, the Existing Conditions Model, which includes additional cross-sections in the vicinity of the site and modification to the decking at South Avenue, yielded flood levels that are higher than those in the Duplicate Effective Model. It is our belief that our Existing Conditions Model more accurately describes the potential for flooding upstream of South Avenue Bridge than he NJDEP model. The South Avenue Bridge structure is the controlling

cross section for water surface elevations in this area. Table 1 presents the results from the four models considered. River stations in bold indicate the additional cross-section added to the model at the site.

Table 1: Hydraulic Model Results – FEMA 100-year Flood Levels (6,170 cfs)

| River Station | 1 Effective Model (ft) | 2 Duplicate Effective (ft) | 3 Existing Conditions (ft) | 4 Proposed Conditions (ft) | (4-3) Difference (ft) |
|---------------|---------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-----------------------------|
| 12.329 | 66.22 | 66.22 | 66.32 | 66.33 | 0.01 |
| 12.204 | 66.13 | 66.13 | 66.23 | 66.24 | 0.01 |
| 12.2 | 66.09 | 66.09 | 66.19 | 66.20 | 0.01 |
| 12.1975 | Dam | | | | |
| 12.197 | 66.01 | 66.01 | 66.11 | 66.12 | 0.01 |
| 12.191 | 66.01 | 66.01 | 66.12 | 66.13 | 0.01 |
| 12.166 | 66.03 | 66.03 | 66.13 | 66.14 | 0.01 |
| 12.156 | 66.06 | 66.06 | 66.16 | 66.17 | 0.01 |
| 12.15 | North Union Avenue Bridge | | | | |
| 12.146 | 65.43 | 65.43 | 65.60 | 65.62 | 0.02 |
| 12.136 | 65.00 | 65.00 | 65.20 | 65.22 | 0.02 |
| 12.089 | 65.13 | 65.13 | 65.32 | 65.34 | 0.02 |
| 11.992 | 64.06 | 64.06 | 64.38 | 64.40 | 0.02 |
| 11.983 | 64.00 | 64.00 | 64.33 | 64.35 | 0.02 |
| 11.977 | North Avenue Bridge | | | | |
| 11.971 | 62.92 | 62.92 | 63.37 | 63.39 | 0.02 |
| 11.935 | 62.98 | 62.98 | 63.42 | 63.44 | 0.02 |
| 11.9255 | Central Railroad Bridge | | | | |
| 11.916 | 62.79 | 62.79 | 63.26 | 63.28 | 0.02 |
| 11.907 | n/a | n/a | 63.28 | 63.30 | 0.02 |
| 11.896 | n/a | n/a | 63.27 | 63.28 | 0.01 |
| 11.889 | n/a | n/a | 63.24 | 63.26 | 0.02 |
| 11.873 | 62.72 | 62.72 | 63.27 | 63.27 | 0.00 |
| 11.8675 | South Avenue Bridge | | | | |
| 11.862 | 60.94 | 60.94 | 60.94 | 60.94 | 0.00 |
| 11.775 | 60.59 | 60.59 | 60.59 | 60.59 | 0.00 |
| 11.642 | 60.12 | 60.12 | 60.12 | 60.12 | 0.00 |
| 11.548 | 60.19 | 60.19 | 60.19 | 60.19 | 0.00 |
| 11.541 | 60.18 | 60.18 | 60.18 | 60.18 | 0.00 |
| 11.5405 | Droescher's Dam | | | | |
| 11.54 | 60.00 | 60.00 | 60.00 | 60.00 | 0.00 |
| 11.537 | 60.02 | 60.02 | 60.02 | 60.02 | 0.00 |
| 11.518 | 59.68 | 59.68 | 59.68 | 59.68 | 0.00 |

| | | | | | |
|--------|--------------------|-------|-------|-------|------|
| 11.463 | 59.68 | 59.68 | 59.68 | 59.68 | 0.00 |
| 11.455 | High Street Bridge | | | | |
| 11.45 | 58.69 | 58.69 | 58.69 | 58.69 | 0.00 |
| 11.44 | 56.91 | 56.91 | 56.91 | 56.91 | 0.00 |
| 11.43 | 57.12 | 57.12 | 57.12 | 57.12 | 0.00 |
| 11.429 | 56.75 | 56.75 | 56.75 | 56.75 | 0.00 |
| 11.209 | 54.50 | 54.50 | 54.50 | 54.50 | 0.00 |

The Existing Conditions Model yields WSEs that are 0.55 foot higher than the Effective and Duplicate Effective models at South Avenue Bridge. Approximately ½ mile upstream, the difference is only 0.1 foot.

The Proposed Conditions Model includes the flood protection on the west bank of the model. A slight rise in WSEL is noted in the vicinity of the site and upstream due to the flood protection installation. A maximum rise of 0.02 feet is noted at the south end of the flood wall as a result of the flood protection wall.

Table 2 presents the results for the NJDEP Flood Hazard Criteria with flows at 7,713 cfs. River stations in bold indicate the additional cross-sections added to the model at the site.

Table2: Hydraulic Model Results – NJDEP Flood Hazard Flows (7,713 cfs)

| River Station | 2 | 3 | 4 | (4-3) |
|----------------------|----------------------------|----------------------------|----------------------------|-------------------|
| | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) |
| 12.329 | 67.15 | 67.24 | 67.25 | 0.01 |
| 12.204 | 67.02 | 67.11 | 67.12 | 0.01 |
| 12.200 | 66.97 | 67.07 | 67.07 | 0.00 |
| 12.1975 | Dam | | | |
| 12.197 | 66.88 | 66.98 | 66.99 | 0.01 |
| 12.191 | 66.89 | 66.99 | 66.99 | 0.00 |
| 12.166 | 66.91 | 67 | 67.01 | 0.01 |
| 12.156 | 66.96 | 67.05 | 67.06 | 0.01 |
| 12.150 | North Union Avenue Bridge | | | |
| 12.146 | 66.46 | 66.61 | 66.62 | 0.01 |
| 12.136 | 65.98 | 66.16 | 66.17 | 0.01 |
| 12.089 | 66.12 | 66.29 | 66.30 | 0.01 |
| 11.992 | 64.9 | 65.24 | 65.26 | 0.02 |
| 11.983 | 64.81 | 65.16 | 65.18 | 0.02 |
| 11.977 | North Avenue Bridge | | | |
| 11.971 | 63.82 | 64.27 | 64.30 | 0.03 |
| 11.935 | 63.89 | 64.31 | 64.34 | 0.03 |
| 11.9255 | Central Railroad Bridge | | | |

| | | | | |
|---------------|---------------------|--------------|--------------|-------------|
| 11.916 | 63.6 | 64.08 | 64.10 | 0.02 |
| 11.907 | n/a | 64.14 | 64.16 | 0.02 |
| 11.896 | n/a | 64.12 | 64.14 | 0.02 |
| 11.889 | n/a | 64.09 | 64.12 | 0.03 |
| 11.873 | 63.61 | 64.14 | 64.14 | 0.00 |
| 11.8675 | South Avenue Bridge | | | |
| 11.862 | 61.91 | 61.91 | 61.91 | 0.00 |
| 11.775 | 61.63 | 61.63 | 61.63 | 0.00 |
| 11.642 | 61.18 | 61.18 | 61.18 | 0.00 |
| 11.548 | 61.26 | 61.26 | 61.26 | 0.00 |
| 11.541 | 61.25 | 61.25 | 61.25 | 0.00 |
| 11.5405 | Droescher's Dam | | | |
| 11.540 | 61.12 | 61.12 | 61.12 | 0.00 |
| 11.537 | 61.14 | 61.14 | 61.14 | 0.00 |
| 11.518 | 60.88 | 60.88 | 60.88 | 0.00 |
| 11.463 | 60.91 | 60.91 | 60.91 | 0.00 |
| 11.455 | High Street Bridge | | | |
| 11.450 | 60.15 | 60.15 | 60.15 | 0.00 |
| 11.440 | 57.95 | 57.95 | 57.95 | 0.00 |
| 11.430 | 58.38 | 58.38 | 58.38 | 0.00 |
| 11.429 | 57.39 | 57.39 | 57.39 | 0.00 |
| 11.209 | 55.78 | 55.78 | 55.78 | 0.00 |

Based on model results, the proposed sheetpile flood wall around the Cranford Substation will only slightly impact water surface elevations in the Rahway River Floodplain under Flood Hazard Flow Conditions. The maximum rise as a result of the sheetpile wall is 0.03 feet under Flood Hazard Flow Conditions. Approximately one-half mile upstream of the site the resulting change in WSE is 0.01 ft.

Black & Veatch modeled the observed flooding condition of approximately EL. 63.5 feet reported by PSE&G during Hurricane Irene. In order to realize an inundation of that depth at the site, a flow of approximately 7,500 cfs would be necessary. According to USGS, their flow gauge, which is located 7,000 feet upstream of the Cranford site, was destroyed during Hurricane Irene. However, the last gauge reading during the storm was about 7,000 cfs.


3.0 Conclusions and Recommendation

The proposed flood protection facilities will only slightly impact flooding upstream of the Cranford Substation. If PSE&G proceeds with the design and construction of the proposed flood mitigation measures for the Cranford Substation, there should be little to no impact to upstream existing structures. Hydraulically and based on the model results, there are no impacts to downstream structures.

The existing conditions model prepared for this study was based on the NJDEP model but was modified to more accurately describe South Avenue and the South Avenue Bridge based on recent survey data. The updates resulted in a rise in predicted flood levels. For the 100-year flood, an increase of 0.55 foot upstream of South Avenue (63.27 feet NAVD 88) was predicted. This fact will be addressed during the permitting process and will require approval of the NJDEP and FEMA.

The flow and inundation from Hurricane Irene were greater than the required FEMA 100-year, and nearly equivalent to the NJDEP Flood Hazard flows. An Elevation of 65.2 feet, which is approximately 1 foot above the Black & Veatch estimated Flood Hazard Elevation, was selected as the top of wall design level.

| ELEVATION SUMMARY (FEET NAVD 88) | | | | |
|----------------------------------|------------------|------------------------------------|------------------------|-------------------------------|
| Site | Minimum Site EL. | Maximum Observed Flood EL. (PSE&G) | NJDEP Flood Hazard EL. | Proposed Flood Protection EL. |
| Cranford | 60.5 | 63.5 | 64.2 | 65.2 |









Figure 2: Cross-sectional views (looking downstream) of cross-sections 11.916 and 11.873 as modeled in NJDEP Hec-Ras Model. PF1 = FEMA 100-yr flow 6,170 cfs; PF2 = NJDEP Flood Hazard flow 7,713 cfs.




South Avenue Bridge as modeled in Effective and Duplicate Effective Models




South Avenue Bridge as modeled in Existing Conditions and Proposed Conditions Models

Figure 3: Cross-sectional views (looking downstream) of South Avenue Bridge as modeled in NJDEP HEC-RAS Model and as modified based on 2012 survey data in Existing Conditions and Proposed Conditions Models. PF1 = FEMA 100-yr flow 6,170 cfs; PF2 = NJDEP Flood Hazard flow 7,713 cfs.




XS just Upstream of South Avenue Bridge as modeled in NJDEP Model (Effective and Duplicate Effective Models)



XS just Upstream of South Avenue Bridge as modeled in Existing Conditions and Proposed Conditions Models

Figure 4: Cross-sectional views (looking downstream) of cross-section just upstream of South Avenue Bridge as modeled in NJDEP HEC-RAS Model and as modified based on 2012 survey data in Existing Conditions and Proposed Conditions Models. PF1 = FEMA 100-yr flow 6,170 cfs; PF2 = NJDEP Flood Hazard flow 7,713 cfs.









Figure 6: Cross-sectional view from Upstream End of Site looking downstream.
PF1 = FEMA 100-yr flow 6,170 cfs; PF2 = NJDEP Flood Hazard flow 7,713 cfs.



Middle of Site (XS 11.896): Existing conditions.



Middle of Site (XS 11.896): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 7: Cross-sectional view from XS 11.896 looking downstream.
PF1 = FEMA 100-yr flow 6,170 cfs; PF2 = NJDEP Flood Hazard flow 7,713 cfs.





Figure 8: Cross-sectional view from XS 11.889 looking downstream.
PF1 = FEMA 100-yr flow 6,170 cfs; PF2 = NJDEP Flood Hazard flow 7,713 cfs.

FLOOD IMPACT STUDY FOR HILLSDALE SUBSTATION

Public Service Electric & Gas

11 OCTOBER 2012



Table of Contents

- 1.0 Background1**
- 2.0 Data Review and Hydraulic Modeling.....2**
 - Data Review 2
 - Hydraulic Model Scenarios 3
 - Hydraulic Model Development 3
 - Preliminary Flood Impacts 5
- 3.0 Conclusions and Recommendation.....9**

1.0 Background

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing significant impact to electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. Based on this and prior flooding events a "Flood Protection Report" was completed for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, 2012). The Report defines the preliminary requirements to provide flood protection at the twelve flood prone substation sites. Since most of the substation sites are located within either the FEMA 100-year floodplain or the defined floodway area, construction of flood protection facilities at these sites could potentially impact upstream flood water elevations.

Flood Impact Studies will be performed for ten of the twelve substation sites, and will be based on the recommendations for flood protection measures included in the Flood Protection Report. Flood impact studies are not required for two of the twelve sites as they are either a) not in the FEMA 100-year floodplain (Bayway) or b) the proposed flood protection facilities will be located behind existing site floodwall protection (Garfield). PSE&G has provided guidance as to the order in which they would like the substations studied. This prioritization is denoted in the list below in parentheses after the substation name. The ten substations to be studied are as follows:

Central Division

1. Cranford Substation (2)
2. Rahway Substation (5)
3. Somerville Substation (6)

Metro Division

4. Belmont Substation (10)
5. Jackson Road Substation (7)

Palisades Division

6. New Milford Switching Station (1)
7. River Edge Substation (4)
8. Hillsdale Substation (3)
9. Marion Switching Station (8)

Southern Division

10. Ewing Substation (9)

This Flood Impact Study addresses the potential for flooding upstream of the Hillsdale Substation. It describes the upstream flood impacts resulting from construction of the recommended flood protection facilities. It is intended that the results of this study will be used by PSE&G in evaluating the implementation of the flood protection measures at this site. It is recognized that additional flood studies will likely be required to support the permitting process if the recommended mitigation methods are chosen.

The Hillsdale Substation is located at Knickerbocker Avenue, west of Paterson Street, and encompasses approximately 2.5 acres. Primary gated access is off of Knickerbocker Avenue, and secondary gated access is off of Paterson Street. The north and east sides are heavily wooded, and businesses are located on the other sides of the site. The substation is located less than 200 feet from the Pascack Brook.

2.0 Data Review and Hydraulic Modeling

DATA REVIEW

The following documents were utilized in the development of the hydraulic model for the Hillsdale Substation.

- 1) NJDEP. HEC-RAS printout for the Pascack Brook from 6 September 2000 (PASCACK_BR_DEWBERRY.PDF)
- 2) NJDEP. Delineation of Floodway and Flood Hazard Area: Plans – Borough of Hillsdale, NJ. June 1978, Plate 14.
- 3) Dresdner Robin Hanson Engineering Division, Boundary and Topographic Survey - Hillsdale Substation, Block 1212, Lot 14 Borough of Hillsdale, NJ. (17 April 2012)
- 4) Black & Veatch (B&V). 2012 Substation Flood Protection – Summary Evaluation Report. 2 March 2012.
- 5) New Jersey Post-Hurricane Floyd Flood Study Hydrologic Analyses of Musquapsink and Pascack Brooks, FEMA June 2002 (PASCACK_MUSQUAPSINK_NEWER_HYDROLOGY.PDF)

NJDEP's HEC-RAS printout (document 1) was the basis of the model development. The NJDEP Delineation of Floodway and Flood Hazard Area (document 2) assisted in the appropriate placement of modeled cross-sections relative to the Hillsdale Substation Site. The site survey (document 3) assisted in determining ground elevations at the site, distances to the river, and appropriate modifications to the existing hydraulic cross-sections along the site. The New Jersey Post-Hurricane Floyd Flood Study (document 5) provided updated flows for the model.

The estimated height for the flood protection measures was initially based on information provided in the Substation Flood Protection Report (document 4). However, after modeling results were obtained, it was decided that the height for the flood protection measures should be increased due to the updated flows (document 5).

The vertical datum for all elevations reported in the HEC-RAS model (document 1) is NGVD 29, while the vertical datum for documents 3 and 4 is NAVD 88. NAVD 88 is one foot below NGVD 29 elevations. All elevations presented in this report unless otherwise noted are NAVD 88, (i.e. cross section profile views which were taken directly from the HEC-RAS model are in NGVD 29. (See Figures 2-6).

Based on updated flows and model results, the top of the flood protection wall at the Hillsdale Substation was initially set at 2 feet above the updated NJDEP's Flood Hazard level. Based on model results for Flood Hazard flow, which is equal to 125% of the 100-year flow, the corresponding flood level in the vicinity of the site is 63.8 ft (NAVD 88) near its northern

edge. This would have made the top elevation of the wall at elevation 66 ft. However, during Hurricane Irene the maximum observed flood elevation was 66 ft. A one foot of freeboard has been added to this observed level for a top of wall elevation at 67 ft. (NAVD 88).

HYDRAULIC MODEL SCENARIOS

Black & Veatch used the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S Army Corps of Engineers Hydraulic Engineering Center, to develop a hydraulic model for the Pascack Brook in the vicinity of the Hillsdale Substation. The hydraulic model used for this study was a portion of NJDEP's HEC-RAS model in printout form of the Pascack Brook. The model started approximately 0.5 miles downstream from the site and continued upstream to the downstream end of the energy dissipater and stilling basin for Woodcliff Lake Dam.

In order to achieve the goal of this study, four geometry models were considered.

- The first model was the Effective Model. This model is the printout of results from the HEC-RAS model as provided by NJDEP. The results of the Effective Model provide the New Jersey Department of Environmental Protection (NJDEP) 100-year flood levels.

The remaining three other models were constructed models using NJDEP's HEC-RAS print out model as the basis, (document 1). These models are: the Duplicate Effective Model, the Existing Conditions Model, and the Proposed Conditions Model.

- The Duplicate Effective Model is an entered version of the printout of the NJDEP HEC-RAS model with no modifications, but rerun to ensure similar results and proper calibration.
- The Existing Conditions Model was based on the Duplicate Effective Model, but includes additional cross-sections in the vicinity of the site and modifications to some cross-sections. In addition the flows have been increased due to the study results by FEMA (document 5)
- The Proposed Conditions Model was based on the Existing Conditions Model and includes proposed flood protection.

The flood elevation differences between proposed conditions and existing conditions throughout the modeled length along Pascack Brook will represent the potential flood impact associated with the proposed improvements.

HYDRAULIC MODEL DEVELOPMENT

A profile of the river indicating exact cross-section locations was not provided. Hence, the cross-section locations had to be estimated based on available information within NJDEP's HEC-RAS model. The cross-sections in the model are labeled by stationing of the stream. The provided Delineation of Floodway and Flood Hazard Area map also had the stream stationing located on the map. The two downstream bridges, Hillsdale Avenue and Patterson Street, have stationing in the model that agrees with the stationing shown on the map. Therefore, it was possible to place the cross-section locations by their river stationing

name in accordance with the stationing on the Delineation of Floodway and Flood Hazard map. The cross-sections used in the model are shown in Figure 1. The white cross-sections are representative of where the existing NJDEP cross-sections are located.

In development of the Existing Conditions Model (Model 3), three cross-sections were added at the site, (28792, 28706, and 28575) and two existing cross-sections (28830, 28620) were modified. The additional cross-sections and extensions to existing cross sections are shown in yellow on Figure 1. Profile views of these cross-sections are presented in Figures 2 - 6.

Figures 2a and 2b show cross-section 28830 located just north of the upstream end of the site. The figures illustrate the Effective and Duplicate Effective cross-section along with the Existing and Proposed Conditions cross-section. For the Existing and Proposed Conditions, cross-section 28830 was modified to match 2012 survey information (document 3, 2012). Cross-section 28830 in the NJDEP Effective Model had a left bank floodplain elevation of 59 ft. This was raised up to match the 2012 survey to an elevation of 60 ft. The cross-section was also extended to the east to cover the full length of the site. Survey information indicates that there is a contour at elevation 63 ft along the north edge of the site, thus WSEs would need to exceed 63 feet in order to flow onto the site from the north. There is also a partial berm running east to west on the northern half of the site with a top elevation of 63 ft. Any water east of this berm would be ineffective unless WSEs exceed 63 feet. Therefore, an ineffective flow marker was placed on cross-section 28830 to prevent effective flow from utilizing the eastern portion of the cross-section for levels less than 63 feet.

Figure 5a illustrates the modification to cross-section 28620 between the Effective and Duplicate Effective model and the Existing Conditions model, which contains blocked obstructions to represent buildings and other site features which will impede flows. Figure 5b shows the Proposed Conditions cross-section. Again, all cross-section modifications were taken from the 2012 survey (document 3, 2012).

The last cross-section at the southern edge of the plant site starts at 62 ft then gradually slopes up to 63 ft before increasing grade at a faster rate as indicated in the survey. Figure 6 shows the last cross-section at the southern edge of the site, cross-section 28575. The southern edge of the site has a curb with a top elevation of approximately 63 ft. Therefore an ineffective flow marker was placed on cross-section 28575 at the western edge of that curb to prevent flow east of the curb until the curb is overtopped.

In development of the Proposed Conditions Model (Model 4), the proposed flood protection was inserted on the east bank in each of the three added cross-sections and one of the existing cross-sections. Any buildings that were illustrated on the existing conditions model are now shown as a flood protection wall or an ineffective area in the Proposed Conditions Model. Cross-section 28830, at the northern edge of the plant site, is believed to be located just north of the drainage ditch on the north end of the plant. Therefore, this cross-section does not show the proposed flood protection.

The following flows were considered:

For the Duplicate Effective Model

- 2,745 cfs - The Pascack Brook NJDEP model 100-year flood flow in the vicinity of the Hillsdale Substation Site.
- 3,431 cfs – NJDEP Flood Hazard Limit Criterion = 125% of the Pascack Brook 100-year flood flow.

For the Existing Conditions and Proposed Conditions Models

- 3,647 cfs - The Pascack Brook updated NJDEP model 100-year flood flow in the vicinity of the Hillsdale Substation Site. (document 5)
- 4,556 cfs – Updated NJDEP Flood Hazard Limit Criterion = 125% of the Pascack Brook 100-year flood flow. (document 5)

During Hurricane Irene, an observation was made at the Hillsdale Substation that placed the maximum observed water surface elevation at approximately 66.0 ft. According to the USGS website for gage station USGS 01377500 Pascack Brook at Westwood NJ, the peak flow at the gauging station was 4,630 cfs. The flow at the Hillsdale Substation would be less than at the gauging station. However, flows in excess of this amount would be required to obtain a modeled water surface at the site equal to 66 ft. Therefore, it is believed that substantial debris was in the channel and blockage of bridge structures may have caused the water surface to rise to the observed elevation. There is not enough information to accurately model the hurricane flow and elevation at the site. However, because an elevation of approximately 66 ft was observed during this time, it is advisable to design the flood protection for the observed Hurricane Irene level plus one foot of freeboard.

PRELIMINARY FLOOD IMPACTS

The Duplicate Effective Model yields results that are equivalent to those of the Effective Model. However, the Existing Conditions Model, which includes additional cross-sections in the vicinity of the site, modification to two existing cross-sections, and updated increased flows, yielded flood levels that are higher than those in the Duplicate Effective Model. It is our belief that our Existing Conditions Model more accurately describes the potential for flooding upstream of the Hillsdale Substation than the NJDEP model. Table 1 presents the results from the four models considered. River stations in bold indicate the additional cross-section added to the model at the site.

Table 1: Hydraulic Model Results – FEMA 100-year Flood Levels

(Duplicate Effective Flow 2,745 cfs and Existing and Proposed Conditions Flow 3,647 cfs)

| | 1 | 2 | 3 | 4 | (4-3) |
|---------------|-------------------------|---------------------|---------------------|---------------------|-------------|
| River Station | Effective Model | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 30500 | 65.60 | 65.60 | 66.22 | 66.22 | 0 |
| 30490 | 65.55 | 65.55 | 66.16 | 66.16 | 0 |
| 30448 | 65.46 | 65.46 | 66.01 | 66.01 | 0 |
| 30030 | 64.93 | 64.93 | 65.48 | 65.48 | 0 |
| 29555 | 63.09 | 63.09 | 64.07 | 64.07 | 0 |
| *28830 | 61.88 | 61.88 | 62.93 | 62.93 | 0 |
| 28792 | n/a | n/a | 62.76 | 62.76 | 0 |
| 28706 | n/a | n/a | 62.63 | 62.63 | 0 |
| *28620 | 61.70 | 61.70 | 62.66 | 62.67 | 0.01 |
| 28575 | n/a | n/a | 62.63 | 62.63 | 0 |
| 28290 | 61.12 | 61.12 | 62.18 | 62.18 | 0 |
| 28030 | 60.69 | 60.69 | 61.80 | 61.80 | 0 |
| 27715 | 60.37 | 60.37 | 61.46 | 61.46 | 0 |
| 27145 | 59.98 | 59.98 | 61.06 | 61.06 | 0 |
| 26615 | 59.24 | 59.24 | 60.25 | 60.25 | 0 |
| 26595 | 59.25 | 59.24 | 60.25 | 60.25 | 0 |
| 26575 | Hillsdale Avenue Bridge | | | | |
| 26555 | 59.18 | 59.18 | 60.23 | 60.23 | 0 |
| 26495 | 58.97 | 58.96 | 59.99 | 59.99 | 0 |
| 26150 | 58.86 | 58.86 | 59.90 | 59.90 | 0 |
| 25765 | 58.57 | 58.57 | 59.60 | 59.60 | 0 |

*Modifications made to this cross-section in the Existing Conditions Model

The Existing Conditions Model yields WSEs that are in the range of 1 ft higher than the Effective and Duplicate Effective Models, with the maximum increase being 1.11 ft. higher at cross-section 28030, which is approximately 500 ft downstream from the Hillsdale Substation. This increase is largely due to the increase in flows taken from the FEMA study (document 5) but also partially due to updated survey information used at the Hillsdale Substation site.

The Proposed Conditions Model includes the flood protection on the east bank of the model. As discussed above, the updated topography in the Existing Conditions model places the flood protection wall almost entirely outside of the effective 100-year floodplain. As a result there is only a 0.01 ft rise at cross section 28620 for the 100-year flood WSEs due to the proposed flood protection wall.

Modeling results indicate that the 100-year flood does not reach elevations in excess of 63 ft and under existing conditions; the site should be safe from flooding during a 100-year event, since the most recent survey puts the general site elevation at 63 ft. This finding contradicts what is shown on the FEMA map. The intent of this project is to use the updated 2012 survey data to supplement and refine the model development. The proposed flood protection wall has no impact on upstream water surface elevations for events less than or equal to the 100-year flood.

However, under existing conditions the Flood Hazard flow water surface elevation will overtop the 63 ft contour and flow across the site unless flood protection measures are taken. In this case, the eastern portion of cross-section 28830 will effectively convey flow and the entire site will experience flooding.

Table 2 presents the results for the NJDEP Flood Hazard Criteria with the Duplicate Effective flow of 3,341 cfs and the updated increased flow of 4,556 cfs for the Existing and Proposed Conditions Models. River stations in bold indicate the additional cross-sections added to the model at the site.

Table2: Hydraulic Model Results – NJDEP Flood Hazard Flows

(Duplicate Effective Flow 3,431 cfs and Existing and Proposed Conditions Flow 4,556 cfs)

| River Station | 2 Duplicate Effective (ft) | 3 Existing Conditions (ft) | 4 Proposed Conditions (ft) | (4-3) Difference (ft) |
|---------------|-------------------------------------|-------------------------------------|-------------------------------------|-----------------------------|
| 30500 | 66.08 | 66.78 | 66.81 | 0.03 |
| 30490 | 66.02 | 66.71 | 66.74 | 0.03 |
| 30448 | 65.88 | 66.51 | 66.54 | 0.03 |
| 30030 | 65.34 | 65.98 | 66.03 | 0.05 |
| 29555 | 63.67 | 64.52 | 64.79 | 0.27 |
| 28830 | 62.61 | 63.92 | 63.84 | -0.08 |
| 28792 | n/a | 63.64 | 63.66 | 0.02 |
| 28706 | n/a | 63.54 | 63.54 | 0 |
| 28620 | 62.44 | 63.58 | 63.59 | 0.01 |
| 28575 | n/a | 63.55 | 63.55 | 0 |
| 28290 | 61.94 | 63.14 | 63.14 | 0 |
| 28030 | 61.55 | 62.80 | 62.80 | 0 |
| 27715 | 61.21 | 62.44 | 62.44 | 0 |
| 27145 | 60.82 | 62.04 | 62.04 | 0 |
| 26615 | 60.02 | 61.19 | 61.19 | 0 |
| 26595 | 60.02 | 61.19 | 61.19 | 0 |
| 26575 | Hillsdale Avenue Bridge | | | |
| 26555 | 59.99 | 61.16 | 61.16 | 0 |
| 26495 | 59.75 | 60.91 | 60.91 | 0 |

| | | | | |
|-------|-------|-------|-------|---|
| 26150 | 59.66 | 60.84 | 60.84 | 0 |
| 25765 | 59.36 | 60.53 | 60.53 | 0 |

Based on model results, the proposed sheetpile flood wall around the Hillsdale Substation will have a maximum impact of a 0.27 ft rise on the water surface elevation in the Pascack Brook Floodplain under Flood Hazard Flow Conditions. This occurs approximately 750 ft upstream from the site at cross-section 29555. The next cross-section 500 ft further upstream shows an increase of only 0.05 ft. An increase of 0.03 ft continues upstream until it reaches the Woodcliff Lake Dam spillway.

The average difference in WSE, for the Flood Hazard flow, between the Duplicate Effective model and the updated Existing Conditions model is approximately 1.2 ft with a maximum of 1.31 ft occurring at the northern edge of the substation site. To reiterate, this rise is primarily due to updated flows but is partially due to updated existing conditions per the 2012 site survey.

3.0 Conclusions and Recommendations


The proposed flood protection facilities will have a maximum impact of 0.27 ft on the updated Existing Conditions occurring approximately 750 ft upstream from the Hillsdale Substation. This increase occurs for the Flood Hazard flow condition. There is only a 0.01 ft rise from the sheetpile floodwall protection for the 100-year event. If PSE&G proceeds with the design and construction of the proposed flood mitigation measures for the Hillsdale Substation, there should be minimal impact to upstream existing structures. Hydraulically and based on the model results, there are no impacts to downstream structures.


The existing conditions model prepared for this study was based on the NJDEP model but was modified to more accurately describe the Hillsdale Substation site based on recent survey data and an updated flow study by FEMA (document 5). The updates to the Existing Conditions model increased water surface elevations above levels from the Duplicate Effective model by a maximum of 1.11 ft for the 100-year event, and 1.31 ft for the Flood Hazard flow. These updates to flows and topography will be addressed during the permitting process and will require approval of the NJDEP and FEMA.

The inundation from Hurricane Irene was greater than the required FEMA 100-year, and the NJDEP Flood Hazard elevations. The site has an approximate elevation of 63 ft. The estimated Flood Hazard elevation in the vicinity of the site is 63.8 ft. However an elevation of approximately 66.0 feet was observed at the site during Hurricane Irene. Hurricane Irene produced a higher water surface elevation than the Flood Hazard model; therefore the Hurricane Irene event is even more conservative than the Flood Hazard event. A one foot of freeboard was applied to the maximum observed flood level occurring during Hurricane Irene for the design of the top of the flood protection wall. This places the top of wall elevation at 67 ft (NAVD 88).


| ELEVATION SUMMARY (FEET NAVD 88) | | | | |
|----------------------------------|------------------|------------------------------------|--------------------------------|-------------------------------|
| Site | Minimum Site EL. | Maximum Observed Flood EL. (PSE&G) | NJDEP Updated Flood Hazard EL. | Proposed Flood Protection EL. |
| Hillsdale | 63 | 66.0 | 63.8 | 67.0 |

The site survey prepared by Dresdner Robin indicates FEMA 100-year and NJDEP Flood Hazard limits that are not in agreement with our analyses. The survey plot references Document 2 listed above, but there is a discrepancy in the resulting values. Black & veatch will contact Dresdner Robin to clarify the issue.






NJDEP XS 28830 – Upstream of northern edge of Hillsdale Substation as modeled in Effective and Duplicate Effective Models. Elevations are in NGVD 29.




NJDEP XS 28830 – Upstream of northern edge of Hillsdale Substation as modeled in Existing Conditions Model. Elevations are in NGVD 29.

Figure 2a: Cross-sectional views (looking downstream) of cross-section 28830 as modeled in NJDEP Effective and Duplicate Effective Models and updated Existing Conditions Model.
 PF1 = FEMA 100-yr flow 3,647 cfs; PF2 = NJDEP Flood Hazard flow 4,556 cfs.




NJDEP XS 28830 – Upstream of northern edge of Hillsdale Substation as modeled in Proposed Conditions Model.
Elevations are in NGVD 29.

Figure 2b: Cross-sectional view (looking downstream) of cross-section 28830 as modeled in Proposed Conditions Model.
PF1 = FEMA 100-yr flow 3,647 cfs; PF2 = NJDEP Flood Hazard flow 4,556 cfs.




Added XS 28792 – North end of Hillsdale Substation as modeled in Existing Conditions Model.
Elevations are in NGVD 29.




Added XS 28792 – North end of Hillsdale Substation as modeled in Proposed Conditions Model.
Elevations are in NGVD 29.

Figure 3: Cross-sectional views (looking downstream) of north end of Hillsdale Substation as modeled in Existing and Proposed Conditions Models and based on 2012 survey.
PF1 = FEMA 100-yr flow 3,647 cfs; PF2 = NJDEP Flood Hazard flow 4,556 cfs.




Added XS 28706 – Center portion of Hillsdale Substation as modeled in Existing Conditions Model.
Elevations are in NGVD 29.




Added XS 28706 – Center portion of Hillsdale Substation as modeled in Proposed Conditions Model.
Elevations are in NGVD 29.

Figure 4: Cross-sectional views (looking downstream) of center portion of Hillsdale Substation as modeled in Existing and Proposed Conditions Models and based on 2012 survey.
 PF1 = FEMA 100-yr flow 3,647 cfs; PF2 = NJDEP Flood Hazard flow 4,556 cfs.




NJDEP XS 28620 – Southern portion of Hillsdale Substation as modeled in Effective and Duplicate Conditions Models. Elevations are in NGVD 29.




NJDEP XS 28620 – Southern portion of Hillsdale Substation as modeled in Existing Conditions Model. Elevations are in NGVD 29.

Figure 5a: Cross-sectional views (looking downstream) of southern portion of Hillsdale Substation as modeled in Effective, Duplicate Effective, and Existing Conditions Models and based on 2012 survey. PF1 = FEMA 100-yr flow 3,647 cfs; PF2 = NJDEP Flood Hazard flow 4,556 cfs.




NJDEP XS 28620 – Southern portion of Hillsdale Substation as modeled in Proposed Conditions Model. Elevations are in NGVD 29.

Figure 5b: Cross-sectional views (looking downstream) of southern portion of Hillsdale Substation as modeled in Proposed Conditions Model and based on 2012 survey.
PF1 = FEMA 100-yr flow 3,647 cfs; PF2 = NJDEP Flood Hazard flow 4,556 cfs.



Added XS 28575 – Southern edge of Hillsdale Substation as modeled in Existing Conditions Model.
Elevations are in NGVD 29.



Added XS 28575 – Southern Edge of Hillsdale Substation as modeled in Proposed Conditions Model.
Elevations are in NGVD 29.

Figure 6: Cross-sectional views (looking downstream) of southern edge of Hillsdale Substation as modeled in Existing and Proposed Conditions Models and based on 2012 survey.
PF1 = FEMA 100-yr flow 3,647 cfs; PF2 = NJDEP Flood Hazard flow 4,556 cfs.

FLOOD IMPACT STUDY FOR RIVER EDGE SUBSTATION

Public Service Electric & Gas

11 OCTOBER 2012



Table of Contents

| | |
|---|----------|
| 1.0 Background | 1 |
| 2.0 Data Review and Hydraulic Modeling | 2 |
| Data Review | 2 |
| Hydraulic Model Scenarios | 3 |
| Hydraulic Model Development | 3 |
| Preliminary Flood Impacts | 5 |
| 3.0 Conclusions and Recommendation | 9 |

1.0 Background

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing significant impact to electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. Based on this and prior flooding events a "Flood Protection Report" was completed for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, 2012). The Report defines the preliminary requirements to provide flood protection at the twelve flood prone substation sites. Since most of the substation sites are located within either the FEMA 100-year floodplain or the defined floodway area, construction of flood protection facilities at these sites could potentially impact upstream flood water elevations.

Flood Impact Studies will be performed for ten of the twelve substation sites, and will be based on the recommendations for flood protection measures included in the Flood Protection Report. Flood impact studies are not required for two of the twelve sites as they are either a) not in the FEMA 100-year floodplain (Bayway) or b) the proposed flood protection facilities will be located behind existing site floodwall protection (Garfield). PSE&G has provided guidance as to the order in which they would like the substations studied. This prioritization is denoted in the list below in parentheses after the substation name. The ten substations to be studied are as follows:

Central Division

1. Cranford Substation (2)
2. Rahway Substation (5)
3. Somerville Substation (6)

Metro Division

4. Belmont Substation (10)
5. Jackson Road Substation (7)

Palisades Division

6. New Milford Switching Station (1)
7. River Edge Substation (4)
8. Hillsdale Substation (3)
9. Marion Switching Station (8)

Southern Division

10. Ewing Substation (9)

This Flood Impact Study addresses the potential for flooding upstream of the River Edge Substation. It describes the upstream flood impacts resulting from construction of the recommended flood protection facilities. It is intended that the results of this study will be used by PSE&G in evaluating the implementation of the flood protection measures at this site. It is recognized that additional flood studies will likely be required to support the permitting process if the recommended mitigation methods are chosen.

The River Edge Substation is located at the end of Main Street East of Hackensack Avenue. There is gated access to the site from Main Street, the only accessible side of the site. The

site covers approximately 0.5 acres, and has no existing flood protection. The site is located at the confluence of the Hackensack River and the small tributary of Coles Brook.

A portion of the River Edge site is located within the floodway, which comprises the river channel and adjacent floodplain that should be kept free of encroachment in accordance with FEMA recommendations. The site is also located within the NJDEP Riparian Buffer Zone.

2.0 Data Review and Hydraulic Modeling

DATA REVIEW

- 1) Heritage Plaza Improved Encroachment: HEC-2 Input and Output Printouts from 22 July 1982 (Coles_Brook_Heritage_Plaza_Improved_7-22-82_FW.pdf)
- 2) River Edge Flood Insurance Study: HEC-2 Input and Output Printouts (Coles_Brook_FW.pdf)
- 3) HEC-2 Input and Output Printouts from 9 April 1981 (Hackensack_River_Amended_Run_FW.pdf)
- 4) HEC-2 Input and Output Printouts from 22 September 2006 (Hackensack_River_New_Milford_FW_Hacknmfy3.pdf)
- 5) Kennon Surveying Services Inc (KSS). Boundary and Topographic Survey – River Edge Substation (29 May 2012)
- 6) NJDEP. Delineation of Floodway and Flood Hazard Area – Hackensack River (Sta. 1002+00 to Sta. 1065+00). March 1980.
- 7) Black & Veatch. 2012 Substation Flood Protection – Summary Evaluation Report. 2 March 2012.

Since the River Edge Substation is located just at the confluence of the Hackensack River with Coles Brook, two separate models of each of these river systems are necessary. The HEC-2 Input and Output printouts, presented as documents 1 and 2 were the basis for development for the Coles Brook model, while the HEC-2 input and output of documents 3 and 4 were the basis for the development of the Hackensack River model. Cross-sectional characteristics were obtained directly from these documents. The site survey (document 5) assisted in determining ground elevations at the site and distances to the river. The delineation map of the floodway (document 6) assisted in locating the cross-sections in the Hackensack Model relative to the substation. The Substation Flood Protection Report (document 7) provided the required height for flood protection measures. The vertical datum for all elevations reported in the HEC-2 files (documents 1 through 4) is NGVD 29, while the vertical datum for documents 5 and 7 is NAVD 88. NAVD 88 is one foot below NGVD 29 levels. All elevations presented in this report unless otherwise noted are NAVD 88, (i.e. cross-section profile views which were taken directly from the HEC-RAS model are in NGVD 29, See Figures 3-7).

The Substation Flood Protection – Summary Evaluation report (document 4), recommends a top elevation for the flood protection wall at the River Edge Substation 2 feet above the 100-year flood level. Based on references 1 and 2, the 100-year flood level in the vicinity of

the site is 6.4 ft (NAVD 88) near its northern edge. This recommendation would yield a top of the wall at 8.4 ft (NAVD 88). Final recommendations for the flood protection height are based on the findings of this hydraulic study and are presented in the Conclusions and Recommendations (Section 3.0).

HYDRAULIC MODEL SCENARIOS

Black & Veatch used the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S Army Corps of Engineers Hydraulic Engineering Center, to develop hydraulic models for both Coles Brook and the Hackensack River in the vicinity of the River Edge Substation. The hydraulic models used for this study were developed from NJDEP's HEC-2 input data.

In order to achieve the goal of this study, four geometry models were considered.

- The first model was the Effective Model. These are the water surface elevations (WSEs) as presented in the results of the HEC-2 printouts. The results of the Effective Model provide the New Jersey Department of Environmental Protection (NJDEP) 100-year flood levels.

The remaining three other models were developed from the Effective model: the Duplicate Effective Model, the Existing Conditions Model, and the Proposed Conditions Model.

- The Duplicate Effective Model is the input data from the HEC-2 files, input into a HEC-RAS model and run to ensure similar results and proper calibration.
- The Existing Conditions Model was based on the Duplicate Effective Model, but includes additional cross-sections in the vicinity of the site and modifications to some cross-sections.
- The Proposed Conditions Model was based on the Existing Conditions Model and includes proposed flood protection.

The flood elevation differences between proposed conditions and existing conditions throughout the modeled length along the river will represent the potential flood impact associated with the proposed improvements.

HYDRAULIC MODEL DEVELOPMENT

As previously indicated, River Edge Substation is located at the confluence of two water bodies: Coles Brook and the Hackensack River. As such, two separate models were required in order to adequately estimate potential flood impacts associated with the proposed improvements. See Figure 1 for site location.

COLES BROOK MODEL DEVELOPMENT

A profile of Coles Brook indicating exact cross-section locations was not provided. Hence, the cross-section locations had to be estimated based on available information within HEC-2 input files. The HEC-2 files indicate that cross-section 1498 is just downstream of the New Bridge Road bridge, while cross-section 145 is the most downstream cross-section in the model and assumed to be 145 feet upstream of the confluence with the Hackensack River.

The distance between the bridge and last cross-section is approximately 1,350 feet. The cross-sections modeled in the NJDEP HEC-2 model are shown in white in Figure 1.

In development of the Existing Conditions Model for Coles Brook (Coles Brook Model 3), cross-sections were added at the site. Three additional cross-sections transecting the River Edge site were added to the Existing Conditions Model. These were based on the KSS site survey (KSS, 2012). The additional cross-sections are shown in yellow on Figure 1.

In development of the Proposed Conditions Model for Coles Brook (Coles Brook Model 4), the proposed flood protection was inserted on the north bank in each of the three added cross-sections.

The following flows were considered:

- 1,900 cfs – Coles Brook FEMA 100-year flood flow in the vicinity of the River Edge Site.
- 2,375 cfs – NJDEP Flood Hazard Limit Criterion = 125% of Coles Brook 100-year flood flow

HACKENSACK RIVER MODEL DEVELOPMENT

A profile of the river indicating several cross-section locations on the Hackensack River in the vicinity of the River Edge site was provided (document 6). Additional information regarding cross-section locations was available within NJDEP's HEC-2 files, including distances between cross-sections and hydraulic structures (bridges). The floodway map (document 6) indicates that cross-section 99600 is just downstream of the confluence with Coles Brook. Cross-section 99860 is just downstream of the Main Street bridge, while cross-section 100150 is just downstream of the New Bridge Road bridge. These cross-sections as well as others from the HEC-2 data files are shown in white in Figure 2.

In development of the Hackensack Existing Conditions Model (Hackensack Model 3), cross-sections were added at the site. Two additional cross-sections transecting the River Edge site were added to the Hackensack Existing Conditions Model. These were based on the KSS site survey (KSS, 2012). The additional cross-sections are shown in yellow on Figure 2.

In development of the Hackensack Proposed Conditions Model (Hackensack Model 4), the proposed flood protection was inserted on the west bank in each of the added cross-sections. The proposed flood protection was modeled as blocked obstructions to flow in the HEC-RAS model.

The following flows were considered:

- 6,900 cfs - The Hackensack River's FEMA 100-year flood flow in the vicinity of the River Edge Site upstream of the confluence with Coles Brook.
- 7,410 cfs - The Hackensack River's FEMA 100-year flood flow in the vicinity of the River Edge Site downstream of the confluence with Coles Brook.
- 8,625 cfs - NJDEP Flood Hazard Limit Criterion = 125% of the Hackensack River, 100-year flood flow upstream of the confluence with Coles Brook

- 9,263 cfs – NJDEP Flood Hazard Limit Criterion = 125% of the Hackensack River, 100-year flood flow downstream of the confluence with Coles Brook

During Hurricane Irene, the River Edge Substation was flooded up to an approximate WSEL of 8 ft. Based on the HEC-RAS model; this would correspond with a Hackensack River flow of approximately 10,200 cfs in the vicinity of the substation just upstream of the confluence and a flow of 11,000 cfs in the vicinity of the substation just downstream of the confluence.

PRELIMINARY FLOOD IMPACTS

COLES BROOK MODEL RESULTS

The Coles Brook Duplicate Effective Model yields results that are equivalent to those of the Effective Model. However, the Existing Conditions Model, which includes additional cross-sections in the vicinity of the site, yielded flood levels that are slightly higher (0.02 feet) than those in the Duplicate Effective Model. Table 1 presents the results for the 100-year flood from the four models considered. River stations in bold indicate the cross-sections added to the model at the site.

Table 1: Hydraulic Model Results – FEMA 100-year Flood Levels (1,900 cfs)

| Model # | 1 | 2 | 3 | 4 | (4-3) |
|----------------------|------------------------|----------------------------|----------------------------|----------------------------|-------------------|
| | Effective Model | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| River Station | (ft) | (ft) | (ft) | (ft) | (ft) |
| 1498 | 5.47 | 5.46 | 5.48 | 5.48 | 0.00 |
| 1448 | 4.88 | 4.93 | 4.95 | 4.95 | 0.00 |
| 1415 | 4.62 | 4.65 | 4.67 | 4.67 | 0.00 |
| 1348 | 4.72 | 4.72 | 4.74 | 4.74 | 0.00 |
| 810 | 4.50 | 4.50 | 4.52 | 4.52 | 0.00 |
| 508 | n/a | n/a | 4.37 | 4.37 | 0.00 |
| 337 | n/a | n/a | 4.02 | 4.02 | 0.00 |
| 196 | n/a | n/a | 3.93 | 3.93 | 0.00 |
| 145 | 3.84 | 3.84 | 3.84 | 3.84 | 0.00 |

The Proposed Conditions Model includes the flood protection along the north bank of the Coles Brook model. A rise in WSEL is not predicted in the vicinity of the site nor further upstream due to the flood protection installation. The River Edge Site has a curb running the majority of the site’s perimeter. This curb is approximately at elevation 7.0 feet, while 100-year flood levels near the site in Coles Brook are approximately elevation 4.4 ft.

Table 2 presents the results for the NJDEP Flood Hazard Criteria with flows at 2,375 cfs. River stations in bold indicate the additional cross-sections added to the model at the site.

Table2: Hydraulic Model Results – NJDEP Flood Hazard Flows (2,375 cfs)

| Model # | 2 | 3 | 4 | (4-3) |
|----------------------|----------------------------|----------------------------|----------------------------|-------------------|
| | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| River Station | (ft) | (ft) | (ft) | (ft) |
| 1498 | 6.29 | 6.32 | 6.32 | 0.00 |
| 1448 | 5.66 | 5.70 | 5.70 | 0.00 |
| 1415 | 5.30 | 5.35 | 5.35 | 0.00 |
| 1348 | 5.40 | 5.45 | 5.45 | 0.00 |
| 810 | 5.17 | 5.24 | 5.24 | 0.00 |
| 508 | n/a | 5.06 | 5.06 | 0.00 |
| 337 | n/a | 4.65 | 4.65 | 0.00 |
| 196 | n/a | 4.58 | 4.58 | 0.00 |
| 145 | 4.47 | 4.48 | 4.48 | 0.00 |

As presented in Table 2 and illustrated in Figures 3 through 5, the Flood Hazard flow for Coles Brook does not yield water levels that reach the River Edge site. While the curb around most of the site is at 7.0 feet, the maximum WSE in the vicinity of the site was estimated to be 5.0 feet for Flood Hazard Flows in Coles Brook. Thus the proposed flood protection wall does not impact water levels in Coles Brook.

HACKENSACK RIVER MODEL RESULTS

The Hackensack River Duplicate Effective Model yields results that are similar to those of the Effective Model. Differences in WSEs arise primarily at bridges (Main Street and New Bridge Road) and are in the range of 0.03 to 0.05 foot.

Table 3 presents the results from the four models considered. River stations in bold indicate the additional cross-sections added to the model at the site.

Table 3: Hydraulic Model Results – FEMA 100-year Flood Levels (6,900 – 7,410 cfs)

| Model # | 1 | 2 | 3 | 4 | (4-3) |
|----------------------|------------------------|----------------------------|----------------------------|----------------------------|-------------------|
| | Effective Model | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| River Station | (ft) | (ft) | (ft) | (ft) | (ft) |
| 108930 | 9.08 | 9.10 | 9.10 | 9.10 | 0.00 |
| 108880 | 9.01 | 9.08 | 9.08 | 9.08 | 0.00 |
| 108580 | 8.99 | 9.03 | 9.03 | 9.03 | 0.00 |
| 108100 | 8.92 | 8.91 | 8.91 | 8.91 | 0.00 |
| 107625 | 8.82 | 8.83 | 8.83 | 8.83 | 0.00 |
| 106850 | 8.64 | 8.66 | 8.66 | 8.66 | 0.00 |
| 106560 | 8.55 | 8.58 | 8.58 | 8.58 | 0.00 |
| 106100 | 8.41 | 8.44 | 8.44 | 8.44 | 0.00 |

| | | | | | |
|--------------|--------------------------|------------|-------------|-------------|-------------|
| 105700 | 8.39 | 8.41 | 8.41 | 8.41 | 0.00 |
| 105080 | 8.25 | 8.26 | 8.26 | 8.26 | 0.00 |
| 104500 | 8.12 | 8.13 | 8.13 | 8.13 | 0.00 |
| 104000 | 8.03 | 8.03 | 8.03 | 8.03 | 0.00 |
| 103365 | 7.75 | 7.74 | 7.74 | 7.74 | 0.00 |
| 102920 | 7.61 | 7.60 | 7.60 | 7.60 | 0.00 |
| 102500 | 7.43 | 7.41 | 7.41 | 7.41 | 0.00 |
| 102050 | 7.41 | 7.39 | 7.39 | 7.39 | 0.00 |
| 101400 | 7.24 | 7.23 | 7.23 | 7.23 | 0.00 |
| 100910 | 7.17 | 7.15 | 7.15 | 7.15 | 0.00 |
| 100490 | 7.12 | 7.10 | 7.10 | 7.10 | 0.00 |
| 100211 | | 7.00 | 7.00 | 7.00 | 0.00 |
| 100210 | New Bridge Road - Bridge | | | | |
| 100150 | 6.61 | 6.56 | 6.56 | 6.56 | 0.00 |
| 100040 | 6.60 | 6.55 | 6.55 | 6.55 | 0.00 |
| 99891 | | 6.42 | 6.42 | 6.42 | 0.00 |
| 99890 | Main Street - Bridge | | | | |
| 99860 | 6.35 | 6.35 | 6.35 | 6.35 | 0.00 |
| 99815 | 6.37 | 6.37 | 6.37 | 6.37 | 0.00 |
| 99760 | n/a | n/a | 6.37 | 6.37 | 0.00 |
| 99660 | n/a | n/a | 6.32 | 6.32 | 0.00 |
| 99600 | 6.26 | 6.26 | 6.26 | 6.26 | 0.00 |
| 99100 | 6.14 | 6.14 | 6.14 | 6.14 | 0.00 |
| 98900 | 6.18 | 6.19 | 6.19 | 6.19 | 0.00 |
| 98300 | 5.88 | 5.89 | 5.89 | 5.89 | 0.00 |
| 97900 | 5.88 | 5.88 | 5.88 | 5.88 | 0.00 |
| 97470 | 5.73 | 5.73 | 5.73 | 5.73 | 0.00 |
| 96900 | 5.70 | 5.70 | 5.70 | 5.70 | 0.00 |

The Existing Conditions Model, which includes additional cross-sections in the vicinity of the site, yielded water levels that are equivalent to those in the Duplicate Effective Model. The River Edge Site has a curb running the majority of the site’s perimeter. This curb is approximately at elevation 7.0 feet, while 100-year flood levels near the site are approximately elevation 6.4 ft. The driveway entrance to the site is approximately elevation 6.5, and the road outside the site would be inundated.

The Proposed Conditions Model includes the flood protection on the west bank of the Hackensack River model. However, as presented in Table 3 and illustrated in Figures 6 and 7, the 100-year flood does not enter the site. Thus the addition of the flood protection wall does not impact 100-year flood levels.

Table 4 presents the results for the NJDEP Flood Hazard Criteria in the Hackensack River with flows at 8,625 cfs upstream of the confluence and 9,263 cfs downstream of the

confluence with Coles Brook. River stations in bold indicate the additional cross-sections added to the model at the site.

Table4: Hydraulic Model Results – NJDEP Flood Hazard Levels (8,625 – 9,263 cfs)

| Model # | 2 | 3 | 4 | (4-3) |
|----------------------|----------------------------|----------------------------|----------------------------|-------------------|
| | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| River Station | (ft) | (ft) | (ft) | (ft) |
| 108930 | 10.05 | 10.05 | 10.05 | 0.00 |
| 108880 | 10.01 | 10.01 | 10.01 | 0.00 |
| 108580 | 9.96 | 9.96 | 9.96 | 0.00 |
| 108100 | 9.85 | 9.85 | 9.85 | 0.00 |
| 107625 | 9.75 | 9.75 | 9.75 | 0.00 |
| 106850 | 9.57 | 9.57 | 9.57 | 0.00 |
| 106560 | 9.49 | 9.49 | 9.49 | 0.00 |
| 106100 | 9.33 | 9.33 | 9.33 | 0.00 |
| 105700 | 9.31 | 9.31 | 9.31 | 0.00 |
| 105080 | 9.16 | 9.16 | 9.16 | 0.00 |
| 104500 | 9.03 | 9.03 | 9.03 | 0.00 |
| 104000 | 8.93 | 8.93 | 8.93 | 0.00 |
| 103365 | 8.67 | 8.67 | 8.67 | 0.00 |
| 102920 | 8.52 | 8.52 | 8.52 | 0.00 |
| 102500 | 8.34 | 8.34 | 8.34 | 0.00 |
| 102050 | 8.32 | 8.32 | 8.32 | 0.00 |
| 101400 | 8.14 | 8.13 | 8.14 | 0.01 |
| 100910 | 8.07 | 8.06 | 8.06 | 0.00 |
| 100490 | 8.02 | 8.02 | 8.02 | 0.00 |
| 100211 | 7.93 | 7.92 | 7.93 | 0.01 |
| 100210 | New Bridge Road - Bridge | | | |
| 100150 | 7.49 | 7.49 | 7.49 | 0.00 |
| 100040 | 7.48 | 7.48 | 7.48 | 0.00 |
| 99891 | 7.39 | 7.39 | 7.39 | 0.00 |
| 99890 | Main Street - Bridge | | | |
| 99860 | 7.36 | 7.35 | 7.35 | 0.00 |
| 99815 | 7.36 | 7.36 | 7.36 | 0.00 |
| 99760 | n/a | 7.32 | 7.32 | 0.00 |
| 99660 | n/a | 7.28 | 7.29 | 0.01 |
| 99600 | 7.20 | 7.20 | 7.20 | 0.00 |
| 99100 | 7.09 | 7.09 | 7.09 | 0.00 |
| 98900 | 7.14 | 7.14 | 7.14 | 0.00 |
| 98300 | 6.79 | 6.79 | 6.79 | 0.00 |
| 97900 | 6.80 | 6.80 | 6.80 | 0.00 |

| | | | | |
|-------|------|------|------|------|
| 97470 | 6.64 | 6.64 | 6.64 | 0.00 |
| 96900 | 6.61 | 6.61 | 6.61 | 0.00 |

Based on model results, the proposed sheetpile flood wall around the River Edge Substation will not impact water surface elevations in the Hackensack River Floodplain under Flood Hazard Flow Conditions. The maximum rise as a result of the sheetpile wall is 0.01 feet under Flood Hazard Flow Conditions.


Black & Veatch modeled the observed flooding condition of approximately EL. 8.0 feet reported by PSE&G during Hurricane Irene. Based on the HEC-RAS model; this would correspond with a Hackensack River flow of approximately 10,200 cfs in the vicinity of the substation just upstream of the confluence and a flow of 11,000 cfs in the vicinity of the substation just downstream of the confluence.



3.0 Conclusions and Recommendation


The proposed flood protection facilities will not impact flooding upstream of the River Edge Substation. If PSE&G proceeds with the design and construction of the proposed flood mitigation measures for the River Edge Substation, there should be little to no impact to upstream existing structures. Hydraulically and based on the model results, there are no impacts to downstream structures.

During Hurricane Irene, a maximum flood level of 8.0 feet was observed at the River Edge site. Based on the results of the hydraulic modeling, we assert that this flooding was due to large flows in the Hackensack River, rather than from Coles Brook. The flow and resulting inundation from Hurricane Irene were greater than the NJDEP Flood Hazard flows in the Hackensack River. An Elevation of 9.0 feet, which is approximately 1 foot above the maximum observed flood level and also over 2 feet above the Black & Veatch estimated Flood Hazard Elevation, was selected as the top of wall design level.


| ELEVATION SUMMARY (FEET NAVD 88) | | | | |
|----------------------------------|------------------|------------------------------------|------------------------|-------------------------------|
| Site | Minimum Site EL. | Maximum Observed Flood EL. (PSE&G) | NJDEP Flood Hazard EL. | Proposed Flood Protection EL. |
| River Edge | 6.5 | 8.0 | 7.3 | 9.0 |








Coles Brook Model- West End of Site (XS 508): Existing conditions.




Coles Brook Model - West End of Site (XS 508): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 3: Cross-sectional view from upstream end of site looking downstream in Coles Brook. PF1 = FEMA 100-yr flow 1,900 cfs; PF2 = NJDEP Flood Hazard flow 2,375 cfs. (Model in NGVD 29)




Coles Brook Model- Middle of Site (XS 337): Existing conditions.




Coles Brook Model – Middle of Site (XS 337): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 4: Cross-sectional view from upstream end of site looking downstream in Coles Brook. PF1 = FEMA 100-yr flow 1,900 cfs; PF2 = NJDEP Flood Hazard flow 2,375 cfs. (Model in NGVD 29)




Coles Brook Model- East End of Site (XS 196): Existing conditions.




Coles Brook Model – East End of Site (XS 196): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 5: Cross-sectional view from upstream end of site looking downstream in Coles Brook. PF1 = FEMA 100-yr flow 1,900 cfs; PF2 = NJDEP Flood Hazard flow 2,375 cfs. (Model in NGVD 29)




Hackensack River Model- North Side of Site (XS 99760): Existing conditions.




Hackensack River Model- North Side of Site (XS 99760): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 6: Cross-sectional view from upstream end of site looking downstream in the Hackensack River. PF1 = FEMA 100-yr flow 6,900 cfs; PF2 = NJDEP Flood Hazard flow 8,625 cfs. (Model in NGVD 29)



Hackensack River Model- South Side of Site (XS 99660): Existing conditions.



Hackensack River Model- South Side of Site (XS 99660): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 7: Cross-sectional view from upstream end of site looking downstream in the Hackensack River. PF1 = FEMA 100-yr flow 7,410 cfs; PF2 = NJDEP Flood Hazard flow 9,263 cfs. (Model in NGVD 29)

FLOOD IMPACT STUDY FOR RAHWAY SUBSTATION

Public Service Electric & Gas

11 OCTOBER 2012



Table of Contents

- 1.0 Background1**
- 2.0 Data Review and Hydraulic Modeling.....2**
 - Data Review 2
 - Hydraulic Model Scenarios 2
 - Hydraulic Model Development 3
 - Preliminary Flood Impacts 4
- 3.0 Conclusions and Recommendation.....8**

1.0 Background

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing significant impact to electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. Based on this and prior flooding events a "Flood Protection Report" was completed for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, 2012). The Report defines the preliminary requirements to provide flood protection at the twelve flood prone substation sites. Since most of the substation sites are located within either the FEMA 100-year floodplain or the defined floodway area, construction of flood protection facilities at these sites could potentially impact upstream flood water elevations.

Flood Impact Studies will be performed for ten of the twelve substation sites, and will be based on the recommendations for flood protection measures included in the Flood Protection Report. Flood impact studies are not required for two of the twelve sites as they are either a) not in the FEMA 100-year floodplain (Bayway) or b) the proposed flood protection facilities will be located behind existing site floodwall protection (Garfield). PSE&G has provided guidance as to the order in which they would like the substations studied. This prioritization is denoted in the list below in parentheses after the substation name. The ten substations to be studied are as follows:

Central Division

1. Cranford Substation (2)
2. Rahway Substation (5)
3. Somerville Substation (6)

Metro Division

4. Belmont Substation (10)
5. Jackson Road Substation (7)

Palisades Division

6. New Milford Switching Station (1)
7. River Edge Substation (4)
8. Hillsdale Substation (3)
9. Marion Switching Station (8)

Southern Division

10. Ewing Substation (9)

This Flood Impact Study addresses the potential for flooding upstream of the Rahway Substation. It describes the upstream flood impacts resulting from construction of the recommended flood protection facilities. It is intended that the results of this study will be used by PSE&G in evaluating the implementation of the flood protection measures at this site. It is recognized that additional flood studies will likely be required to support the permitting process if the recommended mitigation methods are chosen.

The station is located across Clarkson Place from the Rahway River, in an urban residential/industrial area. The river in this area is well below the street elevation and has

steep banks. The substation has two gated access points from Monroe Street, and access is generally open along Clarkson Place. The east side of the site is graded higher, at the same elevation as the station building, and the site has a total area of approximately 0.75 acres. The site is located within the NJDEP Riparian Buffer Zone.

2.0 Data Review and Hydraulic Modeling

DATA REVIEW

The following documents were utilized in the development of the hydraulic model for the Rahway Substation.

- 1) NJDEP. HEC-RAS model for the Rahway River from 13 November 2002 (111302Rahway.prj)
- 2) NJDEP. Delineation of Floodway and Flood Hazard Area: Plans – City of Rahway, NJ.
- 3) Kennon Surveying Services, Inc (KSS). Boundary and Topographic Survey - Rahway Substation (29 May 2012)
- 4) Black & Veatch (B&V). 2012 Substation Flood Protection – Summary Evaluation Report. 2 March 2012.

NJDEP's Rahway HEC-RAS model (document 1) was the basis of the model development. The site survey (document 3) assisted in determining ground elevations at and around the site and distances to the river. The Substation Flood Protection Report (document 4) provided the estimated height for the flood protection measures. The vertical datum for all elevations reported in the HEC-RAS model (document 1) is NGVD 29, while the vertical datum for documents 3 and 4 is NAVD 88. NAVD 88 is one foot below NGVD 29 elevations. All elevations presented in this report unless otherwise noted are NAVD 88, (i.e. cross section profile views which were taken directly from the HEC-RAS model are in NGVD 29. (See Figures 2-7).

The Substation Flood Protection – Summary Evaluation report (document 4), recommends a top elevation for the flood protection wall at the Rahway Substation 2 feet above the 100-year flood level. Based on references 1 and 2, the 100-year flood level in the vicinity of the site is 11.8 ft (NAVD 88) near its northern edge. This recommendation would yield a top of the wall at 14 ft (NAVD 88). Final recommendations for the flood protection height are based on the findings of this hydraulic study and are presented in the Conclusions and Recommendations (Section 3.0).

HYDRAULIC MODEL SCENARIOS

Black & Veatch used the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S. Army Corps of Engineers Hydraulic Engineering Center, to develop a hydraulic model for the Rahway River in the vicinity of the Rahway Substation. The hydraulic model used for this study was a copy of NJDEP's HEC-RAS floodway model for the entire Rahway River.

In order to achieve the goal of this study, four geometry models were considered.

- The first model was the Effective Model. This model is the HEC-RAS model with its saved results as provided by NJDEP. The results of the Effective Model provide the New Jersey Department of Environmental Protection (NJDEP) 100-year flood levels.

The remaining three other models were copies of NJDEP's HEC-RAS model: the Duplicate Effective Model, the Existing Conditions Model, and the Proposed Conditions Model.

- The Duplicate Effective Model is a copy of the NJDEP HEC-RAS model with no modifications, but rerun to ensure similar results and proper calibration.
- The Existing Conditions Model was based on the Duplicate Effective Model, but includes additional cross-sections in the vicinity of the site and modifications to some cross-sections.
- The Proposed Conditions Model was based on the Existing Conditions Model and includes proposed flood protection.

The flood elevation differences between proposed conditions and existing conditions throughout the modeled length along the river will represent the potential flood impact associated with the proposed improvements.

HYDRAULIC MODEL DEVELOPMENT

A profile of the river indicating exact cross-section locations was not provided. Hence, the cross-section locations had to be estimated based on available information within NJDEP's HEC-RAS model. The existing NJDEP model indicates that cross-section 5.168 is just downstream of the Bridge Street Bridge, while cross-section 5.115 is at the upstream face of the Monroe Street Bridge. The distance between the two bridges is approximately 280 feet. Rahway Substation lies along the eastern bank (left bank) within this reach. These cross-sections and Rahway Substation are shown in white in Figure 1.

In development of the Existing Conditions Model (Rahway Model 3), cross-sections were added at the site and/or modifications were made to the NJDEP cross-sections. NJDEP cross-section 5.124 was extended on the east bank (left bank) based on recent site survey data (KSS, 2012). Modifications to XS 5.124 are illustrated on Figure 2.

Modified and added cross-sections are shown in yellow on Figure 1. Cross-section 5.154 was also added and runs north of the Rahway site. It was necessary to include this cross-section as there is an existing building that will impede flows onto the site, reducing the effective flow area upstream of the site. Figures 2 through 7 present the profiles of added cross-sections transecting the Rahway Substation site.

Ineffective flow areas are presented as the green hatched areas on the cross-sections. In some of the cross-sections, ineffective flow is indicated in areas which would likely experience flooding, however, the flow would have little to no velocity. In these instances, the green-hatched area experiences pooled water, which is typical at the edges of flood plains. Existing buildings are shown as obstructions in the cross-section profiles.

Although the bridge at Monroe Street was reconstructed in 2010, the bridge decking in the HEC-RAS model was not modified as drawings of the new bridge were not readily available.

However, the bridge cross-sections were extended along the east side to reflect recent survey data (KSS, 2012). Survey information did not extend to the west side of the bridge. In the Effective Model, the bridge decking was modeled at elevation 15.7 ft across the entire width of the cross-section. Thus flows in this model cannot weir over Monroe Street, unless they exceed an elevation of 15.7 feet. Rather all flow is forced through the bridge opening. This approach is a good conservative approach for determining floodplains where loss of life and property are at risk. However, based on 2012 survey data (KSS, 2012), the road deck is actually much lower than 15.7 feet and in reality, the City of Rahway could expect flooding over Monroe Street. This can also be seen on the NJDEP Delineation of Floodway and Flood Hazard Area Map, (Document 2). Additionally, during a site visit it was noted that the new bridge has only one pier, while the model indicates that it has two piers. Figure 3 presents the Monroe Street Bridge as modeled in the Duplicate Effective (NJDEP) and Existing Conditions Models, respectively.

In development of the Proposed Conditions Model (Rahway Model 4), the proposed flood protection was inserted on the east bank in each of the added cross-sections that transect the site. At the south end of the Rahway Substation Site, where the sheet piling would end, effective flow is allowed to expand out to Monroe Street at a 1:1 ratio.

The following flows were considered:

- 8,330 cfs - The Rahway River's FEMA 100-year flood flow in the vicinity of the Rahway Site.
- 10,413 cfs - NJDEP Flood Hazard Limit Criterion = 125% of the Rahway River, 100-year flood flow

During Hurricane Irene, the Rahway Substation was flooded up to an approximate WSEL of 13.0 ft. Based on the HEC-RAS model; this would correspond with a Rahway River flow 11,800 cfs in the vicinity of the substation.

PRELIMINARY FLOOD IMPACTS

The Duplicate Effective Model yields results that are nearly equivalent to those of the Effective Model. However, the Existing Conditions Model, which includes additional cross-sections in the vicinity of the site and modification to the road decking at Monroe Street, yielded flood levels that are lower than those in the Duplicate Effective Model. It is our belief that our Existing Conditions Model more accurately describes the potential for flooding upstream of Monroe Street Bridge than the NJDEP model. In the NJDEP model, the Monroe Street Bridge decking was set to an elevation of 15.7 feet across the entire cross-section. As a result, flood flows were only able to pass through the bridge opening under pressurized flow conditions. Thus the effective flow area was also restricted to the river banks.

As indicated, the Monroe Street Bridge was reconstructed in 2010. Recent survey information indicates that flood flows will overtop Monroe Street, around the bridge abutments rather than be confined to the river channel as indicated in the NJDEP model. The bridge itself is not overtopped. This change impacts flood levels in the vicinity of Rahway Substation.

Table 1 presents the results from the four models considered. River stations in bold indicate the additional cross-sections added to the model at the site.

Table 1: Hydraulic Model Results – FEMA 100-year Flood Levels (8,330 cfs)

| River Station | 1 | 2 | 3 | 4 | (4-3) |
|----------------|-----------------------------|---------------------|---------------------|---------------------|-------------|
| | Effective Model | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 5.4185 | West Grand Avenue - Bridge | | | | |
| 5.413 | 13.35 | 13.34 | 12.16 | 12.89 | 0.73 |
| 5.366 | 13.38 | 13.36 | 12.21 | 12.93 | 0.72 |
| 5.343 | 13.28 | 13.27 | 12.06 | 12.81 | 0.75 |
| 5.295 | 13.27 | 13.25 | 12.02 | 12.79 | 0.77 |
| 5.286 | 12.89 | 12.87 | 11.62 | 12.40 | 0.78 |
| 5.2795 | Elizabeth Avenue - Bridge | | | | |
| 5.273 | 12.65 | 12.63 | 11.35 | 12.16 | 0.81 |
| 5.267 | 12.78 | 12.77 | 11.47 | 12.29 | 0.82 |
| 5.209 | 12.45 | 12.44 | 11.09 | 11.94 | 0.85 |
| 5.2 | 12.43 | 12.42 | 11.06 | 11.92 | 0.86 |
| 5.1895 | Railroad Bridge | | | | |
| 5.179 | 12.34 | 12.32 | 10.93 | 11.81 | 0.88 |
| 5.173 | 12.39 | 12.37 | 11.00 | 11.87 | 0.87 |
| 5.1705 | Bridge Street - Bridge | | | | |
| 5.168 | 11.90 | 11.88 | 10.94 | 11.40 | 0.46 |
| 5.165 | 11.81 | 11.84 | 10.95 | 11.42 | 0.47 |
| 5.154 | n/a | n/a | 10.83 | 11.31 | 0.48 |
| 5.145 | n/a | n/a | 10.84 | 11.30 | 0.46 |
| 5.132 | n/a | n/a | 10.41 | 10.88 | 0.47 |
| * 5.124 | 11.42 | 11.42 | 10.40 | 10.80 | 0.40 |
| 5.117 | n/a | n/a | 10.40 | 10.75 | 0.35 |
| *5.115 | 11.28 | 11.28 | 10.23 | 10.72 | 0.49 |
| *5.109 | Monroe Street - Bridge | | | | |
| 5.103 | 9.10 | 9.09 | 9.39 | 9.10 | -0.29 |
| 5.096 | 8.91 | 8.91 | 8.91 | 8.91 | 0.00 |
| 4.985 | 8.75 | 8.75 | 8.75 | 8.75 | 0.00 |
| 4.856 | 8.60 | 8.60 | 8.60 | 8.60 | 0.00 |
| 4.847 | 8.58 | 8.58 | 8.58 | 8.58 | 0.00 |
| 4.843 | East Milton Avenue - Bridge | | | | |
| 4.839 | 8.37 | 8.36 | 8.36 | 8.36 | 0.00 |
| 4.835 | 8.34 | 8.34 | 8.34 | 8.34 | 0.00 |
| 4.73 | 8.36 | 8.35 | 8.35 | 8.35 | 0.00 |
| 4.616 | 8.29 | 8.28 | 8.28 | 8.28 | 0.00 |

| | | | | | |
|-------------------------------------|------|------|------|------|------|
| 4.547 | 8.20 | 8.19 | 8.19 | 8.19 | 0.00 |
| *Indicates a modified cross-section | | | | | |

The Existing Conditions Model yields WSEs that are approximately 1 foot lower than the Effective and Duplicate Effective models in the vicinity of Rahway Substation (at XS 5.124). Approximately ½ mile upstream, the Existing Conditions Model yields WSEs that are approximately 0.16 foot lower than the Duplicate Effective Model and 1 mile upstream, the Existing Conditions WSEs are 0.11 foot lower. There is no difference in WSEs upstream of the St. George’s Avenue Bridge.

The Proposed Conditions Model includes the flood protection on the east bank of the model. A rise in WSEL is noted in the reach immediately adjacent to the site under 100-year flow conditions due to the flood protection installation. In the Rahway Substation reach, a maximum rise of 0.48 foot is noted at XS 5.154. However, further upstream, slightly larger rises are predicted. A rise of 0.88 feet is estimated for XS 5.179 which is just downstream of the Railroad Bridge. This increase in water rise moving upstream is due to the additional head losses at upstream bridges as a result of higher downstream WSEs. The water surface profile is under backwater control conditions.

Approximately ½ mile upstream of the Rahway site, the Proposed Conditions Model yields WSEs that are approximately 0.25 foot higher than the Existing Conditions Model. This rise of 0.25 foot is persistent further upstream until the St George’s Avenue Bridge. There is no rise in WSEs upstream of the St George’s Avenue Bridge.

Table 2 presents the results for the NJDEP Flood Hazard Criteria with flows at 10,413 cfs. River stations in bold indicate the additional cross-sections added to the model at the site.

Table2: Hydraulic Model Results – NJDEP Flood Hazard Flows (10,413 cfs)

| River Station | 2 | 3 | 4 | (4-3) |
|----------------------|----------------------------|----------------------------|----------------------------|-------------------|
| | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) |
| 5.4185 | West Grand Avenue - Bridge | | | |
| 5.413 | 16.66 | 14.96 | 15.95 | 0.99 |
| 5.366 | 16.67 | 14.98 | 15.96 | 0.98 |
| 5.343 | 16.61 | 14.89 | 15.89 | 1.00 |
| 5.295 | 16.62 | 14.88 | 15.89 | 1.01 |
| 5.286 | 16.61 | 14.88 | 15.88 | 1.00 |
| 5.2795 | Elizabeth Avenue - Bridge | | | |
| 5.273 | 15.69 | 13.70 | 14.78 | 1.08 |
| 5.267 | 15.68 | 13.83 | 14.78 | 0.95 |
| 5.209 | 15.32 | 13.35 | 14.37 | 1.02 |
| 5.2 | 15.30 | 13.33 | 14.34 | 1.01 |
| 5.1895 | Railroad Bridge | | | |
| 5.179 | 15.22 | 13.20 | 14.24 | 1.04 |

| | | | | |
|----------------|-----------------------------|--------------|--------------|-------------|
| 5.173 | 15.28 | 13.28 | 14.31 | 1.03 |
| 5.1705 | Bridge Street - Bridge | | | |
| 5.168 | 14.34 | 12.44 | 13.41 | 0.97 |
| 5.165 | 14.31 | 12.47 | 13.45 | 0.98 |
| 5.154 | n/a | 12.34 | 13.34 | 1.00 |
| 5.145 | n/a | 12.35 | 13.33 | 0.98 |
| 5.132 | n/a | 12.04 | 13.01 | 0.97 |
| * 5.124 | 14.08 | 12.06 | 12.95 | 0.89 |
| 5.117 | n/a | 12.07 | 12.90 | 0.83 |
| *5.115 | 14.05 | 11.96 | 12.90 | 0.94 |
| *5.109 | Monroe Street - Bridge | | | |
| 5.103 | 10.23 | 10.98 | 10.40 | -0.58 |
| 5.096 | 10.12 | 10.12 | 10.12 | 0.00 |
| 4.985 | 10.01 | 10.01 | 10.01 | 0.00 |
| 4.856 | 9.86 | 9.86 | 9.86 | 0.00 |
| 4.847 | 9.84 | 9.84 | 9.84 | 0.00 |
| 4.843 | East Milton Avenue - Bridge | | | |
| 4.839 | 9.41 | 9.41 | 9.41 | 0.00 |
| 4.835 | 9.38 | 9.38 | 9.38 | 0.00 |
| 4.73 | 9.43 | 9.43 | 9.43 | 0.00 |
| 4.616 | 9.36 | 9.36 | 9.36 | 0.00 |
| 4.547 | 9.28 | 9.28 | 9.28 | 0.00 |

Based on model results, the proposed sheetpile flood wall around the Rahway Substation will impact water surface elevations in the Rahway River Floodplain under Flood Hazard Flow Conditions. The maximum rise as a result of the sheetpile wall in the Rahway Substation reach is 1.00 feet under Flood Hazard Flow Conditions (XS 5.154). However, further upstream, slightly larger rises are predicted. A rise of 1.08 feet is estimated for XS 5.273 which is just downstream of the Elizabeth Avenue Bridge. This increase in water rise moving upstream is due to the additional head losses at upstream bridges as a result of higher downstream WSEs. The water surface profile is under backwater control conditions.

Approximately ½ mile upstream of the Rahway site, the Proposed Conditions Model yields WSEs that are approximately 0.5 foot higher than the Existing Conditions Model. At one mile upstream, WSEs are 0.25 foot higher in the Proposed Conditions Model. There is no difference in WSEs upstream of the Valley Road Bridge.

Black & Veatch modeled the observed flooding condition of EL. 13 feet reported by PSE&G during Hurricane Irene. In order to realize an inundation of that depth at the site, a flow of approximately 11,800 cfs would be necessary. A peak flow of 7,250 cfs was recorded at USGS gauge 01395000 (Rahway River at Rahway, NJ). This gauge is located 100 feet upstream of St George Avenue, approximately 1.1 miles upstream of the Rahway site. The flows and water surface elevations recorded during Hurricane Irene were the new peak of record (in excess of the 100 year storm event).

3.0 Conclusions and Recommendation


The proposed flood protection facilities will impact flooding upstream of the Rahway Substation. Should PSE&G proceed with the design and construction of the proposed flood mitigation measures for the Rahway Substation, upstream existing structures will be impacted. Hydraulically and based on the model results, there are no impacts to downstream structures.

However, the proposed conditions WSELs are less than or equal to the most recent NJDEP models, that have not been applied to the flood mapping for the area. Further, we have concluded that those models do not accurately assess the effects of the Monroe Street Bridge on the river flow. The end result is that while there is an increase in WSEL with the addition of the flood protection, it is essentially the small WSEL that is currently mapped by the NJDEP.

The existing conditions model prepared for this study was based on the NJDEP model but was modified to more accurately describe Monroe Street based on recent survey data. The updates resulted in a decrease in predicted flood levels. For the 100-year flood, water surface elevations in the reach immediately adjacent to the Rahway Substation decreased by 1 foot. This finding will be addressed during the permitting process, if PSE&G proceed with design, and will require approval of the NJDEP and FEMA.

The flow and inundation from Hurricane Irene were greater than the required FEMA 100-year, and nearly equivalent to the NJDEP Flood Hazard flows. An elevation of 14.33 feet, which is approximately 1 foot above the NJDEP Flood Hazard Elevation, was selected as the top of wall design level.

| ELEVATION SUMMARY (FEET NAVD 88) | | | | |
|----------------------------------|------------------|------------------------------------|------------------------|-------------------------------|
| Site | Average Site EL. | Maximum Observed Flood EL. (PSE&G) | NJDEP Flood Hazard EL. | Proposed Flood Protection EL. |
| Rahway | 10 | 13.0 | 13.33 | 14.33 |









Figure 2: Cross-sectional views (looking downstream) at cross-section 5.124
 PF1 = FEMA 100-yr flow 8,330 cfs; PF2 = NJDEP Flood Hazard flow 10,410 cfs
 Page 239



Monroe Street Bridge as modeled in Effective and Duplicate Effective Models



Monroe Street Bridge as modeled in Existing Conditions and Proposed Conditions Models

Figure 3: Cross-sectional views (looking downstream) of Monroe Street Bridge
 PF1 = FEMA 100-yr flow 8,330 cfs; PF2 = NJDEP Flood Hazard flow 10,413 cfs
 Page 240







Figure 4: Cross-sectional view from upstream (north) side of site looking downstream.
PF1 = FEMA 100-yr flow 8,330 cfs; PF2 = NJDEP Flood Hazard flow 10,410 cfs




Middle of Site (XS 5.132): Existing Conditions.




Middle of Site (XS 5.132): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 5: Cross-sectional view from middle of site (XS 5.132) looking downstream.

PF1 = FEMA 100-yr flow 8,330 cfs; PF2 = NJDEP Flood Hazard flow 10,413 cfs




Middle of Site (XS 5.124): Existing Conditions.




Middle of Site (5.124): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 6: Cross-sectional view from XS 5.124 looking downstream.
 PF1 = FEMA 100-yr flow 8,330 cfs; PF2 = NJDEP Flood Hazard flow 10,413 cfs.



South End of Site (XS 5.117): Existing Conditions.



South End of Site (XS 5.117): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 7: Cross-sectional view from XS 5.117 looking downstream.
 PF1 = FEMA 100-yr flow 8,330 cfs; PF2 = NJDEP Flood Hazard flow 10,413 cfs
 Page 244

FLOOD IMPACT STUDY FOR SOMERVILLE SUBSTATION

Public Service Electric & Gas

11 OCTOBER 2012



Table of Contents

- 1.0 Background 1**
- 2.0 Data Review and Hydraulic Modeling..... 2**
 - Data Review 2
 - Hydraulic Model Scenarios 3
 - Hydraulic Model Development 3
 - Preliminary Flood Impacts 5
- 3.0 Conclusions and Recommendation..... 7**

1.0 Background

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing significant impact to electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. Based on this and prior flooding events a "Flood Protection Report" was completed for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, 2012). The Report defines the preliminary requirements to provide flood protection at the twelve flood prone substation sites. Since most of the substation sites are located within either the FEMA 100-year floodplain or the defined floodway area, construction of flood protection facilities at these sites could potentially impact upstream flood water elevations.

Flood Impact Studies will be performed for ten of the twelve substation sites, and will be based on the recommendations for flood protection measures included in the Flood Protection Report. Flood impact studies are not required for two of the twelve sites as they are either a) not in the FEMA 100-year floodplain (Bayway) or b) the proposed flood protection facilities will be located behind existing site floodwall protection (Garfield). PSE&G has provided guidance as to the order in which they would like the substations studied. This prioritization is denoted in the list below in parentheses after the substation name. The ten substations to be studied are as follows:

Central Division

1. Cranford Substation (2)
2. Rahway Substation (5)
3. Somerville Substation (6)

Metro Division

4. Belmont Substation (10)
5. Jackson Road Substation (7)

Palisades Division

6. New Milford Switching Station (1)
7. River Edge Substation (4)
8. Hillsdale Substation (3)
9. Marion Switching Station (8)

Southern Division

10. Ewing Substation (9)

This Flood Impact Study addresses the potential for flooding upstream of the Somerville Substation. It describes the upstream flood impacts resulting from construction of the recommended flood protection facilities. It is intended that the results of this study will be used by PSE&G in evaluating the implementation of the flood protection measures at this site. It is recognized that additional flood studies will likely be required to support the permitting process if the recommended mitigation methods are chosen.

The Somerville Substation is located about 700 feet north of the Route 206 and S. Bridge Street intersection, Somerville, NJ, 08876 and is approximately 2 acres. The site is bounded

by SAS Medical Arts to the southwest; S. Bridge Street to the east; and a cemetery to the north. There are many overhead power lines in and around the site with the lowest point approximately 25-ft above grade. There is gated access to the site from S. Bridge St and it is generally open around the property. The Raritan River lies to the south of the site and flows from west to east. US Hwy 206 serves as an upstream barrier preventing flood flows from flowing across the site. However, flooding of the site is possible from flood flows in the Raritan River adjacent to and downstream of the site.

2.0 Data Review and Hydraulic Modeling

DATA REVIEW

The following documents were utilized in the development of the hydraulic model for the Somerville Substation.

- 1) USGS Computer Program E431 Input Printouts from 30 Jan 1997 (RARITAN_RIV_HILLSBOROUGH_USGS_INPUT.pdf)
- 2) USGS Computer Program E431 Output Printouts from 30 Jan 1997 (RARITAN_RIV_HILLSBOROUGH_USGS_RUN.pdf)
- 3) PSE&G Services Corporation – Surveys & Mapping. Boundary and Topographic Survey – Somerville Substation (23 April 2012)
- 4) NJDEP. Delineation of Floodway and Flood Hazard Area – Borough of Somerville: Raritan River. January 1986.
- 5) Black & Veatch. 2012 Substation Flood Protection – Summary Evaluation Report. 2 March 2012.

The USGS Computer Program E431 input printout from the 1997 Raritan River model (document 1) was the basis of the model development, while the output printouts (document 2) provided model results for the NJDEP 100-year flood plain and floodway. The site survey (document 3) assisted in determining ground elevations at and around the site (see Figure 2). The Substation Flood Protection Report (document 5) provided the estimated height for the flood protection measures. The vertical datum for all elevations reported in the USGS Computer Program E431 model printouts (documents 1 and 2) is NGVD 29, while the vertical datum for documents 3 and 5 is NAVD 88. NAVD 88 is one foot below NGVD 29 elevations. All elevations presented in this report are NAVD 88 unless otherwise noted (i.e. Figures 3 through 5, which are based on model data from documents 1 and 2).

The Substation Flood Protection – Summary Evaluation Report (document 5), recommends a top elevation for the flood protection wall at the Somerville Substation 2 feet above the 100-year flood level. Based on references 1 and 2, the 100-year flood level in the vicinity of the site is 46.5 ft (NAVD 88). This recommendation would yield a top of the wall at 48.5 ft (NAVD 88). Final recommendations for the flood protection height are based on the findings of this hydraulic study and are presented in the Conclusions and Recommendations (Section 3.0).

HYDRAULIC MODEL SCENARIOS

Black & Veatch used the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S. Army Corps of Engineers Hydraulic Engineering Center, to develop a hydraulic model for the Raritan River in the vicinity of the Somerville Substation. The hydraulic model used for this study was a copy of NJDEP's HEC-RAS floodway model for the entire Raritan River.

In order to achieve the goal of this study, four geometry models were considered.

- The first model was the Effective Model. This model is the USGS E431 model and the corresponding reported results in the USGS E431 output file. The results of the Effective Model provide the New Jersey Department of Environmental Protection (NJDEP) 100-year flood levels.

The remaining three other models were prepared from information in the USGS E431 model printouts: the Duplicate Effective Model, the Existing Conditions Model, and the Proposed Conditions Model.

- The Duplicate Effective Model is the input data from the USGS E431 input file, input into a HEC-RAS model and run to ensure similar results and proper calibration.
- The Existing Conditions Model was based on the Duplicate Effective Model, but includes additional cross-sections in the vicinity of the site and modifications to some cross-sections and bridges.
- The Proposed Conditions Model was based on the Existing Conditions Model and includes proposed flood protection.

The flood elevation differences between proposed conditions and existing conditions throughout the modeled length along the river will represent the potential flood impact associated with the proposed improvements.

HYDRAULIC MODEL DEVELOPMENT

A profile of the river indicating exact cross-section locations was not provided to aid in the development of the HEC-RAS models relative to the Somerville Substation site. Hence, the cross-section locations had to be estimated based on available information within USGS E431 model printout (Effective Model), NJDEP Delineation of Floodway and Flood Hazard Area Map, (Document 4), and aerial imagery in Google Earth. Information in the Effective Model indicates that cross-section 136850 is just downstream of the US Hwy 206 Bridge. After estimating the location of this cross-section, all other cross-section locations in the model were estimated from distances between cross-sections as reported in the Effective Model. Somerville Substation lies along the northern bank (left bank) of the Raritan River just downstream of the US Hwy 206 Bridge. Somerville Substation and the estimated river model layout are shown in Figure 1.

In addition to the US Hwy 206 Bridge, the Effective Model also indicates that there is a railroad bridge approximately 1,500 feet upstream of the US Hwy 206 Bridge. In order to calibrate the Duplicate Effective Model to the Effective Model results, the expansion

coefficients at the upstream cross-sections of the bridges was set to 0.1 and 0.24 for the railroad and US Hwy 206 bridges, respectively.

In development of the Existing Conditions Model (Somerville Model 3), the following changes were implemented:

- the US Hwy 206 bridge geometry was modified
- expansion and contraction coefficients at the US Hwy 206 bridge were modified
- the railroad bridge (1,500 feet upstream of US Hwy 206 bridge) was deleted
- cross-sections were added in the vicinity of the site

The bridge at US Hwy 206 was reconstructed in 2003. The bridge characteristics were modified based on available information. Figure 3 presents the US Hwy 206 Bridge as modeled in the Duplicate Effective (NJDEP) and Existing Conditions Models, respectively. As well, the contraction and expansion coefficients in the Existing Conditions Model were set to 0.3 and 0.5 respectively for the cross-sections immediately upstream and downstream of the US Hwy 206 Bridge. These values are in line with standard recommended values for most bridges.

The Effective Model indicates that there was a railroad bridge approximately 1,500 feet upstream of the US Hwy 206 Bridge; however, recent aerial imagery indicates that this bridge has been removed. The railroad bridge was deleted for the Existing Conditions Model.

Two additional cross-sections transecting the Somerville site were added to the Existing Conditions Model. These were based on the PSE&G site survey as shown in Figure 2 (PSEG, 2012). Added cross-sections are shown in yellow on Figure 1. Figures 4 and 5 present the profiles of the two added cross-sections transecting the Somerville Substation site.

In development of the Proposed Conditions Model (Somerville Model 4), the proposed flood protection was inserted on the east bank in each of the added cross-sections that transect the site. It is represented as a blocked obstruction in the HEC-RAS models and can be visualized in Figures 4 and 5.

The following flows were considered:

- 40,600 cfs - The Raritan River's FEMA 100-year flood flow in the vicinity of the Somerville Site.
- 50,750 cfs - NJDEP Flood Hazard Limit Criterion = 125% of the Raritan River, 100-year flood flow.

During Hurricane Irene, the Somerville Substation was flooded up to an approximate WSEL of 49.0 ft. Based on the HEC-RAS model; this would correspond with a Raritan River flow of approximately 54,000 cfs in the vicinity of the substation.

PRELIMINARY FLOOD IMPACTS

The Duplicate Effective Model yields results that are very similar to those of the Effective Model. The Existing Conditions Model yielded flood levels that are approximately 1 foot higher than those in the Duplicate Effective Model. However, it is our belief that our Existing Conditions Model more accurately describes the potential for flooding upstream of the US Hwy 206 Bridge than the Duplicate Effective Model. This belief is based on the fact that the Existing Conditions Model has updated bridge geometry, ineffective flow area on the north overbank east of US Hwy 206, and more realistic contraction and expansion loss coefficients.

Table 1 presents the results from the four models considered under 100-year flow flood conditions. River stations in bold indicate the additional cross-sections added to the model at the site.

Table 1: Hydraulic Model Results – FEMA 100-year Flood Levels (40,600 cfs)

| | 1 | 2 | 3 | 4 | (4-3) |
|---------------|---------------------|---------------------|---------------------|---------------------|-------------|
| River Station | Effective Model | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 148600 | 51.85 | 51.86 | 52.11 | 52.11 | 0.00 |
| 147550 | 51.57 | 51.57 | 51.85 | 51.85 | 0.00 |
| 146460 | 51.02 | 51.02 | 51.35 | 51.35 | 0.00 |
| 145480 | 50.59 | 50.59 | 50.98 | 50.98 | 0.00 |
| 144060 | 49.76 | 49.77 | 50.27 | 50.27 | 0.00 |
| 144040 | 49.59 | 49.60 | 50.13 | 50.13 | 0.00 |
| 143855 | 49.53 | 49.53 | 50.08 | 50.08 | 0.00 |
| 143360 | 48.94 | 48.95 | 49.61 | 49.61 | 0.00 |
| 142310 | 48.61 | 48.62 | 49.35 | 49.35 | 0.00 |
| 141270 | 48.34 | 48.36 | 49.14 | 49.14 | 0.00 |
| 140200 | 48.09 | 48.10 | 48.94 | 48.94 | 0.00 |
| 139090 | 47.79 | 47.80 | 48.71 | 48.71 | 0.00 |
| 138600 | 47.42 | 47.43 | 48.39 | 48.39 | 0.00 |
| 138250 | 47.26 | 47.21 | 48.27 | 48.27 | 0.00 |
| 137750 | 46.95 | 46.90 | 48.01 | 48.01 | 0.00 |
| 136982 | US HWY 206 - Bridge | | | | |
| 136850 | 46.57 | 46.57 | 46.57 | 46.57 | 0.00 |
| 136736 | n/a | n/a | 46.52 | 46.52 | 0.00 |
| 136297 | n/a | n/a | 46.51 | 46.51 | 0.00 |
| 136130 | 46.47 | 46.47 | 46.47 | 46.47 | 0.00 |
| 134800 | 46.05 | 46.05 | 46.05 | 46.05 | 0.00 |
| 133500 | 45.67 | 45.67 | 45.67 | 45.67 | 0.00 |
| 132400 | 45.31 | 45.31 | 45.31 | 45.31 | 0.00 |
| 131600 | 45.11 | 45.11 | 45.11 | 45.11 | 0.00 |

The Existing Conditions Model yields WSEs that are 1.11 feet higher than the Effective and Duplicate Effective models in the vicinity of US Hwy 206 (at XS 137750). Approximately 1 mile upstream, the Existing Conditions Model yields WSEs that are approximately 0.66 foot higher than the Duplicate Effective Model. Just over 2 miles upstream, the difference is only 0.25 foot.

The Proposed Conditions Model includes the flood protection on the north bank of the model. A rise in WSE due to the flood protection installation is not predicted in the vicinity of the site or further upstream under 100-year flow conditions.

Table 2 presents the results for the NJDEP Flood Hazard Criteria with flows at 50,750 cfs. River stations in bold indicate the additional cross-sections added to the model at the site.

Table2: Hydraulic Model Results – NJDEP Flood Hazard Flows (50,750 cfs)

| | 2 | 3 | 4 | (4-3) |
|---------------|---------------------|---------------------|---------------------|-------------|
| River Station | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) |
| 148600 | 53.45 | 53.81 | 53.81 | 0.00 |
| 147550 | 53.17 | 53.56 | 53.56 | 0.00 |
| 146460 | 52.65 | 53.09 | 53.09 | 0.00 |
| 145480 | 52.25 | 52.75 | 52.75 | 0.00 |
| 144060 | 51.51 | 52.13 | 52.13 | 0.00 |
| 144040 | 51.36 | 52.01 | 52.01 | 0.00 |
| 143855 | 51.32 | 51.97 | 51.97 | 0.00 |
| 143360 | 50.82 | 51.57 | 51.57 | 0.00 |
| 142310 | 50.53 | 51.33 | 51.33 | 0.00 |
| 141270 | 50.29 | 51.14 | 51.14 | 0.00 |
| 140200 | 50.05 | 50.95 | 50.95 | 0.00 |
| 139090 | 49.78 | 50.73 | 50.73 | 0.00 |
| 138600 | 49.41 | 50.44 | 50.44 | 0.00 |
| 138250 | 49.38 | 50.33 | 50.33 | 0.00 |
| 137750 | 49.02 | 50.03 | 50.03 | 0.00 |
| 136982 | US HWY 206 - Bridge | | | |
| 136850 | 48.43 | 48.43 | 48.43 | 0.00 |
| 136736 | n/a | 48.37 | 48.37 | 0.00 |
| 136297 | n/a | 48.40 | 48.40 | 0.00 |
| 136130 | 48.37 | 48.36 | 48.36 | 0.00 |
| 134800 | 47.97 | 47.97 | 47.97 | 0.00 |
| 133500 | 47.60 | 47.60 | 47.60 | 0.00 |
| 132400 | 47.22 | 47.22 | 47.22 | 0.00 |
| 131600 | 47.02 | 47.02 | 47.02 | 0.00 |

Based on model results, the proposed sheetpile flood wall around the Somerville Substation will not impact water surface elevations in the Raritan River Floodplain under Flood Hazard Flow Conditions. The model indicates that there will be no rise as a result of the sheetpile wall in the Raritan River under Flood Hazard Flow Conditions.

Black & Veatch modeled the observed flooding condition of EL. 49 feet reported by PSE&G during Hurricane Irene. In order to realize an inundation of that depth at the site, a flow of approximately 54,000 cfs would be necessary.


3.0 Conclusions and Recommendation


Although in the floodplain, the Somerville Substation site sits over 20 feet above the invert of the Raritan River and is protected from effective flow in the floodplain due to US Hwy 206 and SAS Medical Arts just south and west of the substation (see Figure 2 – Topographic Survey). The proposed flood protection facilities will not impact flooding upstream of the Somerville Substation. If PSE&G proceed with the design and construction of the proposed flood mitigation measures for the Somerville Substation, upstream existing structures will not be impacted. Hydraulically and based on the model results, there are no impacts to downstream structures.

The existing conditions model prepared for this study was based on the NJDEP model but was modified to more accurately describe the new US Hwy 206 Bridge, ineffective flow area on the north floodplain east of US Hwy 206, and the removal of the railroad bridge 1,500 feet upstream of US Hwy 206. The updates resulted in an increase in predicted flood levels for the existing conditions model. For the 100-year flood, water surface elevations in the reach immediately adjacent to the Somerville Substation increased by 1.11 feet. This finding will be addressed during the permitting process and will require approval of the NJDEP and FEMA.


The flow and inundation from Hurricane Irene were greater than both the FEMA 100-year and NJDEP Flood Hazard flows. An elevation of 50.0 feet, which is approximately 1 foot above the maximum observed flood elevation, was selected as the top of wall design level.

| ELEVATION SUMMARY (FEET NAVD 88) | | | | |
|----------------------------------|------------------|------------------------------------|------------------------|-------------------------------|
| Site | Average Site EL. | Maximum Observed Flood EL. (PSE&G) | NJDEP Flood Hazard EL. | Proposed Flood Protection EL. |
| Somerville | 46 | 49.0 | 48.4 | 50.0 |






US Hwy 206 Bridge as modeled in Effective and Duplicate Effective Models



US Hwy 206 Bridge as modeled in Existing Conditions and Proposed Conditions Models

Figure 2: Cross-sectional views (looking downstream) of US Hwy 206 Bridge as modeled in Duplicate Effective Model and as modeled based on available information in Existing Conditions and Proposed Conditions Models.
 PF1 = FEMA 100-yr flow 40,600 cfs; PF2 = NJDEP Flood Hazard flow 50,750 cfs.



West Side of Site (XS 136736): Existing conditions.






Figure 3: Cross-sectional view from upstream (north) side of site looking downstream.
PF1 = FEMA 100-yr flow 40,600 cfs; PF2 = NJDEP Flood Hazard flow 50,750 cfs



East Side of Site (XS 136297): Existing conditions.



East Side of Site (XS 136297): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 4: Cross-sectional view from east side of site (XS 136297) looking downstream.
PF1 = FEMA 100-yr flow 40,600 cfs; PF2 = NJDEP Flood Hazard flow 50,750 cfs

FLOOD IMPACT STUDY FOR JACKSON ROAD SUBSTATION

Public Service Electric & Gas

11 OCTOBER 2012



BLACK & VEATCH
Building a world of difference.®

Table of Contents

- 1.0 Background 1**
- 2.0 Data Review and Hydraulic Modeling..... 2**
 - Data Review 2
 - Hydraulic Model Scenarios 3
 - Hydraulic Model Development 3
 - Preliminary Flood Impacts 4
- 3.0 Conclusions and Recommendation..... 7**

1.0 Background

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing substantial impact to some electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. Based on this and prior flooding events a "Flood Protection Report" was completed for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, 2012). The Report defines the preliminary requirements to provide flood protection at the twelve flood prone substation sites. Since most of the substation sites are located within either the FEMA 100-year floodplain or the defined floodway area, construction of flood protection facilities at these sites could potentially impact upstream flood water elevations.

Flood Impact Studies will be performed for ten of the twelve substation sites, and will be based on the recommendations for flood protection measures included in the Flood Protection Report. Flood impact studies are not required for two of the twelve sites as they are either a) not in the FEMA 100-year floodplain (Bayway) or b) the proposed flood protection facilities will be located behind existing site floodwall protection (Garfield). PSE&G has provided guidance as to the order in which they would like the substations studied. This prioritization is denoted in the list below in parentheses after the substation name. The ten substations to be studied are as follows:

Central Division

1. Cranford Substation (2)
2. Rahway Substation (5)
3. Somerville Substation (6)

Metro Division

4. Belmont Substation (10)
5. Jackson Road Substation (7)

Palisades Division

6. New Milford Switching Station (1)
7. River Edge Substation (4)
8. Hillsdale Substation (3)
9. Marion Switching Station (8)

Southern Division

10. Ewing Substation (9)

This Flood Impact Study addresses the potential for flooding upstream of the Jackson Road Substation. It describes the upstream flood impacts resulting from construction of the recommended flood protection facilities. It is intended that the results of this study will be used by PSE&G in evaluating the implementation of the flood protection measures at this site. It is recognized that additional flood studies will likely be required to support the permitting process if the recommended mitigation methods are chosen.

The Jackson Road Substation is located at an approximate address of 11 Jackson Rd, Totowa, NJ, 07512 and is approximately three acres. The site is bounded by a

forest/wetland to the west; Jackson Rd to the east; a warehouse to the north; and Madison Road and a Trucking Company's warehouse to the south. Overhead power lines, approximately 30-ft above grade at the lowest point, are all around and inside the site. There is an approximate 2.5-ft tall Jersey barrier wall that encompasses all but the eastern side of the substation. There is gated access to the site from Jackson Road. The site perimeter is located in close proximity to the limit of the 300 foot NJDEP Riparian buffer zone, and should be verified during design.

2.0 Data Review and Hydraulic Modeling

DATA REVIEW

The following documents were utilized in the development of the hydraulic model for the Jackson Road Substation.

- 1) NJDEP. HEC-2 Input and Output Printouts from 19 Oct 1983 (SINGAC_BR_TOTOWA_CED_83.pdf)
- 2) FEMA. Passaic County, NJ- Flood Profiles sheet 227. January 1986.
- 3) FEMA. Flood Insurance Rate Map (FIRM), Passaic County, NJ: Panels 194, 211 and 213. 28 SEP 2007.
- 4) NJDEP. Delineation of Floodway and Flood Hazard Area – Naachpunkt Brook. 18 DEC 1984.
- 5) Carroll Engineering. Boundary and Topographic Survey – PSE&G Co. Jackson Road Substation (01 June 2012)
- 6) Black & Veatch. 2012 Substation Flood Protection – Summary Evaluation Report. 2 March 2012.

The NJDEP provided printouts of their HEC-2 Signac Brook Model dated from 1983 (document 1). This document was the basis of the model development, and its associated output provided model results for the NJDEP 100-year floodplain and floodway. The FEMA Flood Profile and FIRM, and the NJDEP Delineation of Floodway (documents 2, 3 and 4) assisted in locating the Jackson Road site within the HEC-2 model (see Figure 1). The site survey (document 5) was used to determine ground elevations at and around the site. The Substation Flood Protection Report (document 6) provided the estimated height for the flood protection measures. The vertical datum for all elevations reported in the NJDEP HEC-2 files (document 1) is NGVD 29, while the vertical datum for documents 2, 5 and 6 is NAVD 88. NAVD 88 is one foot below NGVD 29 elevations. All elevations presented in this report are NAVD 88 unless otherwise noted (i.e., Figures 2 through 6, which are based on model data from document 1).

The Substation Flood Protection – Summary Evaluation report (document 6), recommends a top elevation for the flood protection wall at the Jackson Road Substation 2 feet above the 100-year flood level. Based on reference 1, the 100-year flood level in the vicinity of the site is 173.2 ft (NAVD 88). This recommendation would yield a top of the wall at 175.2 ft (NAVD 88). Final recommendations for the flood protection height are based on the findings of this hydraulic study and are presented in the Conclusions and Recommendations (Section 3.0).

HYDRAULIC MODEL SCENARIOS

Black & Veatch used the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S. Army Corps of Engineers Hydraulic Engineering Center, to develop a hydraulic model for the Signac Brook in the vicinity of the Jackson Road Substation. The hydraulic model used for this study was developed from NJDEP's HEC-2 input data.

In order to achieve the goal of this study, four geometry models were considered.

- The first model was the Effective Model. These are the water surface elevations (WSEs) as presented in the results of the HEC-2 printouts. The results of the Effective Model provide the New Jersey Department of Environmental Protection (NJDEP) 100-year flood levels.

The remaining three other models were developed from the Effective model: the Duplicate Effective Model, the Existing Conditions Model, and the Proposed Conditions Model.

- The Duplicate Effective Model is the input data from the HEC-2 files, input into a HEC-RAS model and run to ensure similar results and proper calibration.
- The Existing Conditions Model was based on the Duplicate Effective Model, but includes additional cross-sections in the vicinity of the site and modifications to some cross-sections.
- The Proposed Conditions Model was based on the Existing Conditions Model and includes proposed flood protection.

The flood elevation differences between proposed conditions and existing conditions throughout the modeled length along the river will represent the potential flood impact associated with the proposed improvements.

HYDRAULIC MODEL DEVELOPMENT

A profile of the river indicating exact cross-section locations for cross-sections in the NJDEP HEC-2 model was not provided to aid in the development of the HEC-RAS models relative to the Jackson Road Substation site. Hence, the cross-section locations had to be estimated based on available information within the HEC-2 printout (Effective Model), river ground levels indicated in the flood profile sheet and aerial imagery in Google Earth. The Flood Profile Sheet indicates an inverted river slope at the Conrail Railroad Bridge. The inverted slope and bridge were then identified in the HEC-2 file. The location was further confirmed due to agreement in distances to upstream bridges. After estimating the location of the cross-section just upstream of the Conrail Railroad Bridge, all other cross-section locations in the model were estimated from distances between cross-sections as reported in the Effective Model. Jackson Road Substation lies along the eastern bank (left bank) of the Signac Brook downstream of Continental Road Bridge and upstream of the Conrail Railroad Bridge. Jackson Road Substation and the estimated river model layout are shown in Figure 1. Cross-sections taken from the HEC-2 model are shown in white.

Two cross-sections were modified and three cross-sections were added in the vicinity of the Jackson Road Substation site for the Existing Conditions Model. Elevations in the east (left) bank of cross-sections 2475 and 2135 were adjusted and the width of these cross-sections

was broadened in order to transect the site. These modifications as well as the added cross-sections were based on the site survey (Carroll Engineering, 2012). Added cross-sections and modified cross-sections are shown in yellow on Figure 1. Figures 2 through 6 present the profiles of the modified and added cross-sections in the vicinity of the Jackson Road Substation site. Immediately upstream of the Jackson Road Substation is a warehouse which will block effective flow. The warehouse is indicated as a blocked obstruction in Figure 2. In Figures 3 and 4 – Existing Conditions, ineffective flow markers have been placed to further account for the warehouse. Ineffective flow markers are also placed in cross-sections 2135 and 2115 (see Figures 5 and 6) to account for the severe constriction to flow at the Conrail Railroad Bridge.

In development of the Proposed Conditions Model (Jackson Road Model 4), the proposed flood protection was inserted on the east bank in each of the added cross-sections that transect the site. It is represented as a blocked obstruction in the HEC-RAS models and can be visualized in Figures 2 through 6.

The following flows were considered:

- 2,000 cfs - The Signac Brook's FEMA 100-year flood flow in the vicinity of the Jackson Road Site.
- 2,500 cfs – NJDEP Flood Hazard Limit Criterion = 125% of the Signac Brook, 100-year flood flow

During Hurricane Floyd, the Jackson Road Substation was flooded up to an approximate WSEL of 173.5 ft. Based on the HEC-RAS model this would correspond to a flow of 2,130 cfs. This flow is nearly equivalent to the 100-year flood flow for the Signac Brook flow of approximately 2,000 cfs in the vicinity of the substation. The site has not flooded since Hurricane Floyd in 1999 (Black & Veatch, 2012).

PRELIMINARY FLOOD IMPACTS

The Duplicate Effective Model yields results that are similar to those of the Effective Model.

The Existing Conditions Model, which includes additional and modified cross-sections, also yielded flood levels that are similar to those in the Effective and Duplicate Effective Models.

Table 1 presents the results from the four models considered under 100-year flow flood conditions. River stations in bold indicate cross-sections added to the model in the vicinity of the site.

Table 1: Hydraulic Model Results – FEMA 100-year Flood Levels (2,000 cfs)

| River Station | 1 Effective Model (ft) | 2 Duplicate Effective (ft) | 3 Existing Conditions (ft) | 4 Proposed Conditions (ft) | (4-3) Difference (ft) |
|-------------------------------------|---------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-----------------------------|
| 2915 | 173.72 | 173.73 | 173.63 | 173.67 | 0.04 |
| 2635 | 173.58 | 173.59 | 173.48 | 173.53 | 0.05 |
| 2634 | Continental Road Bridge | | | | |
| 2595 | 173.30 | 173.39 | 173.24 | 173.30 | 0.06 |
| 2525 | - | - | 173.06 | 173.13 | 0.07 |
| *2475 | 173.18 | 173.21 | 173.01 | 173.07 | 0.06 |
| 2285 | - | - | 173.00 | 172.95 | -0.05 |
| *2135 | 172.62 | 172.63 | 172.93 | 172.89 | -0.04 |
| 2115 | - | - | 172.93 | 172.90 | -0.03 |
| 1985 | 172.56 | 172.59 | 172.59 | 172.59 | 0.00 |
| 1984 | Conrail Railroad Bridge | | | | |
| 1960 | 172.55 | 172.58 | 172.58 | 172.58 | 0.00 |
| 1560 | 172.51 | 172.53 | 172.53 | 172.53 | 0.00 |
| 1180 | 172.48 | 172.48 | 172.48 | 172.48 | 0.00 |
| 530 | 172.38 | 172.39 | 172.39 | 172.39 | 0.00 |
| 250 | 172.35 | 172.36 | 172.36 | 172.36 | 0.00 |
| 0 | 172.10 | 172.10 | 172.10 | 172.10 | 0.00 |
| -300 | 172.22 | 172.22 | 172.22 | 172.22 | 0.00 |
| -740 | 172.03 | 172.03 | 172.03 | 172.03 | 0.00 |
| -1290 | 172.08 | 172.08 | 172.08 | 172.08 | 0.00 |
| -1539 | 171.87 | 171.87 | 171.87 | 171.87 | 0.00 |
| -1540 | 172.00 | 172.00 | 172.00 | 172.00 | 0.00 |
| *Indicates a modified cross-section | | | | | |

The Existing Conditions Model yields WSEs that are similar to the Effective and Duplicate Effective models in the vicinity of Jackson Road Substation.

The Proposed Conditions Model includes the flood protection on the east bank of the model. A slight rise of 0.07 feet is predicted in the vicinity of the site and further upstream due to the flood protection installation under 100-year flow conditions. However, no impact to water levels is seen 0.6 miles upstream at Passaic County Road 640 (also known as French Hill Road).

Table 2 presents the results for the NJDEP Flood Hazard Criteria with flows at 2,500 cfs. River stations in bold indicate cross-sections added to the model in the vicinity of the site.

Table2: Hydraulic Model Results – NJDEP Flood Hazard Flows (2,500 cfs)

| | 2 | 3 | 4 | (4-3) |
|-------------------------------------|-------------------------|---------------------|---------------------|--------------|
| River Station | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) |
| 2915 | 175.60 | 175.37 | 175.56 | 0.19 |
| 2635 | 175.56 | 175.31 | 175.52 | 0.21 |
| 2634 | Continental Road Bridge | | | |
| 2595 | 175.41 | 175.29 | 175.35 | 0.06 |
| 2525 | - | 175.23 | 175.29 | 0.06 |
| *2475 | 175.34 | 175.20 | 175.27 | 0.07 |
| 2285 | - | 175.19 | 175.16 | -0.03 |
| *2135 | 174.88 | 175.17 | 175.14 | -0.03 |
| 2115 | - | 175.16 | 175.14 | -0.02 |
| 1985 | 174.75 | 174.75 | 174.75 | 0.00 |
| 1984 | Conrail Railroad Bridge | | | |
| 1960 | 174.74 | 174.74 | 174.74 | 0.00 |
| 1560 | 174.81 | 174.81 | 174.81 | 0.00 |
| 1180 | 174.80 | 174.80 | 174.80 | 0.00 |
| 530 | 174.74 | 174.74 | 174.74 | 0.00 |
| 250 | 174.70 | 174.70 | 174.70 | 0.00 |
| 0 | 174.49 | 174.49 | 174.49 | 0.00 |
| -300 | 174.60 | 174.60 | 174.60 | 0.00 |
| -740 | 174.44 | 174.44 | 174.44 | 0.00 |
| -1290 | 174.49 | 174.49 | 174.49 | 0.00 |
| -1539 | 174.23 | 174.23 | 174.23 | 0.00 |
| -1540 | 174.39 | 174.39 | 174.39 | 0.00 |
| *Indicates a modified cross-section | | | | |

Based on model results, the proposed sheetpile flood wall around the Jackson Road Substation will impact water surface elevations in the Signac Brook Floodplain under Flood Hazard Flow Conditions. The model indicates that there will be a rise of 0.07 feet in the reach immediately adjacent to the Jackson Road Substation and a rise of 0.21 feet upstream of Continental Road Bridge as a result of the sheetpile wall in the Signac Brook floodplain under Flood Hazard Flow Conditions. However, a measurable rise in water levels is not predicted 0.6 miles upstream near Passaic County Road 640 (also known as French Hill Road).


3.0 Conclusions and Recommendation


The proposed flood protection facilities will have a slight impact on flooding levels upstream of the Jackson Road Substation. If PSE&G proceeds with the design and construction of the proposed flood mitigation measures for the Jackson Road Substation, there could be a minor impact to upstream existing structures. Hydraulically and based on the model results, there are no impacts to downstream structures.

Although the floodway does extend onto the PSE&G property, there is sufficient space on the site to accommodate proposed facility improvements without entering the floodway. PSE&G should ensure that the flood protection wall does not impose on the floodway when it is installed.


A maximum flood depth of 14 inches at the breaker was observed at the Jackson Road Substation during Hurricane Floyd in 1999. Based on modeling results, the flow during Hurricane Floyd was greater than both the NJDEP 100-year flow in the Signac Brook, and the NJDEP Flood Hazard Flow. An Elevation of 177.2 feet, which is 1 foot above the Black & Veatch estimated Flood Hazard Elevation and one foot above the maximum observed flood elevation, was selected as the top of wall design level.

| ELEVATION SUMMARY (FEET NAVD 88) | | | | |
|----------------------------------|------------------|------------------------------------|------------------------|-------------------------------|
| Site | Average Site EL. | Maximum Observed Flood EL. (PSE&G) | NJDEP Flood Hazard EL. | Proposed Flood Protection EL. |
| Jackson Road | 175 | 176.2 | 175.3 | 177.2 |





Upstream of Site (XS 2525): Existing Conditions.



Upstream of Site (XS 2525): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 2: Cross-sectional view upstream of site (XS 2525) at warehouse looking downstream.
 PF1 = FEMA 100-yr flow 2,000 cfs; PF2 = NJDEP Flood Hazard flow 2,500 cfs.







Figure 3: Cross-sectional view upstream of site (XS 2475) and downstream of warehouse looking downstream.
PF1 = FEMA 100-yr flow 2,000 cfs; PF2 = NJDEP Flood Hazard flow 2,500 cfs.




North Side of Site (XS 2285): Existing Conditions.




North Side of Site (XS 2285): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 4: Cross-sectional view from north side of site (XS 2285) looking downstream.

PF1 = FEMA 100-yr flow 2,000 cfs; PF2 = NJDEP Flood Hazard flow 2,500 cfs




Middle of Site (XS 2135): Existing Conditions.




Middle of Site (XS 2135): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 5: Cross-sectional view through middle of site (XS 2135) looking downstream.

PF1 = FEMA 100-yr flow 2,000 cfs; PF2 = NJDEP Flood Hazard flow 2,500 cfs



South Side of Site (XS 2115): Existing Conditions.



South Side of Site (XS 2115): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 6: Cross-sectional view from south side of site (XS 2115) looking downstream.

PF1 = FEMA 100-yr flow 2,000 cfs; PF2 = NJDEP Flood Hazard flow 2,500 cfs

FLOOD IMPACT STUDY FOR MARION SWITCHING STATION

Public Service Electric & Gas

11 OCTOBER 2012



Table of Contents

- 1.0 Background 1**
- 2.0 Data Review and Hydraulic Modeling..... 2**
 - Data Review 2
 - Hydraulic Model Scenarios 3
 - Hydraulic Model Development 4
 - Preliminary Flood Impacts 5
- 3.0 Conclusions and Recommendation..... 11**

1.0 Background

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing substantial impact to some electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. Based on this and prior flooding events a "Flood Protection Report" was completed for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, 2012). The Report defines the preliminary requirements to provide flood protection at the twelve flood prone substation sites. Since most of the substation sites are located within either the FEMA 100-year floodplain or the defined floodway area, construction of flood protection facilities at these sites could potentially impact upstream flood water elevations.

Flood Impact Studies will be performed for ten of the twelve substation sites, and will be based on the recommendations for flood protection measures included in the Flood Protection Report. Flood impact studies are not required for two of the twelve sites as they are either a) not in the FEMA 100-year floodplain (Bayway) or b) the proposed flood protection facilities will be located behind existing site floodwall protection (Garfield). PSE&G has provided guidance as to the order in which they would like the substations studied. This prioritization is denoted in the list below in parentheses after the substation name. The ten substations to be studied are as follows:

Central Division

1. Cranford Substation (2)
2. Rahway Substation (5)
3. Somerville Substation (6)

Metro Division

4. Belmont Substation (10)
5. Jackson Road Substation (7)

Palisades Division

6. New Milford Switching Station (1)
7. River Edge Substation (4)
8. Hillsdale Substation (3)
9. Marion Switching Station (8)

Southern Division

10. Ewing Substation (9)

This Flood Impact Study addresses the potential for flooding upstream of the Marion Switching Station. It describes the upstream flood impacts resulting from construction of the recommended flood protection facilities. It is intended that the results of this study will be used by PSE&G in evaluating the implementation of the flood protection measures at this site. It is recognized that additional flood studies will likely be required to support the permitting process if the recommended mitigation methods are chosen.

The Marion Substation is located on West Side Avenue adjacent to the Hudson Generating Station. The substation is located on the larger station property, and occupies

approximately 5 acres. There is gated access at the north end of the site. This is a large industrial site, with open access to the north and east along West Side Avenue. The west and south sides are adjacent to existing equipment with limited access. The Marion site is under the jurisdiction of the Hackensack Meadowlands Commission. The site is on the backside of the Hudson Generating Station. The topography of the site is concave in nature resulting in ponding from storm events.

The Hackensack River, which is west of the site, is under tidal influence and backwater control from Newark Bay. Water levels in the Hackensack River are a direct translation from levels in Newark Bay. The tidal influence and backwater control in the Hackensack River extends upstream over 18 miles. The FEMA FIS flood profile begins at approximate river station 959+50 and indicates that "Flood Elevations Downstream of this Point are Controlled by Newark Bay" (FEMA, 34003CV003A, 2005). NJDEP does not have flood mapping for the Hackensack Meadowlands Commission but FEMA does. Under New Jersey Law, the Flood Hazard Area in tidal areas, such as this, is equivalent to the FEMA 100-year (1%) flood area. Therefore, consideration of a separate Flood Hazard run is not necessary. Additionally, NJAC 7:13 (NJDEP Flood Hazard Area Control Act Rules) indicates in section 3.4(d) that: "*If no FEMA floodway map exists for the section of regulated water in question, the floodway limit shall be equal to the limits of the channel. The Atlantic Ocean and other non-linear tidal waters such as bays and inlets do not have a floodway.*" Thus it is our understanding that the Hackensack River adjacent to the Marion site either does not have a floodway or it is limited to the limits of the river channel.

2.0 Data Review and Hydraulic Modeling

DATA REVIEW

The following documents were utilized in the development of the hydraulic model for the Marion Switching Station.

- 1) NJDEP. HEC-2 Input and Output Printouts (Hackensack_River_FW.pdf)
- 2) USACE. Hackensack Meadowlands Development Commission (HMDC) – Flood Control Study, New Jersey. September 2001
- 3) FEMA. FIS – Bergen County, New Jersey. September 2005.
- 4) PSE&G Services Corporation. Flood Study Base Survey – Marion Switching Station (06 April 2012)
- 5) Black & Veatch. 2012 Substation Flood Protection – Summary Evaluation Report. 2 March 2012.

The NJDEP provided printouts of their HEC-2 Hackensack River Floodway Model beginning at river station 969+00 (document 1). This document was the basis of the model development for the reach of river outside of backwater control at Newark Bay. Its associated output provided model results for the NJDEP 100-year floodplain and floodway in this reach as well. The USACE study (document 2) provided cross-section profiles for the Hackensack River in the vicinity of the Marion Switching Station. These cross-sections were the basis for the model development for the reach of river under backwater control from Newark Bay. An existing HEC-2 or HEC-RAS model for the Hackensack River reach from

station 0+00 to 959+50 was not available since flood levels downstream of station 959+50 are controlled by Newark Bay.

The FEMA FIS (document 3) provided the 100 year (1%) flood level at Newark Bay, and 100-year (1%) flood levels in the Hackensack River beginning at station 959+50. It also provided estimates for 100-year flows at cross-section 96900.

The PSE&G site survey (document 4) assisted in determining ground elevations at the site and distances to the river. The Substation Flood Protection Report (document 5) provided the estimated height for the flood protection measures.

The vertical datum for elevations reported in the NJDEP HEC-2 files (document 1), the USACE Flood Study (document 2), and the FEMA FIS (document 3) is NGVD 29, while the vertical datum for documents 4 and 5 is NAVD 88. NAVD 88 is approximately one foot below NGVD 29 elevations. All elevations presented in this report are NAVD 88 unless otherwise noted (i.e., Figures 2 and 3, which are based on model data from documents 1 and 2).

The Substation Flood Protection – Summary Evaluation Report (document 5), recommends a top elevation for the flood protection wall at the Marion Switching Station 2 feet above the 100-year flood level. Based on document 3, the 100-year (1%) water level in Newark Bay and the vicinity of the site is 8.9 ft (NAVD 88). This recommendation would yield a top of the wall at 10.9 ft (NAVD 88). Final recommendations for the flood protection height are based on the findings of this hydraulic study and are presented in the Conclusions and Recommendations (Section 3.0).

HYDRAULIC MODEL SCENARIOS

Black & Veatch used the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S. Army Corps of Engineers Hydraulic Engineering Center, to develop a hydraulic model for the Hackensack River in the vicinity of the Marion Switching Station. The hydraulic model used for this study was developed from NJDEP's HEC-2 input data.

In order to achieve the goal of this study, four geometry models were considered.

- The first model was the Effective Model. These are the water surface elevations, (WSEs) as presented in the results of the HEC-2 printouts, for the Hackensack River reach beyond backwater control at Newark Bay (beyond river station 959+50). The results of the Effective Model provide the New Jersey Department of Environmental Protection (NJDEP) 100-year flood levels and floodway levels.

The remaining three other models were developed from the Effective model: the Duplicate Effective Model, the Existing Conditions Model, and the Proposed Conditions Model.

- The Duplicate Effective Model is the input data from the HEC-2 files, input into a HEC-RAS model along with the USACE cross-sections (document 2). This model was run to ensure similar results and proper calibration in the upstream reach.

- The Existing Conditions Model was based on the Duplicate Effective Model, but includes additional cross-sections in the vicinity of the site.
- The Proposed Conditions Model was based on the Existing Conditions Model and includes proposed flood protection.

The flood elevation differences between proposed conditions and existing conditions throughout the modeled length along the river will represent the potential flood impact associated with the proposed improvements.

HYDRAULIC MODEL DEVELOPMENT

River profiles indicating exact cross-section locations for cross-sections in the USACE Flood study were available. Thus exact cross-section locations relative to the Marion site could be identified. Marion Switching Station lies on the eastern bank (left bank) of the Hackensack River approximately 3 miles upstream of Newark Bay. Marion Switching Station and the estimated river model layout in the vicinity of the Marion site are shown in Figure 1. Cross-sections taken from the USACE Flood Study are shown in white.

As previously indicated the Duplicate Effective model was developed from both the NJDEP Hackensack River model and the USACE Flood Study cross-sections. One cross-section was added to the Duplicate Effective model at the confluence with Newark Bay in order to set the downstream boundary condition to known water levels at Newark Bay.

For the Existing Conditions Model, two additional cross-sections were added in the vicinity of the Marion site: 16645 and 16195. Cross-section 16645 corresponds with the northern side of the Marion site, while cross-section 16195 runs along the southern side of the site. Station and elevation data for the left bank of the added cross-sections was established from survey information and available topographic data. The topographic survey is presented in Figure 2 (PSE&G, 2012). The added and modified cross-sections are shown in yellow on Figure 1. Figures 2 and 3 present the profiles for cross-sections 16645 and 16195 in the vicinity of the Marion Switching Station site. The Hudson Generating Station is also shown as a blocked obstruction on the two added cross sections in the Existing Conditions Model.

In development of the Proposed Conditions Model (Marion Model 4), the proposed flood protection was inserted on the east bank in each of the two cross-sections that border the site (16645 and 16195). It is represented as a blocked obstruction in the HEC-RAS models and can be visualized in Figures 2 and 3.

Two steady state flow conditions were considered; both have the same flow value but consider different starting water surface elevations in Newark Bay. The flow considered is the Hackensack River's 100-year flood flow of 7,410 cfs at river station 969+00. This was provided in the NJDEP HEC-2 model.

The first run considered a lower water level in Newark Bay in order to achieve the exact WSEL as predicted by the HEC-2 model at cross-section 96900. For this run, Newark Bay was set to a WSEL of 5.53 feet.

In the second run the water level in Newark Bay was based upon available information in the FEMA FIS and FIRM. The following information was considered:

- The FEMA FIS indicates that the Newark Bay 100-year (1%) water level is 8.9 feet (based on the historic record of northeasterly storm surges).
- The FIRM indicates a flood level of 7.9 feet at Marion Station when Newark Bay is experiencing the 100-year (1%) flood level of 8.9 feet.
- Based on Table 12 (Floodway Data) in the FIS, the backwater level in the Hackensack River at river station 969+00. is at 7.7 feet

The second run considered a downstream water level of 7.9 feet in order to achieve the WSEL indicated in the FIRM at the Marion site.

During Hurricane Irene, the Marion Switching Station experienced a maximum flood depth of 1.5 ft. The perimeter of the site is at approximate elevation 7.0 feet. Thus water in Newark Bay and the reach of the Hackensack River adjacent to the Marion site may have experienced water levels during Hurricane Irene of about 8 feet. Historic tide data are available for Bergen Point West Reach, NY and are archived by NOAA. Figure 4 presents the water levels in Newark Bay on the day when Hurricane Irene, as a tropical storm, passed over the Marion Switching Station.

PRELIMINARY FLOOD IMPACTS

The Duplicate Effective Model yields results that are similar to those of the Effective Model at cross-section 96900 and further upstream.

Table 1 presents the results from the four models considered under 100-year flow flood conditions. River stations in bold indicate added cross-sections in the model.

Table 1: Hydraulic Model Results – FEMA 100-year Flood Levels (7,410 cfs)

| River Station | 1 Effective Model* | 2 Duplicate Effective | 3 Existing Conditions | 4 Proposed Conditions | (4-3) Difference |
|---------------|--------------------------|-----------------------------|-----------------------------|-----------------------------|---------------------|
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 99600 | 6.16 | 6.18 | 6.18 | 6.18 | 0.00 |
| 99100 | 6.04 | 6.05 | 6.05 | 6.05 | 0.00 |
| 98900 | 6.08 | 6.10 | 6.10 | 6.10 | 0.00 |
| 98300 | 5.78 | 5.79 | 5.79 | 5.79 | 0.00 |
| 97900 | 5.78 | 5.78 | 5.78 | 5.78 | 0.00 |
| 97470 | 5.63 | 5.63 | 5.63 | 5.63 | 0.00 |
| 96900 | 5.60 | 5.60 | 5.60 | 5.60 | 0.00 |
| 20723 | - | 5.54 | 5.54 | 5.54 | 0.00 |
| 19292 | - | 5.54 | 5.54 | 5.54 | 0.00 |
| 17768 | - | 5.54 | 5.54 | 5.54 | 0.00 |
| 16911 | - | 5.53 | 5.53 | 5.53 | 0.00 |
| 16645 | - | - | 5.54 | 5.54 | 0.00 |

| | 1 | 2 | 3 | 4 | (4-3) |
|----------------------|------------------|---------------------|---------------------|---------------------|-------------|
| River Station | Effective Model* | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 16195 | - | - | 5.53 | 5.53 | 0.00 |
| 15997 | - | 5.53 | 5.53 | 5.53 | 0.00 |
| 13289 | - | 5.53 | 5.53 | 5.53 | 0.00 |
| 13120 | - | 5.53 | 5.53 | 5.53 | 0.00 |
| 0 | - | 5.53 | 5.53 | 5.53 | 0.00 |
| *NJDEP HEC-2 Results | | | | | |

The Existing Conditions Model, which includes additional cross-sections, yielded flood levels that are similar to those in the Effective and Duplicate Effective Models for both the upstream and downstream reaches.

The Proposed Conditions Model includes the flood protection on the east bank of the model. A rise in WSE due to the flood protection installation is not predicted in the vicinity of the site nor further upstream in the reach outside of the backwater control.

Black & Veatch also prepared a second run considering a 100-year (1%) water level at the Marion site with 100-year (1%) flood flows in the Hackensack River. Resulting flood levels from this run are presented in Table 2.

Table 2: Hydraulic Model Results – 100-year (1%) WSEL in Newark Bay and 100-Year Flows (7,410 cfs)

| | 1 | 2 | 3 | 4 | (4-3) |
|---------------|------------------|---------------------|---------------------|---------------------|-------------|
| River Station | Effective Model* | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 99600 | 7.70 | 8.18 | 8.18 | 8.18 | 0.00 |
| 99100 | 7.70 | 8.14 | 8.14 | 8.14 | 0.00 |
| 98900 | 7.70 | 8.16 | 8.16 | 8.16 | 0.00 |
| 98300 | 7.70 | 8.01 | 8.01 | 8.01 | 0.00 |
| 97900 | 7.70 | 8.02 | 8.02 | 8.02 | 0.00 |
| 97470 | 7.70 | 7.97 | 7.97 | 7.97 | 0.00 |
| 96900 | 7.70 | 7.96 | 7.96 | 7.96 | 0.00 |
| 20723 | 7.9 | 7.90 | 7.90 | 7.90 | 0.00 |
| 19292 | 7.9 | 7.90 | 7.90 | 7.90 | 0.00 |
| 17768 | 7.9 | 7.90 | 7.90 | 7.90 | 0.00 |
| 16911 | 7.9 | 7.90 | 7.90 | 7.90 | 0.00 |
| 16645 | 7.9 | - | 7.90 | 7.90 | 0.00 |
| 16195 | 7.9 | - | 7.90 | 7.90 | 0.00 |
| 15997 | 7.9 | 7.90 | 7.90 | 7.90 | 0.00 |

| | 1 | 2 | 3 | 4 | (4-3) |
|-------------------|------------------|---------------------|---------------------|---------------------|------------|
| River Station | Effective Model* | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 13289 | 8.9 | 7.90 | 7.90 | 7.90 | 0.00 |
| 13120 | 8.9 | 7.90 | 7.90 | 7.90 | 0.00 |
| 0 | 8.9 | 7.90 | 7.90 | 7.90 | 0.00 |
| *FEMA FIS Results | | | | | |

This run where Newark Bay experiences 100-year (1%) chance water levels due to storm surges with 100-year flows in the Hackensack River is probably a conservative approach, as it assumes the coincidence of separate independent events.

STORM SURGE FROM TROPICAL STORM IRENE

The National Hurricane Center website was examined for information on the effects of Tropical Storm Irene that made landfall in New Jersey on August 28, 2011 as a tropical storm and was moving in a north northeasterly direction. According to the Tropical Cyclone Report (http://www.nhc.noaa.gov/data/tcr/AL092011_Irene.pdf), observations of storm surge and storm tide were made at Bergen Point in Newark Bay, the nearest to Marion Switching Station. The storm surge is defined as the water height above the normal astronomical tide. The storm surge recorded at Bergen Point was 4.56 ft., resulting in a seawater elevation of 7.26 ft. (NAVD 1988).

(http://tidesandcurrents.noaa.gov/data_menu.shtml?bdate=20110827&edate=20110828&wl_sensor_hist=W1&relative=&datum=7&unit=1&shift=g&stn=8519483+Bergen+Point+West+Reach%2C+NY&type=Historic+Tide+Data&format=View+Plot)

The SLOSH (Sea, Lake, and Overland Surge from Hurricanes) model is used by the National Hurricane Center (NHC) and National Weather Service (NWS) to predict storm surges from Hurricanes (<http://slosh.nws.noaa.gov/sloshPriv/>). The NHC has used the model to predict the maximum storm surge that could occur at a given location for each category of hurricane. This is accomplished by running the model for each basin using a variety of storm directions, speeds and landfall locations. The maximum of all of these runs is then the maximum storm surge that could occur for any given category of hurricane. The Tropical Cyclone Report for Irene critiqued the predictions by NOAA for the storm. However, the critique focused on predictions of path and intensity and not on predicted storm surge. During Tropical Storm Irene NOAA predicted storm surge on a probability basis. For example, a prediction could be 50 percent probability that surge will be 2 ft and 30 percent probability that surge could be 5 feet. The SLOSH Display model cannot be used to simulate Irene because it does not simulate tropical storms.

The SLOSH display model is a tool that NOAA makes available so users can display or view the results of the model runs prepared by NOAA. The display model does not allow the user to run additional cases with inputs defined by the user.

Marion is included in the New York model basin. For this basin, NOAA modeled 288 different hurricane scenarios which included the following conditions:

- Hurricane moving in six directions: northeast (NE), north northeast (NNE), north (N), north northwest (NNW), northwest (NW) and west northwest WNW)
- Hurricane moving at six speeds (10, 20, 30, 40, 50 and 60 mph)
- Landfall during two tidal stages (mean and high tide)
- Categories 1, 2, 3, and 4 hurricane wind speeds

For each of these scenarios, several model runs were made with the hurricane moving along different parallel tracks to produce landfall at different points. Based on these results, a maximum envelop of water (MEOW) was defined. The MEOW represents the maximum height that water reaches, at any time during the storm, in each grid cell when running the model on storms with the same category, forward speed and direction of motion, but with tracks that are parallel to each other. After the MEOWs were defined, the Maximum of MEOWs (MOM) was calculated. The MOM represents the maximum height of water at every grid cell that is reached in any of the MEOWs, where the only constant is hurricane category.

A review of the results of the SLOSH modeling indicates that there are significant differences in the predicted surge heights for hurricanes depending on the speed and direction of the storm and tidal condition. In general, the highest surge is produced by storms moving at 40 mph. Faster moving storms produce approximately the same surge heights while slower moving storms produce less surge. Also, surge height increases as the movement of the storm shifts towards the west. The lowest surges were for storms moving towards the NE while the highest surges were for storms moving in the WNW direction. The recurrence interval for any Category 1 or 2 hurricane (i.e., sustained winds between 74 and 110 mph) impacting the New Jersey coast is about 19 years, while the recurrence interval for any major hurricane (i.e., Category 3 to 5, winds greater than 111 mph) impacting the New Jersey coast is about 74 years. The value of the recurrence intervals is based on, and extrapolated from, a statistical analysis of tropical cyclones.

It is not possible to model the impact of Irene at Marion because the SLOSH model only models hurricanes and not tropical storms. Irene was a tropical storm when it impacted the New Jersey coast. A summary of SLOSH model results showing the affect of Hurricane direction is presented in the following table.

Table 3 – Storm Tide (FT NAVD) and Hurricane Direction

| Direction | Category | Speed (mph) | Tidal Stage | Storm Tide (ft) |
|------------------|-----------------|--------------------|--------------------|------------------------|
| NE | 1 | 10 | Mean | 1.2 |
| NNE | 1 | 10 | Mean | 1.8 |
| N | 1 | 10 | Mean | 1.9 |
| NNW | 1 | 10 | Mean | 2.4 |
| NW | 1 | 10 | Mean | 2.7 |
| WNW | 1 | 10 | Mean | 3.1 |

Most hurricanes that impacted the New Jersey area traveled in a NNE to NE direction. A summary of SLOSH model results showing the effect of hurricane category, speed, and tidal stage is presented in the following table.

Table 3 – Storm Tide (FT NAVD) and Hurricane Direction and Speed Tidal Stage

| Direction | Category | Speed (mph) | Tidal Stage | Storm Tide (ft) |
|------------------|-----------------|--------------------|--------------------|------------------------|
| NNE | 1 | 10 | Mean | 1.2 |
| NNE | 2 | 10 | Mean | 4.0 |
| NNE | 3 | 10 | Mean | 6.0 |
| NNE | 4 | 10 | Mean | 8.2 |
| NNE | 1 | 20 | Mean | 2.3 |
| NNE | 1 | 30 | Mean | 2.9 |
| NNE | 1 | 40 | Mean | 3.6 |
| NNE | 1 | 50 | Mean | 3.6 |
| NNE | 1 | 10 | High | 3.7 |

To evaluate storm surge under conservative conditions, the SLOSH model was run for a Category 2 hurricane going to the NNE at 40 mph and high tide. The model results listed are below and also shown on the following figure.

| Storm Tide (Ft NAVD 1988) for Conservative Conditions | | | | |
|--|-----------------|--------------------|--------------------|------------------------|
| Direction | Category | Speed (mph) | Tidal Stage | Storm Tide (ft) |
| NNE | 2 | 40 | High | 7.8 |

The storm tide of 7.8 ft determined from the SLOSH model is less than the flood level determined from the proposed conditions model of 7.9 ft.





Figure 1 – SLOSH Model for Category 2 Hurricane


3.0 Conclusions and Recommendation

The proposed flood protection facilities will not impact flooding upstream of the Marion Switching Station. If PSE&G proceeds with the design and construction of the proposed flood mitigation measures for the Marion Switching Station, there should be no impact to upstream existing structures. Hydraulically and based on the model results, there are no impacts to downstream structures.


During Hurricane Irene, a maximum flood depth of 1.5 feet was observed at the Marion site. The flow and resulting inundation from Hurricane Irene were less than the 100-year (1%) flood level in Newark Bay. The FEMA FIS and FIRM indicate that when Newark Bay is at the 100-year (1%) flood level of 8.9 feet, the Hackensack River near the Marion site is at a WSEL of 7.9 feet. An elevation of 8.9 feet, which is 1 foot above the Hackensack River 100-year (1%) flood level in the reach adjacent to the Marion site, was selected as the top of wall design level.

| ELEVATION SUMMARY (FEET NAVD 88) | | | | |
|----------------------------------|------------------|------------------------------------|----------------|-------------------------------|
| Site | Minimum Site EL. | Maximum Observed Flood EL. (PSE&G) | 1% Flood Level | Proposed Flood Protection EL. |
| Marion | 5.0 | 6.5 | 7.9 | 8.9 |






North Side of Site (XS 16645): Existing Conditions.




North Side of Site (XS 16645): Proposed Conditions – Sheetpile Flood Protection Installed.

Figure 2: Cross-sectional view from north side of site (XS 16645) looking downstream.
 PF1 = Downstream WSEL = 7.9 ft; PF2 = Downstream WSEL = 5.53 ft



South Side of Site (XS 16195): Existing Conditions.



South Side of Site (XS 16195): Proposed Condition – Sheetpile Flood Protection Installed.

Figure 3: Cross-sectional view from south side of site (XS 16195) looking downstream.
 PF1 = Downstream WSEL = 7.9 ft; PF2 = Downstream WSEL = 5.55 ft




Figure 4: Historic Tide Data at Bergen Point West Reach, NY – Station ID 8519483 During Tropical Storm Irene. Gage Datum is 0.00 feet NAVD 88.

FLOOD IMPACT STUDY FOR EWING SUBSTATION

Public Service Electric & Gas

11 OCTOBER 2012



Table of Contents

- 1.0 Background1**
- 2.0 Data Review and Hydraulic Modeling.....2**
 - Data Review 2
 - Hydraulic Model Scenarios 3
 - Hydraulic Model Development 3
 - Preliminary Flood Impacts 4
- 3.0 Conclusions and Recommendation.....9**

1.0 Background

On August 28, 2011 Hurricane Irene moved through PSE&G's service territory leaving several thousand customers without power while causing substantial impact to some electric and gas facilities. This event flooded several PSE&G substations in North and Central New Jersey to varying depths. Based on this and prior flooding events a "Flood Protection Report" was completed for twelve of PSE&G's substations (Black & Veatch, Substation Flood Protection – Summary Evaluation Report, 2012). The Report defines the preliminary requirements to provide flood protection at the twelve flood prone substation sites. Since most of the substation sites are located within either the FEMA 100-year floodplain or the defined floodway area, construction of flood protection facilities at these sites could potentially impact upstream flood water elevations.

Flood Impact Studies will be performed for ten of the twelve substation sites, and will be based on the recommendations for flood protection measures included in the Flood Protection Report. Flood impact studies are not required for two of the twelve sites as they are either a) not in the FEMA 100-year floodplain (Bayway) or b) the proposed flood protection facilities will be located behind existing site floodwall protection (Garfield). PSE&G has provided guidance as to the order in which they would like the substations studied. This prioritization is denoted in the list below in parentheses after the substation name. The ten substations to be studied are as follows:

Central Division

1. Cranford Substation (2)
2. Rahway Substation (5)
3. Somerville Substation (6)

Metro Division

4. Belmont Substation (10)
5. Jackson Road Substation (7)

Palisades Division

6. New Milford Switching Station (1)
7. River Edge Substation (4)
8. Hillsdale Substation (3)
9. Marion Switching Station (8)

Southern Division

10. Ewing Substation (9)

This Flood Impact Study addresses the potential for flooding upstream of the Ewing Substation. It describes the upstream flood impacts resulting from construction of the recommended flood protection facilities. It is intended that the results of this study will be used by PSE&G in evaluating the implementation of the flood protection measures at this site. It is recognized that additional flood studies will likely be required to support the permitting process if the recommended mitigation methods are chosen.

The Ewing Substation is located about 700 ft south of the N. Olden Avenue and Prospect Street intersection, Ewing, NJ, 08638 and is approximately 0.75 acres. The site is bounded

by an abandoned house and abandoned driving range to the west; Prospect St to the east; a warehouse to the north; and an abandoned miniature golf course to the south. There are no overhead power lines in the site boundary limits, but there are to the east, running parallel with Prospect St. There is a 3-ft tall concrete flood wall that encloses the feeder rows at the substation. There is a gate for access to the feeder rows from Prospect Street. The flood wall has 3 removable panels located along the south side of the wall. The control house and transformer are not protected by the floodwall. There is a 4 x 4 x 3.5 foot deep sump located in the western corner of the site with piping that conveys floodwaters to the eastern side boundary.

A portion of the Ewing site is located within the floodway, which comprises the river channel and adjacent floodplain that should be kept free of encroachment in accordance with FEMA recommendations.

2.0 Data Review and Hydraulic Modeling

DATA REVIEW

The following documents were utilized in the development of the hydraulic model for the Ewing Substation.

- 1) NJDEP. HEC-2 Input and Output Printouts from 21 DEC 1981 (West Br Shabakunk HEC 2 output.pdf)
- 2) NJDEP. Delineation of Floodway and Flood Hazard Area – West Branch Shabakunk Creek. 24 DEC 1980.
- 3) Kennon Surveying Services, Inc (KSS). Boundary and Topographic Survey – Ewing Substation (06 June 2012)
- 4) Black & Veatch. 2012 Substation Flood Protection – Summary Evaluation Report. 2 March 2012.

The NJDEP provided printouts of their HEC-2 West Branch Shabakunk Creek Model dated from 1981 (document 1). This document was the basis of the model development, and its associated output provided model results for the NJDEP 100-year flood plain and floodway. The site survey (document 3) was used to determine ground elevations at and around the site. The Substation Flood Protection Report (document 4) provided the estimated height for the flood protection measures. The vertical datum for elevations reported in the NJDEP HEC-2 files (document 1) and the NJDEP Floodway Delineation (document 2) is NGVD 29, while the vertical datum for documents 3 and 4 is NAVD 88. NAVD 88 is one foot below NGVD 29 elevations. All elevations presented in this report are NAVD 88 unless otherwise noted (i.e., Figures 3 and 4, which are based on model data from document 1).

The Substation Flood Protection – Summary Evaluation Report (document 4), recommends a top elevation for the flood protection wall at the Ewing Substation 2 feet above the 100-year flood level. Based on reference 1, the 100-year flood level in the vicinity of the site is 75.4 ft (NAVD 88). This recommendation would yield a top of the wall at 77.5 ft (NAVD 88). Final recommendations for the flood protection height are based on the findings of this hydraulic study and are presented in the Conclusions and Recommendations (Section 3.0).

HYDRAULIC MODEL SCENARIOS

Black & Veatch used the HEC-RAS one-dimensional hydraulic computer software program, as developed by the U.S. Army Corps of Engineers Hydraulic Engineering Center, to develop a hydraulic model for the Signac River in the vicinity of the Ewing Substation. The hydraulic model used for this study was developed from NJDEP's HEC-2 input data.

In order to achieve the goal of this study, four geometry models were considered.

- The first model was the Effective Model. These are the water surface elevations (WSEs) as presented in the results of the HEC-2 printouts. The results of the Effective Model provide the New Jersey Department of Environmental Protection (NJDEP) 100-year flood levels and floodway levels.

The remaining three other models were developed from the Effective model: the Duplicate Effective Model, the Existing Conditions Model, and the Proposed Conditions Model.

- The Duplicate Effective Model is the input data from the HEC-2 files, input into a HEC-RAS model and run to ensure similar results and proper calibration.
- The Existing Conditions Model was based on the Duplicate Effective Model, but includes additional cross-sections in the vicinity of the site and modifications to some cross-sections.
- The Proposed Conditions Model was based on the Existing Conditions Model and includes proposed flood protection.

The flood elevation differences between proposed conditions and existing conditions throughout the modeled length along the river will represent the potential flood impact associated with the proposed improvements.

HYDRAULIC MODEL DEVELOPMENT

A profile of the river indicating exact cross-section locations for cross-sections in the NJDEP HEC-2 model was not provided to aid in the development of the HEC-RAS models relative to the Ewing Substation site. Hence, the cross-section locations had to be estimated based on available information within the HEC-2 printout (Effective Model) and aerial imagery in Google Earth. After estimating the location of the cross-section just upstream of the Prospect Street Bridge, all other cross-section locations in the model were estimated from distances between cross-sections as reported in the Effective Model. Ewing Substation lies along the northern bank (left bank) of the West Branch Shabakunk Creek downstream of Parkside Avenue and just upstream of the Prospect Street Bridge. Ewing Substation and the estimated river model layout are shown in Figure 1. Cross-sections taken from the HEC-2 model are shown in white.

One cross-section was modified and one cross-section was added in the vicinity of the Ewing site for the Existing Conditions Model. The estimated location of cross-section 6330 corresponds with the eastern edge/border of the Ewing site. As such, this cross-section was modified to match available survey information. Cross-section 6500 was added. This cross-section runs along the western edge/border of the site. All modifications as well as the added cross-section were based on the updated site survey (KSS, 2012). The added and

modified cross-sections are shown in yellow on Figure 1. Figures 2 and 3 present the profiles for cross-sections 6500 and 6330 in the vicinity of the Ewing Substation site.

In development of the Proposed Conditions Model (Ewing Model 4), the proposed flood protection was inserted on the north bank in each of the two cross-sections that transect the site (6500 and 6330). It is represented as a blocked obstruction in the HEC-RAS models and can be visualized in Figures 2 and 3.

The following flows were considered:

- 2,117 cfs - The West Branch Shabakunk Creek’s FEMA 100-year flood flow in the vicinity of the Ewing Site.
- 2,646 cfs - NJDEP Flood Hazard Limit Criterion = 125% of the West Branch Shabakunk Creek, 100-year flood flow

Since a portion of the Ewing Site lies in the floodway, a floodway run which includes encroachments was also considered. A floodway is defined “as the channel of a river or other watercourse and the adjacent land areas that must be reserved in order to discharge the base flood without cumulatively increasing the water-surface elevation by more than a designated height. Normally, the base flood is the one-percent change event (100-year recurrence interval), and the under New Jersey law the designated height is 0.2 foot for maximum rise. The floodway is usually determined by an encroachment analysis, using an equal loss of conveyance on opposite sides of the stream. For purposes of floodway analysis, the floodplain fringe removed by the encroachments is assumed to be completely blocked” (USACE, HEC-RAS User’s Manuel).

During Hurricane Irene, the Ewing Substation was flooded up to an approximate WSEL of 75 ft. Based on the HEC-RAS model this would correspond to a flow of 1,700 cfs. This flow is 20 percent less than the 100-year flood flow of 2,117 cfs in the vicinity of the substation.

PRELIMINARY FLOOD IMPACTS

The Duplicate Effective Model yields results that are similar to those of the Effective Model.

The Existing Conditions Model, which includes additional and modified cross-sections, also yielded flood levels that are similar to those in the Effective and Duplicate Effective Models.

Table 1 presents the results from the four models considered under 100-year flow flood conditions. River stations in bold indicate added and modified cross-sections in the model.

Table 1: Hydraulic Model Results – FEMA 100-year Flood Levels (2,117 cfs)

| | 1 | 2 | 3 | 4 | (4-3) |
|----------------------|------------------------|----------------------------|----------------------------|----------------------------|-------------------|
| River Station | Effective Model | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 11360 | 85.44 | 85.58 | 85.58 | 85.58 | 0.00 |
| 10780 | 85.36 | 85.52 | 85.52 | 85.52 | 0.00 |
| 10370 | 84.96 | 85.14 | 85.14 | 85.14 | 0.00 |

| | 1 | 2 | 3 | 4 | (4-3) |
|---------------|----------------------------|---------------------|---------------------|---------------------|--------------|
| River Station | Effective Model | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 10235 | 85.12 | 85.31 | 85.31 | 85.31 | 0.00 |
| 9770 | 85.05 | 85.23 | 85.23 | 85.23 | 0.00 |
| 9735 | 85.05 | 85.22 | 85.22 | 85.22 | 0.00 |
| 9734 | Pennington Road Bridge | | | | |
| 9655 | 83.00 | 83.25 | 83.25 | 83.25 | 0.00 |
| 9605 | 82.20 | 82.22 | 82.22 | 82.22 | 0.00 |
| 9500 | 82.17 | 82.30 | 82.30 | 82.30 | 0.00 |
| 9395 | 82.40 | 82.43 | 82.43 | 82.43 | 0.00 |
| 9345 | 82.34 | 82.38 | 82.38 | 82.38 | 0.00 |
| 9344 | N.J. National Bank Bridge | | | | |
| 9325 | 81.96 | 81.92 | 81.92 | 81.92 | 0.00 |
| 9275 | 81.96 | 82.00 | 82.00 | 82.00 | 0.00 |
| 8975 | 81.07 | 81.06 | 81.06 | 81.06 | 0.00 |
| 8927 | 81.21 | 81.21 | 81.21 | 81.21 | 0.00 |
| 8926 | Culvert Under Mrs. G Store | | | | |
| 8725 | 81.10 | 81.08 | 81.08 | 81.08 | 0.00 |
| 8680 | 81.09 | 81.06 | 81.06 | 81.06 | 0.00 |
| 8675 | 81.11 | 81.06 | 81.06 | 81.06 | 0.00 |
| 8674 | Parkside Avenue Bridge | | | | |
| 8605 | 81.08 | 80.98 | 80.98 | 80.98 | 0.00 |
| 8600 | 81.00 | 80.97 | 80.97 | 80.97 | 0.00 |
| 8555 | 80.89 | 80.79 | 80.79 | 80.79 | 0.00 |
| 8500 | 79.68 | 79.78 | 79.78 | 79.78 | 0.00 |
| 8080 | 78.10 | 78.27 | 78.26 | 78.26 | 0.00 |
| 7580 | 76.71 | 76.81 | 76.69 | 76.71 | 0.02 |
| 7280 | 76.34 | 76.42 | 76.23 | 76.27 | 0.03 |
| 6900 | 76.08 | 76.14 | 75.87 | 75.92 | 0.05 |
| 6500 | n/a | n/a | 75.60 | 75.62 | 0.02 |
| 6330 | 75.34 | 75.39 | 75.48 | 75.45 | -0.02 |
| 6291 | 75.48 | 75.53 | 75.53 | 75.53 | 0.00 |
| 6290 | 75.38 | 75.53 | 75.53 | 75.53 | 0.00 |
| 6289 | Prospect Street Bridge | | | | |
| 6235 | 75.21 | 75.29 | 75.29 | 75.29 | 0.00 |
| 6234 | 75.25 | 75.29 | 75.29 | 75.29 | 0.00 |
| 6195 | 74.98 | 75.01 | 75.01 | 75.01 | 0.00 |

The Existing Conditions Model yields WSEs that are very similar to the Effective and Duplicate Effective models in the vicinity of Ewing Substation.

The Proposed Conditions Model includes the flood protection on the north bank of the model. A slight rise in WSE due to the flood protection installation is predicted in the vicinity of the site. The model predicts a maximum rise of 0.05 feet; however, the slight rise does not propagate far upstream. At 1,580 feet upstream (XS 8080), there is no impact on 100-year flood levels.

Table 2 presents the results for the NJDEP Flood Hazard Criteria with flows at 2,646 cfs. River stations in bold indicate cross-sections added to the model in the vicinity of the site.

Table2: Hydraulic Model Results – NJDEP Flood Hazard Flows (2,646 cfs)

| River Station | 2 Duplicate Effective (ft) | 3 Existing Conditions (ft) | 4 Proposed Conditions (ft) | (4-3) Difference (ft) |
|---------------|-------------------------------------|-------------------------------------|-------------------------------------|-----------------------------|
| 11360 | 86.02 | 86.02 | 86.02 | 0.00 |
| 10780 | 85.93 | 85.93 | 85.93 | 0.00 |
| 10370 | 85.38 | 85.38 | 85.38 | 0.00 |
| 10235 | 85.63 | 85.63 | 85.63 | 0.00 |
| 9770 | 85.52 | 85.52 | 85.52 | 0.00 |
| 9735 | 85.52 | 85.52 | 85.52 | 0.00 |
| 9734 | Pennington Road Bridge | | | |
| 9655 | 83.65 | 83.65 | 83.65 | 0.00 |
| 9605 | 82.62 | 82.62 | 82.62 | 0.00 |
| 9500 | 82.71 | 82.71 | 82.71 | 0.00 |
| 9395 | 82.92 | 82.92 | 82.92 | 0.00 |
| 9345 | 82.88 | 82.88 | 82.88 | 0.00 |
| 9344 | N.J. National Bank Bridge | | | |
| 9325 | 82.47 | 82.47 | 82.47 | 0.00 |
| 9275 | 82.55 | 82.55 | 82.55 | 0.00 |
| 8975 | 81.54 | 81.54 | 81.54 | 0.00 |
| 8927 | 81.66 | 81.66 | 81.66 | 0.00 |
| 8926 | Culvert Under Mrs. G Store | | | |
| 8725 | 81.52 | 81.52 | 81.52 | 0.00 |
| 8680 | 81.51 | 81.51 | 81.51 | 0.00 |
| 8675 | 81.51 | 81.51 | 81.51 | 0.00 |
| 8674 | Parkside Avenue Bridge | | | |
| 8605 | 81.41 | 81.41 | 81.41 | 0.00 |
| 8600 | 81.41 | 81.41 | 81.41 | 0.00 |
| 8555 | 81.18 | 81.18 | 81.18 | 0.00 |
| 8500 | 80.18 | 80.18 | 80.18 | 0.00 |
| 8080 | 78.95 | 78.93 | 78.94 | 0.00 |

| | 2 | 3 | 4 | (4-3) |
|---------------|------------------------|---------------------|---------------------|--------------|
| River Station | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) |
| 7580 | 77.37 | 77.27 | 77.29 | 0.02 |
| 7280 | 76.93 | 76.76 | 76.80 | 0.03 |
| 6900 | 76.65 | 76.42 | 76.47 | 0.05 |
| 6500 | n/a | 76.17 | 76.17 | 0.01 |
| 6330 | 75.98 | 76.04 | 76.03 | -0.02 |
| 6291 | 76.08 | 76.08 | 76.08 | 0.00 |
| 6290 | 76.08 | 76.08 | 76.08 | 0.00 |
| 6289 | Prospect Street Bridge | | | |
| 6235 | 75.92 | 75.92 | 75.92 | 0.00 |
| 6234 | 75.92 | 75.92 | 75.92 | 0.00 |
| 6195 | 75.69 | 75.69 | 75.69 | 0.00 |

Based on model results, the proposed sheetpile flood wall around the Ewing Substation will not significantly impact water surface elevations in the West Branch Shabakunk Creek Floodplain under Flood Hazard Flow Conditions. The model indicates that there will be a slight rise as a result of the sheetpile wall under Flood Hazard Flow Conditions. The model predicts a maximum rise of 0.05 feet; however, the slight rise does not propagate far upstream. At 1,580 feet upstream (XS 8080) of the site, there is no impact on Flood Hazard flood levels.

Black & Veatch also prepared a floodway run which includes encroachments since the Ewing Substation Site partially lies in the NJDEP designated floodway. Results are presented in Table 3.

Table 3: Hydraulic Model Results – Floodway Run Flood Levels (2,117 cfs)

| | 1 | 2 | 3 | 4 | (4-3) |
|---------------|------------------------|---------------------|---------------------|---------------------|------------|
| River Station | Effective Model | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 11360 | 85.54 | 86.49 | 86.49 | 86.49 | 0.00 |
| 10780 | 85.43 | 86.42 | 86.42 | 86.42 | 0.00 |
| 10370 | 84.94 | 86.16 | 86.16 | 86.16 | 0.00 |
| 10235 | 85.18 | 86.28 | 86.28 | 86.28 | 0.00 |
| 9770 | 85.04 | 86.20 | 86.20 | 86.20 | 0.00 |
| 9735 | 85.04 | 86.18 | 86.18 | 86.18 | 0.00 |
| 9734 | Pennington Road Bridge | | | | |
| 9655 | 83.11 | 83.33 | 83.33 | 83.33 | 0.00 |

| | 1 | 2 | 3 | 4 | (4-3) |
|---------------|----------------------------|---------------------|---------------------|---------------------|--------------|
| River Station | Effective Model | Duplicate Effective | Existing Conditions | Proposed Conditions | Difference |
| | (ft) | (ft) | (ft) | (ft) | (ft) |
| 9605 | 82.33 | 82.20 | 82.20 | 82.20 | 0.00 |
| 9500 | 82.30 | 82.27 | 82.27 | 82.27 | 0.00 |
| 9395 | 82.52 | 82.48 | 82.48 | 82.48 | 0.00 |
| 9345 | 82.36 | 82.35 | 82.35 | 82.35 | 0.00 |
| 9344 | N.J. National Bank Bridge | | | | |
| 9325 | 82.09 | 82.07 | 82.07 | 82.07 | 0.00 |
| 9275 | 82.05 | 82.08 | 82.08 | 82.08 | 0.00 |
| 8975 | 81.24 | 80.69 | 80.69 | 80.69 | 0.00 |
| 8927 | 81.38 | 81.03 | 81.03 | 81.03 | 0.00 |
| 8926 | Culvert Under Mrs. G Store | | | | |
| 8725 | 81.27 | 81.23 | 81.23 | 81.23 | 0.00 |
| 8680 | 81.26 | 81.21 | 81.21 | 81.21 | 0.00 |
| 8675 | 81.27 | 81.21 | 81.21 | 81.21 | 0.00 |
| 8674 | Parkside Avenue Bridge | | | | |
| 8605 | 81.22 | 81.12 | 81.12 | 81.12 | 0.00 |
| 8600 | 81.17 | 81.12 | 81.12 | 81.12 | 0.00 |
| 8555 | 81.10 | 80.97 | 80.97 | 80.97 | 0.00 |
| 8500 | 79.66 | 79.75 | 79.75 | 79.75 | 0.00 |
| 8080 | 78.20 | 78.38 | 78.36 | 78.37 | 0.00 |
| 7580 | 76.84 | 76.86 | 76.70 | 76.73 | 0.03 |
| 7280 | 76.49 | 76.58 | 76.38 | 76.42 | 0.03 |
| 6900 | 76.19 | 76.24 | 75.92 | 75.98 | 0.06 |
| 6500 | n/a | n/a | 75.66 | 75.69 | 0.02 |
| 6330 | 75.44 | 75.45 | 75.54 | 75.51 | -0.02 |
| 6291 | 75.58 | 75.59 | 75.59 | 75.59 | 0.00 |
| 6290 | 75.51 | 75.57 | 75.57 | 75.57 | 0.00 |
| 6289 | Prospect Street Bridge | | | | |
| 6235 | 75.37 | 75.40 | 75.40 | 75.40 | 0.00 |
| 6234 | 75.40 | 75.40 | 75.40 | 75.40 | 0.00 |
| 6195 | 75.22 | 75.22 | 75.22 | 75.22 | 0.00 |

The Proposed Conditions Model includes the flood protection on the north bank of the model. A slight rise in WSE due to the flood protection installation is predicted in the vicinity of the site. The model predicts a maximum rise of 0.06 feet; however, the slight rise does not propagate far upstream. At 1,580 feet upstream (XS 8080), there is no impact on floodway flood levels. This increase in the WSE due to construction in the Floodway will