



Agenda Date: 1/25/17
Agenda Item: 8B

STATE OF NEW JERSEY
Board of Public Utilities
44 South Clinton Avenue, 3rd Floor, Suite 314
Post Office Box 350
Trenton, New Jersey 08625-0350
www.nj.gov/bpu/

CLEAN ENERGY

IN THE MATTER OF THE CLEAN ENERGY PROGRAM)
AUTHORIZATION OF COMMERCIAL AND INDUSTRIAL) ORDER
PROGRAM ENERGY EFFICIENCY INCENTIVES)
EXCEEDING \$500,000 - ALFRED SANZARI)
ENTERPRISES, INC.) DOCKET NO. QG16121150

Parties of Record:

Brad Porrino, Property Manager at Glenpointe, Alfred Sanzari Enterprises, Inc.
Stefanie A. Brand, Esq., Director, Division of Rate Counsel

BY THE BOARD:

Pursuant to N.J.S.A. 48:3-60, the New Jersey Board of Public Utilities (Board) administers the New Jersey Clean Energy Program (NJCEP). The NJCEP offers financial incentives to New Jersey Commercial and Industrial (C&I) customers to encourage the adoption of energy efficient technologies. Eligible applicants may receive rebates for a portion of the cost for installing energy efficient (EE) technologies, such as lighting, heating, ventilation, air conditioning (HVAC) and water heating at their locations. All proposed C&I EE financial incentives and rebates exceeding \$500,000 require explicit Board approval. See I/M/O the Comprehensive Energy Efficiency and Renewable Energy Resource Analysis for the 2009 through 2012 Clean Energy Program – Revised 2012-2013 Programs & Budgets – Revised Rebate Approval Process, BPU Dkt. No. EO07030203 (May 3, 2013).

The Pay for Performance (P4P) – Existing Buildings Program takes a comprehensive, whole building approach to energy efficiency in existing commercial and industrial buildings. Similar to performance contracting programs offered in other states, this Program links incentives directly to energy savings and includes a measurement and verification component to ensure that the estimated savings levels are achieved. Incentives are released upon satisfactory completion of three milestones.

Alfred Sanzari Enterprises, Inc., of Hackensack, NJ, has submitted an application for a total financial incentive of \$575,769.86 under the 2016 P4P Existing Buildings Program, for a project located at the Marriott Teaneck at Glenpointe, 100 Frank W. Burr Boulevard, Teaneck, Bergen County. This application was accepted under the Fiscal Year 2016 Program Descriptions and Budget: Commercial & Industrial dated June 15, 2015. The proposed project is sited at a Marriott hotel consisting of 322,500 square feet that spans 350 guest rooms, space for conferences or other multipurpose use, as well as a restaurant, lounge, and bar. The proposed energy efficiency measures include, but are not limited to, chiller, boiler, pump, domestic hot water heater, and lighting replacements. The air conditioners and associated systems will be upgraded, as will all major HVAC controls. Furthermore, measures such as occupancy-based thermostats and kitchen demand control ventilation will be included in the scope of the project.

The estimated first incentive, for the proposed energy reduction plan (ERP), is \$32,250.00. The estimated second incentive, to be paid after the installation of the recommended measures, is \$271,759.93. The estimated third incentive, which is paid upon submittal of a Post Construction Benchmarking Report that verifies the level of savings achieved, is \$271,759.93. These incentive amounts are within entity cap guidelines. The project has an estimated 30.8% total energy savings, and will save the customer an estimated 2,325,738 kWh of electricity annually and reduce peak electric demand by 167.4 kW annually. Through this project, the customer is also anticipated to save 12,743 therms of natural gas annually. The estimated project cost is \$2,619,842.00. Overall, this project has an estimated annual energy cost savings of \$260,759.00, with a 10.2% internal rate of return and a 7.84 year simple payback period with incentive. Absent these incentives, the project would have a 6.4% internal rate of return and a 15.2 year simple payback.


TRC, the Program Manager engaged by the Board to manage the NJCEP P4P – Existing Buildings Program, submitted its certification that the incentive was calculated in accordance with the program policies and procedures, and that the listed amount is the true and accurate estimated incentive for which the applicant is eligible. Further, Applied Energy Group, in its role as the NJCEP Program Administrator, also reviewed the application and submitted its certification that the incentives were calculated in accordance with the Program policies and procedures, and that the listed amounts are the true and accurate estimated incentives for which the applicant is eligible. Based on these certifications and the information provided by the Program Manager and Program Administrator, Board Staff recommends that the Board approve the above-referenced application.

The Board **HEREBY ORDERS** the approval of the aforementioned application for the total estimated incentive amount of \$575,769.86 for Alfred Sanzari Enterprises, Inc., and **AUTHORIZES** issuance of a standard commitment letter to the applicant identified above, setting forth the terms and conditions of these commitments.

The effective date of this Order is February 4, 2017.

DATED: 1/25/17


BOARD OF PUBLIC UTILITIES
BY:



RICHARD S. MROZ
PRESIDENT




JOSEPH L. FIORDALISO
COMMISSIONER



MARY-ANNA HOLDEN
COMMISSIONER




DIANNE SOLOMON
COMMISSIONER




UPENDRA J. CHIVUKULA
COMMISSIONER

ATTEST:



IRENE KIM ASBURY
SECRETARY

I HEREBY CERTIFY that the within
document is a true copy of the original
in the files of the Board of Public Utilities



IN THE MATTER OF THE CLEAN ENERGY PROGRAM AUTHORIZATION OF
COMMERCIAL AND INDUSTRIAL (C&I) PROGRAM ENERGY EFFICIENCY INCENTIVES
EXCEEDING \$500,000 – ALFRED SANZARI ENTERPRISES, INC.
DOCKET NO. QG16121150

SERVICE LIST

Brian DeLuca
TRC Solutions
900 Route 9 North, Suite 104
Woodbridge, NJ 07095

Carl Teter
TRC Solutions
900 Route 9 North, Suite 104
Woodbridge, NJ 07095

Valentina Rozanova
TRC Solutions
900 Route 9 North, Suite 104
Woodbridge, NJ 07095

Michael Ambrosio
Applied Energy Group, Inc.
317 George Street, Suite 305
New Brunswick, NJ 08901

James Nappi
Applied Energy Group, Inc.
317 George Street, Suite 305
New Brunswick, NJ 08901

Caroline Vachier
Deputy Attorney General
Division of Law
Department of Law & Public Safety
124 Halsey Street
Post Office Box 45029
Newark, NJ 07102-45029
Caroline.vachier@dol.lps.state.nj.us

Stefanie A. Brand, Esq., Director
Division of Rate Counsel
140 East Front Street, 4th Floor
Post Office Box 003
Trenton, NJ 08625-0003
sbrand@rpa.state.nj.us

Irene Kim Asbury, Esq.
Secretary of the Board
Office of the Secretary
Board of Public Utilities
44 South Clinton Avenue, 3rd Floor, Suite 314
Post Office Box 350
Trenton, NJ 08625-0350
Irene.asbury@bpu.nj.gov

Marisa Slaten, Assistant Director
Economic Development & Energy Policy
Board of Public Utilities
44 South Clinton Avenue, 3rd Floor, Suite 314
Post Office Box 350
Trenton, NJ 08625-0350
Marisa.Slaten@bpu.nj.gov

Elizabeth Teng
Office of Clean Energy
Board of Public Utilities
44 South Clinton Avenue, 3rd Floor, Suite 314
Post Office Box 350
Trenton, NJ 08625-0350
Elizabeth.teng@bpu.nj.gov

Sherri Jones
Office of Clean Energy
Board of Public Utilities
44 South Clinton Avenue, 3rd Floor, Suite 314
Post Office Box 350
Trenton, NJ 08625-0350
Sherri.jones@bpu.nj.gov

Veronica Beke
Deputy Attorney General
Division of Law
Department of Law & Public Safety
124 Halsey Street
Post Office Box 45029
Newark, NJ 07102-45029
Veronica.beke@dol.lps.state.nj.us

Allison E. Mitchell
Office of Clean Energy
Board of Public Utilities
44 South Clinton Avenue, 3rd Floor, Suite 314
Post Office Box 350
Trenton, NJ 08625-0350
Allison.mitchell@bpu.nj.gov

Brad Porrino
Property Manager at Glenpointe
Alfred Sanzari Enterprises
25 Main Street
Suite 600
Hackensack, NJ 07601

Maureen Wagner
Legal Specialist
Board of Public Utilities
44 South Clinton Avenue, 3rd Floor, Suite 314
Post Office Box 350
Trenton, NJ 08625-0350
Maureen.Wagner@bpu.nj.gov

**Program Administrator Certification
(New Incentive Commitments > \$500,000)**

I, **Maura Watkins**, Quality Assurance Manager for NJCEP Program Administrator, Applied Energy Group, Inc., here by certify that, I have reviewed the application referenced below and determined that, as required by the policies and procedures applicable to the program, (1) the equipment incentives for which TRC now seeks approval to commit NJCEP funds have been calculated in accordance with those policies and procedures, and (2) that the amount shown below is the true and accurate estimated incentive for which the applicant(s) is(are) eligible.

Additionally, for incentives based on estimated energy savings that are uniquely calculated, including the Custom Program, Pay for Performance and Large Energy Users Program, I also certify that I was able to locate and review documentation supporting the inputs used to calculate the rebate amount and evidencing TRC's evaluation of those inputs as required by the program's policies and procedures.

Maura H Watkins

By: _____

Date: 12-01-2016

Maura Watkins

Quality Assurance Manager - Applied Energy Group, Inc.

Application No.: 35191

Applicant: Alfred Sanzari Enterprises (Brad Porrino)

Payee: Alfred Sanzari Enterprises, Inc.

Committed Amount: \$575,769.86

Program Manager Certification
(New Incentive Commitments > \$500,000)

I Carl Teter hereby certify that applications on the attached list have been reviewed by TRC or its subcontractors as required by the policies and procedures applicable to each program, that the incentives for which TRC now seeks approval to commit have been calculated in accordance with those policies and procedures, and that the listed amounts are the true and accurate estimated incentives for which each applicant is eligible.



By: _____ Date: 12-5-2016
Carl P. Teter, P.E., LEED AP, Associate Vice President
App# 35191

1. Application Number: **35191**
2. Program Name: **Pay for Performance – Existing Buildings**
3. Customer Contact (name, company, address, phone #):
**Brad Porrino, Property Manager at Glenpointe
Alfred Sanzari Enterprises
25 Main Street, Suite 600, Hackensack, NJ 07601
201-832-4822**
4. Project Name and Address:
**Marriott Teaneck at Glenpointe
100 Frank W. Burr Blvd., Teaneck, NJ 07666**
5. Rebate amount:
**Incentive #1: \$32,250.00
Incentive #2: \$271,759.93
Incentive #3: \$271,759.93
*Total: \$575,769.86***
6. Brief description of facility/site:
The facility is a 350 room Marriott hotel. It is about 322,500 square feet and includes space for conference/multipurpose rooms, as well as restaurant, lounge, and bar.
7. Brief description of measures:
Measures include chiller, boiler, pump, domestic hot water heater, & lighting replacements. Air Conditioners 1, 2, & 3 will be upgraded with direct-drive fans, VFDs, new coils, valves, and casing insulation. All major HVAC equipment controls, including VAV's, to be upgraded from standalone/pneumatic controls to direct digital controls to allow implementation of various reset strategies, economizer control, VAV/VFD control, etc. Other projects include synchronous belts on return fans, occupancy based thermostats, and kitchen demand control ventilation.

See last page for full list of measures.
8. Annual Estimated Energy Savings:
**2,325,738 kWh
167.4 kW
12,743 therms**
9. Annual Estimate Energy Cost Savings (including simple payback with and without incentive, and IRR):
**\$260,759.00
Simple payback 15.2 years (without incentive); 7.84 years (with).
IRR 6.4% (without incentive), 10.2% (with)**
10. Project Cost: **\$2,619,842.00 (\$2,315,732 associated with measures, and \$304,110 associated with partner and construction management fees).**

Measure Name		Measure Details	Quantity	Fuel Affected
1	Central Boiler Replacement	Replace existing boilers for 3 new BMK 2000 condensing boilers. Tie into new DDC control system.	3	Natural Gas
2	Hot Water Reset	Program automatic hot water supply temperature reset from 180°F at 20F outdoor air temperature (OAT) to approximately 120°F at 60F OAT. Tie into new DDC control system.	3	Natural Gas
3	Variable Volume Hot Water Pumping, WITH New Pumps, Piping	Replace two (2) existing hot water pumps for NEW Armstrong Series 4600 / 1770 RPM / 600 GPM / 140 Ft. Head / 79% hydraulic eff. @ duty point / 30-40 HP motor. Install VFD for each pump motor. Install system differential pressure sensor on HW riser to guestroom fan coil units to control VFD and tie into new DDC control system. REPIPE and CONTROL to avoid existing bypassing of total flow.	2	Electric
4	Chiller Replacement	Replace one (1) existing McQuay constant speed centrifugal chiller for new water-cooled Carrier 23XRV variable speed screw chiller rated for approximately 365 tons / 10°F dT.	1	Electric
5	Chilled Water Reset	Program both chillers with automatic chilled water temperature reset based on CHWST vs OAT. Tie into new DDC control system.	1	Electric
6	Condenser Water Reset	Program condenser water setpoint with automatic condenser water temperature reset based on outside air wet-bulb. Tie into new DDC control system. Use to control tower fan speed.	1	Electric
7	Variable Volume Chilled Water Pumping, New Pumps, Piping	Replace two (2) existing chilled water pumps for new Armstrong Series 4600 / 1800 RPM / 875 GPM / 140 Ft. Head / 82% hydraulic eff. at duty point / 40 HP motor. Convert to variable primary flow system. Install VFD for each pump motor. Install system differential pressure sensor on roof near R-1 or R-4 to control VFD and tie into new DDC control system. Consider replacement of Spa AHU 1 & 2 3-way CHW control valves with 2-way valves and electric actuators. However, also consider minimum chiller flow requirements. Tie into DDC control system. Install automatic isolation valves on each chiller evaporator bundle. Close bypass valve between supply & return headers.	2	Electric
8	Variable Volume Condenser Water Pumping, New Pumps, Piping	Replace two (2) existing condenser water pumps for new Armstrong Series 4600 / 1200 RPM / 1025 GPM / 70 Ft. Head / 80% hydraulic eff. @ duty point / 25 HP motor. Install automatic isolation valves on each chiller condenser bundle. Tie into new DDC control system. Install VFD for each pump motor and convert to variable flow w/ chiller head pressure control.	2	Electric
9	AC 1, 2 & 3 Refurbishment and R-1 thru R-4 Improvements	<p>Refurbish (AC-1,2,3) units with new insulation on casings / new CHW coils sized for 44°F CHW w/ 10°F dT or higher.</p> <p>Coordinate AC-3 with the kitchen hood demand control ventilation system outlined in Kitchen DCV operation. Ensure AC-3 & EF-8 operation are interlocked.</p> <p>New HW coils sized for 180°F HW w/ 30°F dT for AC-1 & 3 only .</p> <p>Install VFDs on supply and return fan motors for AC-1, AC-2, AC-3. Cut & cap bypass dampers/ductwork on AC-1 & AC-2. New direct-drive plenum supply fans for AC-1,2,3. Fully open, disable and/or remove inlet vortex/bypass dampers on R-1 & R-4. Remove discharge dampers on R-1 & R-4.</p> <p>Remove or lock fully open the filter damper bank for AC-1, 2 & 3.</p> <p>Install electric actuators on outside, return & exhaust air dampers on AC-1, 2, 3, and R-1 & R-4. Replace pneumatic HW & CHW control valves (2way & 3way) with 2-way valves and electric actuators on all AC & R units. Install electronic duct static pressure sensors, ideally located at farthest end of duct for AC-1, AC-2, R-1 & R-4.</p> <p>Convert all AC units & Rooftop units from pneumatic to DDC controls and tie into new DDC control system.</p>	7	Electric

10	Supply Air Temperature Reset	For R-1 & 4 and AC 1 & 2, program an automatic supply air temperature reset from approximately 55°F to 65°F based on, the zone of maximum demand via the DDC control system. Return air sensors will be used to monitor RH, and reset the SAT lower when RA RH > 59%.	6	Electric
11	Air-Side Economizer	Program air-side economizer for R-1, R-4, AC 1 & 2 based on fixed outside air temperature setpoint of 68F. In addition to controls, this requires larger outside air damper bank & intake louvers on R-1 & R-4 to allow air-side economizer.	6	Electric
12	AC-1 & R-1 CO2 Demand Controlled Ventilation	For AC-1, install at least one CO2 sensor in the return air duct of RF-1 and/or the space. Via the DDC control system, program the OA dampers to modulate between 0% to 10% minimum position to maintain a CO2 setpoint of approximately 900 PPM (adjustable), when the air-side economizer mode is off. For R-1, install at least one CO2 sensor in the return air duct of RF-3 and/or the space. Via the DDC control system, program the supply fan VFD to modulate to maintain a CO2 setpoint of approximately 900 PPM (adjustable), at all times. Program RF-3's VFD to track the supply fan R-1.	2	Electric
13	Synchronous Belts	As RF-1, RF-2, RF-3, RF-4, R-1, & R-4 shall be equipped with VFDs as per ECM #9, install synchronous / cog belts on these fans.	6	Electric
14	Retrofit VAVs & Install Occupancy Based Thermostats/Control	Retrofit approximately 60 VAV boxes from pneumatic to DDC controls communicating w/BAS. Replace hot water valves w/electronic actuators. For each VAV, install an occupancy-based or addressable thermostat. Program space temperature and VAV airflow setback setpoints when the space is unoccupied.	60	Electric
15	AC-1 & 2 Time of Day Schedules	Program AC-1 & 2 with time of day schedules to turn these units offline from approximately Midnight to 6:00 AM (adjustable) and turn them online during all other times. Also utilize the DDC system to turn off any zone exhasust fans in the areas served, AND cycle the units on if there is call for heating that cannot be handled by perimeter baseboards, or a call for cooling in core areas.	3	Electric
16	Install Occupancy Based Thermostats/Control in Guestrooms	Install occupancy-based thermostats in guestrooms. Re-locate space thermostat as necessary to properly sense space occupancy and program space temperature setback setpoints when the space is unoccupied (i.e. 68°F heating / 76°F cooling assumed during daytime hours).	360	Electric
17	Replace Kitchen Domestic Hot Water Heater	Remove existing gas fired domestic hot water (DHW) boiler. Install two or more new condensing DHW heater(s)/boiler(s) to meet DHW load/recovery requirements. Typical efficiency is 96.5% for all sizes.	2	Natural Gas
18	Enable Kitchen MUA AHU & Kitchen Hood Demand Controlled Ventilation	Enable the Kitchen makeup air unit (MUA) whenever the Kitchen Hood fans are on, reducing podium infiltration during these hours. Install demand controlled ventilation system on kitchen hood to modulate exhaust fan (EF-8) and kitchen make-up air unit (AC-3) similar to Melink system. Coordinate with AC unit refurbshment outlined in ECM #9. Ensure AC-3 & EF-8 operation are interlocked. Test and balance design airflows for EF-8 and AC-3 using new VFDs for minimum flow needed for capture and containment. Determine current required exhaust flow for EF-9 dish machine hood and reduce existig 2700 cfm if possible. Monitor status of this hood and reduce AC-3 flow when EF-9 is not enabled.	2	Electric

19	Upgrade Interior Lighting to LED Fixtures	Replace fluorescent T8 & T12 fixtures, as well as decorative fixtures that utilize incandescent/halogen lamps such as chandeliers, wall sconces, etc. throughout building with LED fixtures or lamps. Areas include loading dock, storage, kitchen, hallways, offices, restrooms, meeting rooms, etc.	2926	Electric
20	Upgrade Exterior Lighting to LED Fixtures	Replace parking lot T8 high bay fluorescent fixtures and "other" exterior fixtures with LED fixtures/lamps.	114	Electric
21	Lighting Occupancy Sensors	Install wall or ceiling mounted occupancy sensors to control the lighting in the restrooms, meeting rooms, banquet room, and offices.	69	Electric
22	Photocell Control for Skylight Cove Light Fixtures	Install a photocell sensor/controller for each of the four (4) skylights cove lighting for the purpose of dimming or turning off these lights during the day.	4	Electric