

Liberty State Park

Train Car Feeder. Damaged From Super Storm Sandy

Scope of Work

Location: Next to Northside of Train shed (1 Audrey Zapp Drive)

Specific work area will be identified during a scheduled field meeting with park staff.

Requirements: Contractor will have to submit State of New Jersey approved vendor paperwork. Contractor must be a licensed electrician in the State of New Jersey.

Project scope:

1. Remove and properly dispose of existing and replace with in kind the following:
 - a. 100-amp-600 volt Heavy Duty Safety Switch Nema 3R.
 - b. 37.5 KVA 480-volt to 120/240-volt 1-phase transformer Nema 3R.
 - c. 200-amp 240-volt Heavy Duty Safety Switch Nema 3R.
 - d. 100-amp 240-volt Heavy Duty Safety Switch Nema 3R.
 - e. Obtain any necessary permits and inspections.
 - f. Final billing invoice must include parts and labor breakdown.
2. All new work installed must be guaranteed to pass inspection and have a 1 year workmanship warranty and manufacturer's limited warranty on parts.

Timeframe: to complete work in fall 2014.

Please submit itemized quote on the attached (PB-120) form and e-mail it to LSPREPAIR@GMAIL.COM by:

Any questions contact: Greg Wentzel, Project Manager, Liberty State Park at 609-462-0218 (cell)

**STATE OF NEW JERSEY
DEPARTMENT OF THE TREASURY
AGENCY REQUEST FOR PROPOSAL**

VENDOR NAME AND ADDRESS:			RETURN THIS PROPOSAL TO:		DELIVER TO:	
SBE CATEGORY:			FAX NO:			
NOTE: This proposal must be received by the opening date/time:			AGENCY PERSON TO CONTACT:			
at the place named above.						
FISCAL YEAR	ACCOUNT NUMBER		AGENCY REFERENCE NO.		COMMODITY CODE NO:	
ITEM NO.	QUANTITY	UNIT	DESCRIPTION (ALL ITEMS MUST BE DELIVERED F.O.B. DESTINATION)		UNIT PRICE	AMOUNT
PRICES ARE FIRM UNTIL THE FOLLOWING DATE:					TOTAL	
CASH DISCOUNT		DATE OF DELIVERY	VENDOR'S FEDERAL I.D. NUMBER		VENDOR'S TELEPHONE NO.	
VENDOR'S SIGNATURE (Must be Signed):			PRINT OR TYPE NAME BELOW:		DATE:	