

Liberty State Park
Liberty Walk Lighting Control Repairs and Replacement
Scope of Work

Location: Westside Liberty Walkway
Main Walkway along water

Specific work areas will be identified during a scheduled field meeting with park staff.

Requirement: Licensed electrician in the State of New Jersey with approved vendor paperwork.

Project Scope:

1. Replace damaged components to electrical boxes that control light poles along Liberty Walk.
2. This may include installation of 8 suitable enclosures IE. (APX Pedestal enclosure model TCPE401615) or equal to raise the 100 amp disconnect switch or breaker panel to meet required code.
3. The enclosure will be mounted where the existing control is mounted.
4. Obtain all necessary permits and inspections.
5. Run new wire from transformer to disconnect.
6. Coordinate with PSEG on power source issues.

Timeframe to complete work spring 2013

Please use the enclosed PB-120 Form to submit an itemized quote and fax it to (201)915-3408

Contact: Greg Wentzel, Project Manager, Liberty State Park
(609)462-0218 (cell)