

Corporate Headquarters 7 Pleasant Hill Road Cranbury, NJ 08512 Tel: 732.390.5858 • Fax: 732.390.9496 www.whitmanco.com

March 9, 2017

Mr. Ronald Wybraniec New Jersey Department of Children and Families 50 East State Street Trenton, NJ 08608

RE: Lead in Water Sampling

New Jersey Department of Children and Families (NJDCF) Cape May Campus

131 Crest Haven Road

Cape May Court House, New Jersey

Whitman Project #16-11-49T

Dear Mr. Wybraniec:

The potable drinking water sampling, which consisted of eight (8) cold faucet samples, one (1) ice machine sample, and a laboratory blank sample, was conducted by Lisa Scarpelli of Whitman. First draw samples were collected from all sampling locations, in accordance with the USEPA and NJDEP protocols. All water samples and associated laboratory blanks were transported to Precision Analytical Services, Inc. located in Toms River, New Jersey for analysis. All sample analysis was performed utilizing the USEPA test method "Lead and Copper in Water by Furnace AAS (EPA 200.9)".

The samples collected from the Cape May Campus were found to be either ND or below the action level of 15.0 ppb established by the USEPA and the NJDEP. Below is a summary of the results. Sampling results are summarized below and are provided as an attachment to this letter.

School	Sample Location	Result (ug/L)
Cape May Campus	Room 107 cold faucet	ND
	Room 108 cold faucet	0.488 J
	Room 111 cold faucet	ND
	Room 115 cold faucet	ND
	Office (Room 105) cold faucet	ND
	Kitchen (Room 103) cold faucet	ND
	Kitchen ice machine – filtered sample	ND
	Room 120 cold faucet	ND
	Room 125 cold faucet	ND
	N/A (Laboratory Blank)	ND

Ronald Wybraniec New Jersey Division of Children and Families March 10, 2017 Page 2

Should you have any questions or require additional information, please feel free to contact our office at 732-390-5858.

Very truly yours,

Mark E. Hasting

Director

MEH/ Attachment

