



CERTIFICATE OF ANALYSIS

Customer : Whitman
7 Pleasant Hill Road
Cranbury, NJ 08512

Project ID : Monmouth Campus
PAS Project ID : P17-0851

Matrix : Drinking Water
Report Date : 3/2/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0851-01	KITCHEN-103-MC	Lead	0.746 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:05	2/27/17 11:02
P17-0851-02	SL-106 (STAFF LOUNGE)-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:10	2/27/17 11:11
P17-0851-03	CR-107-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:13	2/27/17 11:32
P17-0851-04	CR-108-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:20	2/27/17 11:36
P17-0851-05	CR-113-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:24	2/27/17 11:40
P17-0851-06	CR-114-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:27	2/27/17 11:44
P17-0851-07	COUNSELOR-117-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:30	2/27/17 11:53
P17-0851-08	CR-118-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:34	2/27/17 11:57
P17-0851-09	CR-119-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:38	2/27/17 12:01
P17-0851-10	CR-120-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:40	2/27/17 12:14
P17-0851-11	CR-121-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:42	2/27/17 12:19
P17-0851-12	CR-122-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:47	2/27/17 12:23
P17-0851-13	FIELD BLANK-MC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 08:49	2/27/17 12:28

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director