



CERTIFICATE OF ANALYSIS

Customer : Whitman
7 Pleasant Hill Road
Cranbury, NJ 08512

Project ID : Passaic Campus
PAS Project ID : P17-0856

Matrix : Drinking Water
Report Date : 3/3/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0856-01	01-PC-RM 117-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:40	2/27/17 11:58
P17-0856-02	02-PC-RM 118-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:41	2/27/17 12:03
P17-0856-03	03-PC-RM 120-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:42	2/27/17 12:07
P17-0856-04	04-PC-RM 119-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:43	2/27/17 12:11
P17-0856-05	05-PC-RM 121-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:44	2/27/17 12:24
P17-0856-06	06-PC-RM 122-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:45	2/27/17 12:29
P17-0856-07	07-PC-KITCHEN-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:46	2/27/17 12:33
P17-0856-08	08-PC-RM 106-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:47	2/27/17 12:37
P17-0856-09	09-PC-RM 107-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:50	2/27/17 12:42
P17-0856-10	10-PC-RM 108-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:51	2/27/17 12:46
P17-0856-11	11-PC-RM 113-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:52	2/27/17 12:50
P17-0856-12	12-PC-RM 114-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:54	2/27/17 13:12
P17-0856-13	13-PC-FIELD BLANK-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 10:56	2/27/17 13:16

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director