



Corporate Headquarters  
7 Pleasant Hill Road  
Cranbury, NJ 08512

Tel: 732.390.5858 • Fax: 732.390.9496  
www.whitmanco.com

March 9, 2017

Mr. Ronald Wybraniec  
New Jersey Department of Children and Families  
50 East State Street  
Trenton, NJ 08608

RE: Lead in Water Sampling  
New Jersey Department of Children and Families (NJDCF) Passaic Campus  
160 Minnisink Road  
Totowa, New Jersey  
**Whitman Project #16-11-49T**

Dear Mr. Wybraniec:

The potable drinking water sampling, which consisted of 13 cold faucet samples and a laboratory blank sample, was conducted by Bill Major of Whitman on February 20, 2017. First draw samples were collected from all sampling locations, in accordance with the USEPA and NJDEP protocols. All water samples and associated laboratory blanks were transported to Precision Analytical Services, Inc. located in Toms River, New Jersey for analysis. All sample analysis was performed utilizing the USEPA test method "Lead and Copper in Water by Furnace AAS (EPA 200.9)".

Lead was not detected in samples collected from the Passaic Campus. Water sampling results are summarized below and are provided as an attachment to this letter.

School	Location	ug/L
Passaic Campus	Room 117 cold faucet	ND
	Room 118 cold faucet	ND
	Room 120 cold faucet	ND
	Room 119 cold faucet	ND
	Room 121 cold faucet	ND
	Room 122 cold faucet	ND
	Kitchen cold faucet	ND
	Room 106 cold faucet	ND
	Room 107 cold faucet	ND
	Room 108 cold faucet	ND
	Room 113 cold faucet	ND
	Room 114 cold faucet	ND

Creating Solutions. Exceeding Expectations.

Ronald Wybraniec  
New Jersey Division of Children and Families  
March 10, 2017  
Page 2

Passaic Campus	N/A (Laboratory Blank)	ND
----------------	------------------------	----

Should you have any questions or require additional information, please feel free to contact our office at 732-390-5858.

Very truly yours,



Mark E. Hasting  
Director

MEH/  
Attachment