

GOP-009 Supporting Documentation
Manufacturer Specifications and Supporting Documentation

The Permittee shall submit documentation for the boiler at the time of registration showing:

1. The maximum rated heat input of the boiler, in millions of BTU per hour (HHV), per manufacturer's specifications, and
2. Manufacturer documentation showing that the boiler meets the New Jersey State-of-the-Art (SOTA) NO_x, CO and VOC emission levels (lb/MMBTU) listed below:

Fuel Type(s)	Pollutant	Emission Levels (Lb/MMBTU)
Natural Gas	NO_x	0.0350
	CO	0.0500
	VOC	0.00500