

7/21/2026 9:47 AM

DOCKET NO. D-2002-029 CP-5

DELAWARE RIVER BASIN COMMISSION

**Towamencin Municipal Authority
Wastewater Treatment Plant
Towamencin Township, Montgomery County, Pennsylvania**

PROCEEDINGS

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) on March 3, 2026 (Application), to renew the approval of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. The Pennsylvania Department of Environmental Protection (PADEP) issued National Pollutant Discharge Elimination System (NPDES) Permit No. PA0039004 for this discharge.

The application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Montgomery County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on August 5, 2026.

A. DESCRIPTION

1. **Purpose.** The purpose of this docket is to renew the approval of the docket holder's existing 6.5 million gallons per day (mgd) WWTP and its discharge.

2. **Location.** The docket holder's WWTP is located at Kriebel Road between its intersections with Bustard Road and Greens Lane Road in Towamencin Township, Montgomery County, Pennsylvania. The wastewater treatment plant (WWTP) will continue to discharge treated effluent to Towamencin Creek, which is tributary to Skippack Creek, which is tributary to Perkiomen Creek, which is tributary to Schuylkill River, at River Mile 92.47 – 32.3 – 3.0 – 7.6 – 1.4 (Delaware River – Schuylkill River – Perkiomen Creek – Skippack Creek – Towamencin Creek).

The location of the WWTP outfall is as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	40° 13' 46"	75° 21' 6"

3. **Area Served.** The docket holder's WWTP will continue to serve Towamencin and Upper Gwynedd Townships and portions of the adjacent municipalities of Worcester, Lower Salford, and Hatfield Township, and Lansdale Borough in Montgomery County, Pennsylvania. For the purpose of defining the Area Served, the Type of Discharge and the Service Area sections from the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in Section C. DECISION of this docket.

4. **Design Criteria.** The docket holder's 6.5 mgd WWTP utilizes an activated sludge treatment process and chlorine contact disinfection.

The WWTP discharges to Towamencin Creek through Outfall 003, which is located just downstream from a dam, unless stream flow is substantial, in which case two (2) upstream outfalls (Outfalls 001 & 002) are utilized.

The WWTP is designed for an annual average flow of 6.5 mgd, and a hydraulic design capacity of 7.3 mgd.

5. **Facilities.** The WWTP facilities consist of two (2) parallel treatment units and includes the following facilities three (3) comminutors, eight (8) rotating screens, (8) pre-aeration tanks, eight (8) aeration tanks, six (6) intermediate settling tanks, eight (8) final settling tanks, 13 chlorine contact tanks, and a sodium bisulfate dichlorination unit. PADEP issued Part II WQM Permit No. 4619403, which approved the addition of a Rag Compactor to the solids handling portion of the treatment train in 2019.

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be handled in accordance with the NPDES Permit No. PA0039004.

6. **Water Withdrawals.** The potable water supply in the project service area is provided by a series of groundwater wells owned and operated by North Penn Water Authority. The docket holder's water withdrawal is described in detail in Docket No. D-1992-044 CP-4, which was approved on September 16, 2015.

7. **NPDES Permit / DRBC Effluent Requirements.** NPDES Permit No. PA0039004 issued by the PADEP includes final effluent limitations for the project discharge to surface waters classified by the PADEP as supporting trout stocking (TSF) and migratory fishes (MF). EFFLUENT TABLES C-1 & C-2, included in Section C. DECISION condition C.1. of this docket contains effluent requirements for DRBC parameters that must be met as a condition of this approval. Effluent requirements for Outfall No. 001, 002, and 003 are based on a discharge rate of 6.5 mgd.

8. Relationship to the Comprehensive Plan. The existing WWTP was included in the Comprehensive Plan by Docket No. D-1964-061 CP-1 on June 24, 1964, which approved the construction of the WWTP (1.0 mgd design flow). The WWTP approval was renewed and/or modified by the dockets below. Issuance of this docket will continue the WWTP and its discharge in the Comprehensive Plan.

DOCKET NO.	APPROVAL DATE	WWTP MODIFICATION
D-1972-109 CP-1	April 25, 1973	Expansion (1.0 to 6.5 mgd)
D-1973-206 CP-1	January 24, 1974	Interim re-rating (prior to above expansion)
D-2002-029 CP-1	March 3, 2004	Hydraulic re-rate (6.5 to 7.3 mgd)
D-2002-029 CP-2	December 8, 2011	Renewal
D-2002-029 CP-3	June 11, 2014	Renewal
D-2009-029 CP-4	December 8, 2021	Renewal

B. FINDINGS

The docket holder applied to renew approval of their existing 6.5 mgd WWTP and its discharge.

1. Total Dissolved Solids (TDS)

The docket holder's principal Significant Industrial User (SIU); Clemens Food Group's (CFG) Hatfield Pork Processing Facility, contributes most of the TDS loading to the docket holder's WWTP. Since 2016, CFG has made plant operations changes and other improvements to reduce the concentration of TDS in their effluent, which have been reported by the docket holder to the DRBC through periodic TDS Updates. CFG's most recent efforts have included the construction and utilization of their new Industrial Wastewater Pretreatment Facility (IWPTF), enabling a nearly 40-percent reduction in TDS concentration in their wastewater from that of the former IWPTF.

However, monitoring results of the docket holder's WWTP effluent indicate that TDS in effluent continues to exceed 1000 mg/l. Based on this information, the docket holder is required to continue weekly TDS monitoring and reporting and will also continue to monitor potential sources of TDS and update DRBC staff with annual track down reports (See Section C. Condition C.1).

2. Other

At the docket holder's WWTP discharge, the Towamencin Creek has an estimated seven-day low flow with a recurrence interval of ten years (Q_{7-10}) of 0.25 mgd (0.39 cfs). The ratio of this low flow to the annual average flow from the 6.5 mgd WWTP is 0.04 to 1 (0.25 mgd/6.5 mgd).

The nearest surface water intake of record for public water supply is located on Perkiomen Creek approximately 12 River Miles downstream of the docket holder's WWTP and is operated by Aqua Pennsylvania.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit conform with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge that meets the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

C. DECISION

Effective on the approval date for Docket No. D-2002-029 CP-5 below, the project described in Docket No. D-2002-029 CP-4 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-2002-029 CP-5; Docket No. D-2002-029 CP-4 is terminated and replaced by Docket No. D-2002-029 CP-5; and the project and the appurtenant facilities described in Section A "DESCRIPTION" of this docket shall be included in the Comprehensive Plan. The project and appurtenant facilities as described in Section A of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

Monitoring and Reporting

1. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email aemr@drbc.gov on the **Annual Effluent Monitoring Report Form** located at this web address: <https://www.nj.gov/drbc/programs/project/docket-app-info.html#3>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit

OUTFALL 001,002,003 (Towamencin Creek)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6 to 9 at all times	As required by NPDES Permit
Total Suspended Solids	30 mg/l	As required by NPDES Permit

OUTFALL 001,002,003 (Towamencin Creek)		
PARAMETER	LIMIT	MONITORING
CBOD ₅ (at 20° C) (5/10-10/31) (11/01-4/30)	10 mg/l 20 mg/l	As required by NPDES Permit
CBOD ₅ (at 20° C) Influent	Monitor & Report	As required by NPDES Permit
Ammonia Nitrogen (5-1 to 10-31) (11-1 to 4-30)	1.0 mg/l 2.0 mg/l	As required by NPDES Permit
Fecal Coliform	200 colonies per 100 ml as a geo. avg.	As required by NPDES Permit
Total Dissolved Solids*	Monitor & Report	As required by NPDES Permit

* See DECISION Condition C.4

The following monitoring requirements and average monthly effluent limits are for DRBC parameters not listed in the NPDES Permit.

EFFLUENT TABLE C-2: DRBC Parameters Not Included in NPDES Permit

OUTFALL 001,002,003 (Towamencin Creek)		
PARAMETER	LIMIT	MONITORING
CBOD ₅ (at 20° C)	Monitor & Report Percent Removal	Monthly

Other Conditions

2. Nothing in this docket constitutes a defense to any penalty action for past conduct of the docket holder or ongoing activity not authorized by this approval. In particular, renewal of this docket does not resolve violations – whether in the past or continuing – of provisions of the Delaware River Basin *Compact* (“*Compact*”) or any rule, regulation, order or approval duly issued by the Commission or the Executive Director pursuant to the *Compact*. The Commission reserves its right to take appropriate enforcement action against the docket holder, including but not limited to recovery of financial penalties consistent with Section 14.17 of the *Compact*, for any and all such prior or continuing violations.

3. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

4. The docket holder may request permission from the Executive Director to perform specific conductance monitoring in lieu of TDS monitoring. The request shall be made in writing and shall include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow specific conductance monitoring in lieu of TDS monitoring.

5. In accordance with 18 C.F.R. 401.8. of the Commission’s *Rules of Practice and Procedure (RPP)*, if at any future time the Project is changed materially from the Project as described in this

docket, it will be deemed to constitute a new and different project for the purposes of Article 11 of the Delaware River Basin Compact and will require Commission amendment of the Comprehensive Plan. In accordance with the same section of the RPP, whenever a change to the Project is made, the sponsor must advise the Executive Director, who will determine whether the change is deemed material for purposes of this provision.

6. This approval shall expire on the expiration date set forth below unless prior thereto the docket holder has applied to the Commission to renew or extend this approval.

7. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 C.F.R. 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. If the docket holder has not applied to renew the docket or the DRBC is unable to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable pending the renewal of the docket.

8. The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference the Type of Discharge and Service Area sections of the docket holder's Application to the extent consistent with all other conditions of this section. Any expansion beyond that included in Section A.3. Area Served is subject to DRBC review and approval in accordance with Section 3.8 of the Compact.

9. In accordance with the Commission's regulations at 18 C.F.R. Part 440, the docket holder is prohibited from discharging wastewater from high volume hydraulic fracturing ("HVHF") or HVHF-related activities to waters or land within the Basin. Violation of this or any condition of this docket approval may result in enforcement, including the risk of financial penalties, pursuant to Section 14.17 of the Delaware River Basin Compact and Section 2.7.8 (18 CFR 401.98) of the Commission's Rules of Practice and Procedure.

10. The facility and operational records shall be available at all times for inspection by the DRBC.

11. The facility shall be operated at all times to comply with the requirements of the Commission's *WQR*.

12. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

13. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

14. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
15. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).
16. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, to ensure proper control, use and management of the water resources of the Basin.
17. The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 C.F.R. 401.43).
18. This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
19. The docket holder shall request a name change if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
20. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
21. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the *Rules of Practice and Procedure (RPP)*. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

BY THE COMMISSION

APPROVAL DATE:

EXPIRATION DATE: August 31, 2030