

7/17/2026 2:45 PM

DOCKET NO. D-2006-010 CP-4

DELAWARE RIVER BASIN COMMISSION

Discharge to a Tributary of Special Protection Waters

**Bedminster Municipal Authority
Pennland Farms Wastewater Treatment Plant
Bedminster Township, Bucks County, Pennsylvania**

PROCEEDINGS

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) on December 16, 2025 (Application), for renewal of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. The Pennsylvania Department of Environmental Protection (PADEP) issued National Pollutant Discharge Elimination System (NPDES) Permit No. PA0244066 for this discharge.

The Application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Bucks County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on August 5, 2026.

A. DESCRIPTION

1. **Purpose.** The purpose of this docket is to renew the approval of the docket holder's existing 0.06 million gallons per day (mgd) Pennland Farms WWTP and its discharge.
2. **Location.** The docket holder's WWTP is located on Elephant Road in Bedminster Township, Bucks County, Pennsylvania. The WWTP will continue to discharge treated effluent to an unnamed tributary (UNT) of Deep Run at River Mile 157.0 – 4.7 – 7.1 – 0.1 (Delaware River – Tohickon Creek – Deep Run – UNT of Deep Run) within the drainage area to the Lower Delaware Special Protection Waters (SPW), in Bedminster Township, Bucks County, Pennsylvania as follows:

The location of the WWTP outfall in the Deep Run Watershed as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	40° 22' 46.57"	75° 10' 40.16"

Specific location information has been withheld for security reasons.

3. **Area Served.** The docket holder's Pennland Farms WWTP will continue to serve the Pennland Farms residential development located in Bedminster Township, Bucks County, Pennsylvania. For the purpose of defining the Area Served, the Type of Discharge and the Service Area sections from the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in Section C. DECISION of this docket.

4. **Design Criteria.** The docket holder's existing 0.06 mgd WWTP utilizes an influent pump station with grinder, followed by dual Sequential Batch Reactor (SBR) train in parallel, filtration and ultraviolet light (UV) disinfection.

5. **Facilities.** The WWTP consists of an influent equalization tank, two (2) sequencing batch reactors (SBR) operated in parallel, two (2) aerobic digesters, an effluent equalization tank, a tertiary sand filter, and a UV disinfection unit.

The docket holder's wastewater treatment facility discharges to waters classified as SPW and is required to have available standby power. The existing WWTP has a generator installed capable of providing standby power.

The docket holder's wastewater treatment facility is not staffed 24 hours per day and shall have a remote alarm system that continuously monitors plant operations in accordance with the Commission's SPW requirements. The existing WWTP has a remote alarm system installed that continuously monitors plant operations.

The docket holder's existing wastewater treatment facility has prepared and implemented an emergency management plan (EMP) in accordance with Commission SPW requirements.

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site for disposal in accordance with the NPDES Permit No. PA0244066.

6. **Water Withdrawals.** The potable water supply in the project service area is provided by the docket holder's Pennland Farms water supply distribution system. The docket holder's water withdrawal is described in detail in Permit No. P-2004-032-3, which was approved on February 25, 2026.

7. **NPDES Permit / DRBC Effluent Requirements.** NPDES Permit No. PA0244066 issued by the PADEP includes final effluent limitations for the project discharge of 0.06 mgd to surface waters classified by the PADEP as supporting Warm Water Fishes (WWF) and Migratory Fishes (MF). EFFLUENT TABLES C-1 & C-2 included in Section C. DECISION Condition C.1. of this docket, contains effluent requirements for DRBC parameters that must be met as a condition of this approval.

8. **Relationship to the Comprehensive Plan.** The docket holder's 0.06 mgd WWTP was incorporated into the Comprehensive Plan on July 19, 2006 upon approval of Docket No. D-2006-10 CP-1. The project was continued by Docket Nos. D-2006-010 CP-2, D-2006-010 CP-3 and D-2006-010 CP-4 approved by the Commission on May 11, 2011, March 16, 2016 and September 10, 2020, respectively. Issuance of this docket (D-2006-010 CP-5) will continue the WWTP in the Comprehensive Plan.

B. FINDINGS

The docket holder applied to renew approval of their existing 0.06 mgd Pennland Farms WWTP and its discharge. No modifications to the WWTP are proposed.

1. Special Protection Waters

On July 16, 2008, the DRBC approved amendments to its *Water Quality Regulations (WQR)* that provide increased protection for waters that the Commission classifies as SPW. The portion of the Delaware River and its tributaries within the boundary of the Lower Delaware River Management Plan Area was approved for SPW designation.

The docket holder's WWTP discharges to the drainage area to the Lower Delaware SPW. The docket holder's WWTP discharge is required to comply with the SPW requirements, as outlined in Article 3.10.3A.2. of the *WQR*.

Article 3.10.3A.2.e.1). and 2). of the Commission's *WQR* states that projects subject to review under Section 3.8 of the *Compact* that are located in the drainage area of SPW must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the docket holder's service area which is also located within the drainage area of SPW. The service area of the docket holder is located in the drainage area to the SPW. Since this project does not entail additional construction or expansion of facilities and service area and there are no new or increased non-point source loads associated with this approval, the NPSPCP requirement is not applicable at this time. Accordingly, Section C. DECISION Condition C.2. has been included in this docket.

2. Other

At the WWTP discharge location, Deep Run has an estimated seven-day low flow with a recurrence interval of ten years (Q7-10) of less than 0.1 cubic feet per second (cfs) and therefore is classified by the Commission as an intermittent stream.

The nearest surface water intake of record for public water supply is located on the Delaware River approximately 12 River Miles downstream of the docket holder's WWTP and is operated by North Penn Water Authority (NPWA).

The project as approved herein does not impair or conflict with the Comprehensive Plan.

The effluent limits in the NPDES Permit meet or exceed Commission effluent quality requirements where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

C. DECISION

Effective on the approval date for Docket No. D-2006-010 CP-5 below, the project described in Docket No. D-2006-010 CP-4 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-2006-010 CP-5; Docket No. D-2006-010 CP-4 is terminated and replaced by Docket No. D-2006-010 CP-5; and the project and the appurtenant facilities described in Section A "DESCRIPTION" of this docket shall be continued in the Comprehensive Plan. The project and appurtenant facilities as described in Section A of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

Monitoring and Reporting

1. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email aemr@drbc.gov on the **Annual Effluent Monitoring Report Form** located at this web address: <https://www.nj.gov/drbc/programs/project/docket-app-info.html#3>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit

OUTFALL 001 (Discharge to Deep Run)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6 to 9 at all times	As required by NPDES permit
Dissolved Oxygen	6.0 minimum	As required by NPDES permit
Total Suspended Solids	10 mg/l	As required by NPDES permit
CBOD5 (5-Day at 20° C)	10 mg/l (85% Removal)	As required by NPDES permit

OUTFALL 001 (Discharge to Deep Run)		
PARAMETER	LIMIT	MONITORING
Total Nitrogen	10 mg/l	As required by NPDES permit
Ammonia Nitrogen (5-1 to 10-31) (11-1 to 4-30)	1.5 mg/l 3.0 mg/l	As required by NPDES permit
Total Phosphorus	0.5 mg/l	As required by NPDES permit
Fecal Coliform	50 colonies per 100 ml as a geo. avg.	As required by NPDES permit

The following monitoring requirements and average monthly effluent limits are for DRBC parameters not listed in the NPDES Permit.

EFFLUENT TABLE C-2: DRBC Parameters Not Included in NPDES Permit

OUTFALL 001 (Discharge to Deep Run)		
PARAMETER	LIMIT	MONITORING
Total Dissolved Solids*	1,000 mg/l	Quarterly
Nitrate as N	Monitor & Report	Monthly

* See DECISION Condition C.5.

Other Conditions

2. Prior to allowing connections from any new service areas or any new developments, the docket holder shall either submit and have approved by the Executive Director of the DRBC a NPSPCP in accordance with Section 3.10.3.A.2.e, of the *WQR* or receive written confirmation from the Executive Director of the DRBC that the new service area complies with a DRBC-approved NPSPCP.

3. Prior to the docket holder initiating any substantial alterations or additions to the existing WWTP as defined in Section 3.10.3A2.a.16) of the Commission's *WQR*, an application must be submitted and approved by the Commission. Such an application shall be submitted prior to final design to ensure that the Commission can provide the docket holder with draft effluent limitations for SPW specific parameters as guidance for design as to not require duplication of work or cause a substantial expenditure of public funds without Commission approval. The docket holder is encouraged to contact the Commission staff during the planning stages to identify the potential effluent limitations required to meet the no measurable change parameters under SPW.

4. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

5. The docket holder may request permission from the Executive Director to perform specific conductance monitoring in lieu of TDS monitoring. The request shall be made in

writing and shall include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow specific conductance monitoring in lieu of TDS monitoring.

6. In accordance with 18 C.F.R. 401.8. of the Commission's *Rules of Practice and Procedure (RPP)*, if at any future time the Project is changed materially from the Project as described in this docket, it will be deemed to constitute a new and different project for the purposes of Article 11 of the *Delaware River Basin Compact* and will require Commission amendment of the Comprehensive Plan. In accordance with the same section of the *RPP*, whenever a change to the Project is made, the sponsor must advise the Executive Director, who will determine whether the change is deemed material for purposes of this provision.

7. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 C.F.R. 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. If the docket holder has not applied to renew the docket or the DRBC is unable to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable pending the renewal of the docket.

8. The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference the Type of Discharge and Service Area sections of the docket holder's Application to the extent consistent with all other conditions of this section. Any expansion beyond that included in Section A.3. Area Served is subject to DRBC review and approval in accordance with Section 3.8 of the *Compact*.

9. In accordance with the Commission's regulations at 18 C.F.R. Part 440, the docket holder is prohibited from discharging wastewater from high volume hydraulic fracturing ("HVHF") or HVHF-related activities to waters or land within the Basin. Violation of this or any condition of this docket approval may result in enforcement, including the risk of financial penalties, pursuant to Section 14.17 of the *Delaware River Basin Compact* and Section 2.7.8 (18 CFR 401.98) of the Commission's *Rules of Practice and Procedure*.

10. The facility and operational records shall be available at all times for inspection by the DRBC.

11. The facility shall be operated at all times to comply with the requirements of the Commission's *WQR*.

12. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

13. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.
14. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
15. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).
16. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.
17. The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 CFR 401.43).
18. This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 CFR 401.43).
19. The docket holder shall request a name change if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 CFR 401.43).
20. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
21. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the *Rules of Practice and Procedure*. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

BY THE COMMISSION

APPROVAL DATE:

EXPIRATION DATE: April 30, 2031