

Analysis Compliance Summary For:		
<input type="checkbox"/> Inorganic {Metals}	<input type="checkbox"/> Microbiological	PFAS – Perfluoro Alkyl Substances
<input type="checkbox"/> Secondary	<input type="checkbox"/> Synthetic Organic	PFOS – Perfluorooctane Sulfonic Acid [.013 ppd]
<input type="checkbox"/> Trihalomethanes/Radionuclides	<input type="checkbox"/> Volatile Organic	PFOA – Perfluorooctanonic Acid [.014 ppd]

Provide a complete description of water treatment processes used and attach additional sheets as necessary. Submit water analysis for both source water and finished product for microbiological, inorganic, volatile, semi-volatile, synthetic organic, secondary standards, radiological and total trihalomethane result. Source water testing of community water supplies is not required. See the Bottled Water Quality Standards for specific testing parameters.

<b>Inspection Agency:</b>	<b>Date Last Inspected:</b>
Label Review: <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Bottler <input type="checkbox"/> Bulk Water Facility

**WATER ANALYSIS:** Fill in all results and attach lab reports      Analysis Date:      Container Size:

Inorganic Compounds MCL			COMPOUND		
Contaminants	ppb	Standard		ppb	Standard
Antimony		6	Fluoride		2400
Arsenic		10	Lead		5
Asbestos		7x10 <sup>6</sup> fibers/1>10um	Mercury		2
Barium		2000	Nitrate		10000
Beryllium		4	Nitrite		1000
Cadmium		5	Nitrate/Nitrite		10000
Chromium		100	Selenium		50
Copper		1000	Thallium		2
Cyanide		200			
Synthetic Organic Compounds					
Alachlor		2	Heptachlor		0.4
Atrazine		3	Heptachlor Epoxide		0.2
Benzo[a]pyrene		0.2	Hexachlorobenzene		1
Carbofuran		40	Hexachloropentadiene		50
Chlordane		0.5	Lindane		0.2
Dalapon		200	Methoxychlor		40
DBCP		0.2	Oxamyl		200
Di[2-ethylhexyl] adipate		400	PCBs		0.5
Di[2-ethylhexyl] phthalate		6	Pentachlorophenol		1
Dinoseb		7	Picloram		500
Diquat		20	Simazine		4
Endothall		100	Toxaphene		3
Endrin		2	2,3,7,8-TCDD (Dioxin)		3x10 <sup>-5</sup>
EDB		0.05	Silvex		50
Glyphosate		700	2,4-D		70
Volatile Organic Compound					
Benzene		1	Methylene Chloride		3
Carbon Tetrachloride		2	Monochlorobenzene		50
Meta-Dichlorobenzene		600	Napthalene		300
Ortho-Dichlorobenzene		600	Styrene		100
Para-Dichlorobenzene		75	1,1,2,2-Tetrachloroethane		1
1,1-Dichloroethane		50	Tetrachloroethylene		1
1,2-Dichloroethane		2	Toluene		1000
1,1-Dichloroethylene		2	1,2,4-Trichlorobenzene		9
Cis-1,2-Dichloroethylene		70	1,1,1-Trichloroethane		30
Trans-1,2-Dichloroethylene		100	1,1,2-Trichloroethane		3

<b>Volatile Organic Compound</b>					
<b>Contaminants</b>			<b>Contaminants</b>		
<b>ppb</b>	<b>Standard</b>		<b>ppb</b>	<b>Standard</b>	
1,2-Dichloropropane	5		Trichloroethylene	1	
Ethylbenzene	700		Vinyl Chloride	2	
Methyl tertiary Butyl Ether	70		Xylenes	1000	
Phenols	1		Perfluorooctane Sulfonic Acid	0.13	
Perfluorononanoic Acid	0.13		Perfluorooctanoic Acid	0.14	
1,2,3 Trichloropropane	0.03				
<b>Secondary Standards</b>			<b>Secondary Standards</b>		
<b>result</b>			<b>result</b>		
Color	10 color units		pH	6.5 to 8.5 range	
Odor	3 threshold		Taste	Non-objectionable	
Turbidity	5 NTU				
<b>Secondary Standards</b>			<b>Secondary Standards</b>		
<b>ppm</b>			<b>ppm</b>		
Chlorine	4000		Chloramine	4000	
Chlorine Dioxide	800		Haloacetic Acides	60	
Chorite	1000		Bromate	10	
Foaming Agents (MBAS)	0.5		Aluminum	0.2	
Chloride	250		Fluoride	2	
Hardness	250		Iron	0.3	
Manganese	0.05		Silver	0.1	
Sodium	50		Sulfate	250	
Total Dissolved Solids (TDS)	500		Zinc	5	
<b>Trihalomethanes</b>			<b>Radionuclides</b>		
<b>ppb</b>			<b>MCL in pCi/l</b>		
Bromoform			Gross Alpha		15
Dichlorobromomethane			Gross Beta		50
Chloroform			Radium 226		
Dichlorobromomethane			Radium 228		
Total Trihalomethanes	80		Radium 226 and 228		5
<b>Microbiological</b>			<b>Microbiological</b>		
<b>Present</b>	<b>Absent</b>		<b>Present</b>	<b>Absent</b>	
Total Coliform			Fecal Coliform		
Positive Details:					

**KEY: One microgram per liter (ug/l) is equal to one part per billion (ppb)**